



WEST LINN - WILSONVILLE SCHOOL DISTRICT

Water Quality Information

July 21, 2016

Dear Willamette Families,

This letter is being sent to update you about the water quality testing results that were shared last week. The initial results from July testing at Willamette Primary School showed that out of 78 test locations, 2 indicated elevated levels of lead that exceeded the action level of 20 parts per billion. This included a bubbler in a classroom sink and a sink in a restroom.

Immediate remediation steps were taken include turning water off at these locations, replacing subject fixtures, and retesting. After remediation, water was retested on July 18 and 19. Both fixtures tested below the action level of 20 ppb. These results have cleared all fixtures at Willamette Primary School for elevated levels of lead or copper.

More information about District water quality testing is available at <http://www.wlww.k12.or.us/Page/10603>.

West Linn-Wilsonville School District
Department of Operations
Tim K. Woodley, Director

22210 SW Stafford Road Tualatin OR 97062
Business: 503.673.7000 Fax: 503.673.7001

www.wlww.k12.or.us