

Lead in Water Test Results Summary: Athey Creek Middle School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

Legend:

- Test results **equal to or greater than the Action Level** of 15 ppb are **highlighted in red and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **near the Action Level** of 15 ppb (11.99 to 14.99 ppb) are **highlighted in yellow and precede a "Med" (Medium) value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
C125-Nurses station sink	19220800-001NS	4/25/2024	ND	Low		ND	Low
C123- Bathroom faucet. Bathroom off the nurses station	19220800-002BF	4/25/2024	ND	Low		ND	Low
C124-Bathroom faucet. Single user staff restroom. Located in the main office	19220800-004BF	4/25/2024	ND	Low		ND	Low
C125-Bathroom faucet. Single user staff restroom. Located in the main office	19220800-005BF	4/25/2024	ND	Low		ND	Low
C131-Staff faucet. In the workroom	19220800-006SF	4/25/2024	ND	Low		ND	Low
A109-Classroom faucet. Art room, left	19220800-007CF	4/25/2024	ND	Low		ND	Low
A109-Drinking water. Art room. Left center	19220800-008DW	4/25/2024	ND	Low		ND	Low
A109-Classroom faucet. Art room. Center	19220800-009CF	4/25/2024	ND	Low		ND	Low
A109-Drinking water. Art room. Right center	19220800-010DW	4/25/2024	ND	Low		ND	Low
A109-Classroom faucet. Art room. Right	19220800-011CF	4/25/2024	ND	Low		ND	Low
A112-Classroom faucet. Choir room. Left	19220800-012CF	4/25/2024	ND	Low		ND	Low
A112-Drinking water. Choir room. Right	19220800-013DW	4/25/2024	ND	Low		ND	Low
A116-Classroom faucet. Band room. Right equipment cleaning sink	19220800-014CF	4/26/2024	ND	Low		ND	Low
A116-Classroom faucet. Band room. Left	19220800-015CF	4/25/2024	ND	Low		ND	Low
A116-Drinking water. Bandroom.Center	19220800-016DW	4/25/2024	ND	Low		ND	Low
A120-Water bottle filler. Vestibule leading into gym. Left	19220800-017WB	4/25/2024	ND	Low		ND	Low
A120-Water chiller. Vestibule leading into gym. Center, same fixture as water bottle filler.	19220800-018WC	4/25/2024	ND	Low		ND	Low
A120-Water chiller. Vestibule leading into gym. Left	19220800-019WC	4/25/2024	ND	Low		ND	Low
A103-Bathroom faucet. Boy's restroom across from the Bandroom.Duo sinks. Left	19220800-020BF	4/25/2024	ND	Low		ND	Low
A103-Bathroom faucet. Boy's restroom across from the Band room. Duo sinks. Right	19220800-021BF	4/25/2024	ND	Low		ND	Low
A103-Bathroom faucet. Boy's restroom across from the Band room. Trio of sinks. Right	19220800-022BF	4/25/2024	ND	Low		ND	Low
A103-Bathroom faucet. Boy's restroom across rom the Band room. Trio of sinks. Center	19220800-023BF	4/25/2024	ND	Low		ND	Low
A103-Bathroom faucet. Boy's restroom across from the Band room. Trio of sinks. Left	19220800-024BF	4/25/2024	ND	Low		ND	Low
A104-Bathroom faucet. Girl's restroom across from the choir room. Duo of sinks. Left, Southeast facing	19220800-025BF	4/25/2024	ND	Low		ND	Low
A104- Bathroom faucet. Girl's restroom across from the choir room.Duo of sinks. Right, Southeast facing	19220800-026BF	4/25/2024	ND	Low		ND	Low
A104-Bathroom faucet. Girl's restroom across from the choir room. Trio of sinks. Left, Southwest facing	19220800-027BF	4/25/2024	ND	Low		ND	Low

A104-Bathroom faucet. Girl's restroom across from the choir room. Trio of sinks. Center, Southwest facing	19220800-028BF	4/25/2024	ND	Low		ND	Low
A104-Bathroom faucet. Girl's restroom across from the choir room. Trio of sinks. Right . Southwest facing	19220800-029BF	4/25/2024	ND	Low		ND	Low
A105-Bathroom faucet. Single user restroom across from the Choir room.	19220800-030BF	4/25/2024	ND	Low		ND	Low
A106-Bathroom faucet. Single user restroom located off Porch A121, across from the platform storage	19220800-031BF	4/25/2024	ND	Low		ND	Low
B118-Classroom faucet. Right. Located at platform storage	19220800-032CF	4/25/2024	ND	Low		ND	Low
B118-Drinking water. Left. Located at the platform storage	19220800-033DW	4/25/2024	ND	Low		ND	Low
B125-Water chiller. Located in the gym vestibule. Left	19220800-034WC	4/25/2024	ND	Low		ND	Low
B125-Water bottle filler. Located in the gym vestibule. Center	19220800-035WB	4/25/2024	ND	Low		ND	Low
B125-Water bottle filler. Located in the gym vestibule. Right, same fixture as water bottle filler	19220800-036WC	4/25/2024	ND	Low		ND	Low
B100-Bathroom faucet. Boy's locker room. Right	19220800-037BF	4/25/2024	ND	Low		ND	Low
B100-Bathroom faucet. Boy's locker room. Center	19220800-038BF	4/25/2024	ND	Low		ND	Low
B100-Bathroom faucet. Boy's locker room. Left	19220800-039BF	4/25/2024	ND	Low		ND	Low
B101-Bathroom faucet. Girl's locker room. Left	19220800-041BF	4/25/2024	ND	Low		ND	Low
B101-Bathroom faucet. Girl's locker room. Center	19220800-042BF	4/25/2024	ND	Low		ND	Low
B101-Bathroom faucet. Girl's locker room. Right	19220800-043BF	4/25/2024	ND	Low		ND	Low
B108-Bathroom faucet. Single user restroom across from locker room	19220800-045BF	4/25/2024	ND	Low		ND	Low
B109-Bathroom faucet. Single user restroom across from locker room	19220800-046BF	4/25/2024	ND	Low		ND	Low
C102-Classroom faucet. Student store	19220800-048CF	4/25/2024	1.8	Low		1.8	Low
C100-Water cooler. Far left. Lower commons	19220800-049WC	4/25/2024	ND	Low		ND	Low
C100-Water bottle filler. Left center. Lower commons	19220800-050WB	4/25/2024	ND	Low		ND	Low
C100-Water chiller. Left center, located with the bottle filler. Lower commons	19220800-051WC	4/25/2024	ND	Low		ND	Low
C100-Classroom faucet. Right center. Lower commons	19220800-052CF	4/25/2024	ND	Low		ND	Low
C100-Classroom faucet. Right. Lower commons	19220800-053CF	4/25/2024	ND	Low		ND	Low
C133-Kitchen faucet, sprayer. Left, south facing pot washing sink	19220800-054KF	4/25/2024	3.2	Low		3.2	Low
C133-Kitchen faucet, sprayer. Right attached to 19220800-056KF south facing pot washing sink	19220800-055KF	4/25/2024	ND	Low		ND	Low
C133-Kitchen faucet. Right, south facing pot washing sink	19220800-056KF	4/25/2024	ND	Low		ND	Low
C133-Kitchen faucet. Center, north facing pot washing sink	19220800-057KF	4/25/2024	ND	Low		ND	Low
C133-Kitchen faucet, sprayer. Right, north facing, pot washing sink. Attached to 19220800-059KF	19220800-058KF	4/25/2024	ND	Low		ND	Low
C133-Kitchen faucet. Right, north facing, pot washing sink. Attached to 19220800-058KF kitchen sprayer	19220800-059KF	4/25/2024	ND	Low		ND	Low

C133-Kitchen faucet. Left, north facing, hand washing sink	19220800-060KF	4/25/2024	ND	Low		ND	Low
C133-Kitchen faucet. South facing, hand washing sink. Left of the ovens	19220800-061KF	4/25/2024	ND	Low		ND	Low
C133-Kitchen faucet. Right, south facing, food prep sink. Located in the island closest to the freezer and refrigerator	19220800-062KF	4/25/2024	ND	Low		ND	Low
C133-Kitchen faucet, sprayer. Right, south facing, food prep sink. Attached to 19220800-062KF. Located in the island closest to the freezer and refrigerator	19220800-063KF	4/25/2024	ND	Low		ND	Low
C133-Kitchen faucet. Left, south facing. Hand washing sink. Next to the island closest to the freezer and refrigerator.	19220800-064KF	4/25/2024	ND	Low		ND	Low
C133-Kitchen faucet. Hand washing sink. Left of the serving line.	19220800-065KF	4/25/2024	1.3	Low		1.3	Low
C108-Bathroom faucet. Single user, farthest right bathroom. Located off Porch C111	19220800-066BF	4/25/2024	ND	Low		ND	Low
C108-Bathroom faucet. Left. Trio of faucets outside restrooms. Located off Porch C111	19220800-067BF	4/25/2024	ND	Low		ND	Low
C108-Bathroom faucet. Center. Trio of faucets outside restrooms. Located off Porch C111	19220800-068BF	4/25/2024	ND	Low		ND	Low
C108-Bathroom faucet. Right. Trio of faucets outside restrooms. Located off Porch C111	19220800-069BF	4/25/2024	ND	Low		ND	Low
C121-Classroom faucet. Left	19220800-070CF	4/25/2024	ND	Low		ND	Low
C121-Drinking water . Right	19220800-071DW	4/25/2024	ND	Low		ND	Low
C119-Classroom faucet. Left	19220800-072CF	4/25/2024	ND	Low		ND	Low
C119-Drinking water. Right	19220800-073DW	4/25/2024	ND	Low		ND	Low
C118-Classroom faucet. Left	19220800-074CF	4/25/2024	ND	Low		ND	Low
C118-Drinking water. Right	19220800-075DW	4/25/2024	ND	Low		ND	Low
C117-Classroom faucet. Left	19220800-076CF	4/25/2024	ND	Low		ND	Low
C117-Drinking water. Right	19220800-077DW	4/25/2024	ND	Low		ND	Low
C116-Classroom faucet. Left	19220800-078CF	4/25/2024	ND	Low		ND	Low
C116-Drinking water. Right	19220800-079DW	4/25/2024	ND	Low		ND	Low
C115-Classroom faucet. Center. North facing	19220800-080CF	4/26/2024	ND	Low		ND	Low
C115. Drinking water. North facing. Right	19220800-081DW	4/26/2024	ND	Low		ND	Low
C115-Classroom faucet. North facing. Left	19220800-082CF	4/25/2024	ND	Low		ND	Low
C115-Classroom faucet. West facing. Center	19220800-084CF	4/25/2024	ND	Low		ND	Low
C115-Classroom faucet. West facing. Left	19220800-085CF	4/25/2024	ND	Low		ND	Low
C115-Classroom faucet. South facing. Right	19220800-086CF	4/25/2024	ND	Low		ND	Low
C115-Classroom faucet. South facing. Left	19220800-087CF	4/25/2024	ND	Low		ND	Low
C115-Located in the island at the front of class	19220800-088CF	4/25/2024	ND	Low		ND	Low
C113-Classroom faucet. Science prep room	19220800-089CF	4/25/2024	ND	Low		ND	Low
D102-Classroom faucet. Left. Makers space	19220800-090CF	4/25/2024	ND	Low		ND	Low
D102-Classroom faucet. Right. Makers space	19220800-091CF	4/25/2024	ND	Low		ND	Low
D102-Drinking water. Center. Makers space	19220800-092DW	4/25/2024	ND	Low		ND	Low
E111-Classroom faucet. South facing. Left	19220800-093CF	4/25/2024	ND	Low		ND	Low
E111-Drinking water. South facing. Center	19220800-094DW	4/25/2024	ND	Low		ND	Low
E111 -Classroom faucet. South facing. Right	19220800-095CF	4/25/2024	ND	Low		ND	Low
E111-Classroom faucet. Southwest facing. Center	19220800-097CF	4/25/2024	ND	Low		ND	Low
E111-Classroom faucet. Southwest facing. Right	19220800-098CF	4/25/2024	ND	Low		ND	Low
E111-Classroom faucet. West facing . Left	19220800-099CF	4/25/2024	ND	Low		ND	Low
E111-Classroom faucet. West facing. Right	19220800-100CF	4/25/2024	ND	Low		ND	Low
E111- Located in the island at the front of class	19220800-101CF	4/25/2024	ND	Low		ND	Low
E113-Classroom faucet. Science prep room	19220800-102CF	4/25/2024	ND	Low		ND	Low
E110-Classroom faucet. Left	19220800-103CF	4/25/2024	ND	Low		ND	Low
E110-Drinking water. Right	19220800-104DW	4/25/2024	ND	Low		ND	Low
E109-Classroom faucet. Left	19220800-105CF	4/25/2024	ND	Low		ND	Low
E109-Drinking water. Right	19220800-106DW	4/25/2024	ND	Low		ND	Low

E108-Classroom faucet. Left	19220800-107CF	4/25/2024	ND	Low		ND	Low
E108-Drinking water. Right	19220800-108DW	4/25/2024	ND	Low		ND	Low
E107-Classroom faucet. Left	19220800-109CF	4/25/2024	ND	Low		ND	Low
E107-Drinking water. Right	19220800-110DW	4/25/2024	ND	Low		ND	Low
E105-Classroom faucet. Left	19220800-111CF	4/25/2024	ND	Low		ND	Low
E105-Drinkin water. Right	19220800-112DW	4/25/2024	ND	Low		ND	Low
E102-Bathroom faucet.Left.Girl's restroom located off Porch E114	19220800-113BF	4/25/2024	ND	Low		ND	Low
E102-Bathroom faucet.Right.Girl's restroom located off Porch E114	19220800-114BF	4/25/2024	ND	Low		ND	Low
E101-Bathroom faucet. Single user located between girl's and boy's restroom off Porch E114	19220800-115BF	4/25/2024	ND	Low		ND	Low
E114-Water bottle filler. Center. Located outside the single user restroom E101	19220800-116WB	4/25/2024	ND	Low		ND	Low
E114- Water chiller. Located in the same fixture as 19220800-116WB. Right	19220800-234WC	4/25/2024	ND	Low		ND	Low
E114-Water chiller. Left. Located outside the single user restroom E101	19220800-117WC	4/25/2024	ND	Low		ND	Low
E100-Bathroom faucet. Right. Boy's restroom. Located off Porch E114	19220800-118BF	4/25/2024	ND	Low		ND	Low
E100-Bathroom faucet. Left. Boy's restroom. Located off Porch E114	19220800-119BF	4/25/2024	ND	Low		ND	Low
E210-Classroom faucet. South facing. Left.	19220800-120CF	4/25/2024	ND	Low		ND	Low
E210-Drinking water. South facing. Center	19220800-121DW	4/25/2024	ND	Low		ND	Low
E210-Classroom faucet. South facing. Right	19220800-122CF	4/25/2024	ND	Low		ND	Low
E210-Classroom faucet. West facing. Center	19220800-124CF	4/25/2024	ND	Low		ND	Low
E210-Classroom faucet. West facing. Right	19220800-125CF	4/25/2024	ND	Low		ND	Low
E210-Classroom faucet. Northwest facing. Left	19220800-126CF	4/25/2024	ND	Low		ND	Low
E210-Classroom faucet. Northwest facing. Right	19220800-127CF	4/25/2024	ND	Low		ND	Low
E210-Classroom faucet. Located in the island at the front of class	19220800-128CF	4/25/2024	ND	Low		ND	Low
E211-Classroom faucet.Science prep room	19220800-129CF	4/25/2024	ND	Low		ND	Low
E209-Classroom faucet. Left	19220800-130CF	4/25/2024	ND	Low		ND	Low
E209- Drinking water. Right	19220800-131DW	4/25/2024	ND	Low		ND	Low
E208-Classroom faucet. Left	19220800-132CF	4/25/2024	ND	Low		ND	Low
E208-Drinking water. Right	19220800-133DW	4/25/2024	ND	Low		ND	Low
E207-Classroom faucet. Left	19220800-134CF	4/25/2024	ND	Low		ND	Low
E207-Drinking water. Right	19220800-135DW	4/25/2024	ND	Low		ND	Low
E206-Classroom faucet. Left	19220800-136CF	4/25/2024	ND	Low		ND	Low
E206-Drinking water Right	19220800-137DW	4/25/2024	ND	Low		ND	Low
E204-Classroom faucet. Left	19220800-138CF	4/25/2024	ND	Low		ND	Low
E204-Drinking water. Right	19220800-139DW	4/25/2024	ND	Low		ND	Low
E203-Bathroom faucet. Left. Girl's restroom located off Porch E213	19220800-140BF	4/25/2024	ND	Low		ND	Low
E203-Bathroom faucet.Right.Girl's restroom located off Porch E213	19220800-141BF	4/25/2024	ND	Low		ND	Low
E202-Bathroom faucet. Single user restroom. Located between the girls and boys restroom of Porch E213	19220800-142BF	4/25/2024	ND	Low		ND	Low
E200-Bathroom faucet. Left. Boy's restroom located off Porch E213	19220800-143BF	4/25/2024	ND	Low		ND	Low
E200-Bathroom faucet. Right. Boy's restroom located off Porch E213	19220800-144BF	4/25/2024	ND	Low		ND	Low
E213-Water bottle filler. Center. Located outside the single user restroom E202.	19220800-145WB	4/25/2024	ND	Low		ND	Low
E213- Water chiller. Right. Located in the same fixture as 19220800-145WB	19220800-237WC	4/25/2024	ND	Low		ND	Low
E213-Water chiller. Left. Located outside the single user restroom E202	19220800-146WC	4/25/2024	ND	Low		ND	Low
D203-Classroom faucet. Left	19220800-147CF	4/25/2024	ND	Low		ND	Low
D203-Drinking water. Right	19220800-148DW	4/25/2024	ND	Low		ND	Low
D202-Classroom faucet. Left	19220800-149CF	4/25/2024	ND	Low		ND	Low

D202-Drinking water. Right	19220800-150DW	4/25/2024	ND	Low		ND	Low
D201-Classroom faucet. Left	19220800-151CF	4/25/2024	1.4	Low		1.4	Low
D201-Drinking water . Right	19220800-152DW	4/25/2024	ND	Low		ND	Low
D200-Classroom faucet. Left	19220800-153CF	4/25/2024	2.9	Low		2.9	Low
D200-Drinking water. Right	19220800-154DW	4/25/2024	ND	Low		ND	Low
D210-Classroom faucet. Right	19220800-155CF	4/25/2024	1.7	Low		1.7	Low
D210-Drinking water. Left	19220800-156DW	4/25/2024	ND	Low		ND	Low
D209 -Classroom faucet. South facing. Center	19220800-158CF	4/25/2024	ND	Low		ND	Low
D209-Drinking water. South facing. Right	19220800-159DW	4/25/2024	ND	Low		ND	Low
D209-Classroom faucet. West facing. Left	19220800-160CF	4/25/2024	ND	Low		ND	Low
D209-Classroom faucet. West facing. Center	19220800-161CF	4/25/2024	ND	Low		ND	Low
D209-Classroom faucet. West facing. Right	19220800-162CF	4/25/2024	ND	Low		ND	Low
D209-Classroom faucet. North facing. Left	19220800-163CF	4/25/2024	ND	Low		ND	Low
D209-Classroom faucet. North facing. Right	19220800-164CF	4/25/2024	ND	Low		ND	Low
D209-Classroom faucet. Located in the island at the front of the classroom	19220800-165CF	4/25/2024	ND	Low		ND	Low
D211-Water chiller . Left. Outside restroom D208	19220800-166WC	4/25/2024	ND	Low		ND	Low
D211-Water bottle filler. Center. Outside restroom D208	19220800-167WB	4/25/2024	ND	Low		ND	Low
D211- Water chiller. Right. Outside restroom D208.Center.Located in the same fixture as 19220800-167WB	19220800-243WC	4/25/2024	ND	Low		ND	Low
D208-Bathroom faucet. Single user restroom. Located off Porch D211	19220800-168BF	4/25/2024	ND	Low		ND	Low
C206-Single user restroom. Far right. Located off Porch C218	19220800-169BF	4/25/2024	ND	Low		ND	Low
C206 -Bathroom faucet. Left. Trio of faucets. Located off Porch C218	19220800-170BF	4/25/2024	ND	Low		ND	Low
C206-Bathroom faucet. Center. Trio of sinks. Located off Porch C218	19220800-171BF	4/25/2024	ND	Low		ND	Low
C206-Bathroom faucet. Right. Trio of sinks. Located off Porch C218	19220800-172BF	4/25/2024	ND	Low		ND	Low
C217-Classroom faucet. Left	19220800-173CF	4/25/2024	ND	Low		ND	Low
C217-Drinking water. Right	19220800-174DW	4/25/2024	ND	Low		ND	Low
C215-Classroom faucet. Left	19220800-175CF	4/25/2024	ND	Low		ND	Low
C215-Drinking water. Right	19220800-176DW	4/25/2024	ND	Low		ND	Low
C214-Classroom faucet. Left	19220800-177CF	4/25/2024	ND	Low		ND	Low
C214-Drinking water. Right	19220800-178DW	4/25/2024	ND	Low		ND	Low
C213-Classroom faucet. Left	19220800-179CF	4/25/2024	ND	Low		ND	Low
C213-Drinking water. Right	19220800-180DW	4/25/2024	ND	Low		ND	Low
C212-Classroom faucet. Left	19220800-181CF	4/25/2024	ND	Low		ND	Low
C212-Drinking water. Right	19220800-182DW	4/25/2024	ND	Low		ND	Low
C209-Drinking water. North facing. Right	19220800-183DW	4/25/2024	ND	Low		ND	Low
C209-Classroom faucet. North facing. Center	19220800-184CF	4/25/2024	ND	Low		ND	Low
C209-Classroom faucet. North facing. Left	19220800-185CF	4/25/2024	ND	Low		ND	Low
C209-Classroom faucet. West facing. Center	19220800-187CF	4/25/2024	ND	Low		ND	Low
C209-Classroom faucet. West facing. Left	19220800-188CF	4/25/2024	ND	Low		ND	Low
C209-Classroom faucet. East facing. Right	19220800-189CF	4/25/2024	ND	Low		ND	Low
C209-Classroom faucet. East facing. Left	19220800-190CF	4/25/2024	ND	Low		ND	Low
C209-Classroom faucet. Located in the island at the front of class	19220800-191CF	4/25/2024	ND	Low		ND	Low
C210- Classroom faucet. Science room prep	19220800-192CF	4/25/2024	ND	Low		ND	Low
C208-Staff faucet. Lactation room	19220800-193SF	4/25/2024	1	Low		1	Low
C200-Water chiller. Left. Upper commons	19220800-194WC	4/25/2024	ND	Low		ND	Low
C200-Water bottle filler. Center. Upper commons	19220800-195WB	4/25/2024	ND	Low		ND	Low
C200- Water chiller. Right. Located in the same fixture as 19220800-195WB	19220800-240WC	4/25/2024	ND	Low		ND	Low
B203-Staff faucet. Left. Staff room	19220800-196SF	4/25/2024	ND	Low		ND	Low
B203-Staff faucet. Right. Staff room. Instant hot water	19220800-197SF	4/25/2024	ND	Low		ND	Low

B211-Bathroom faucet. Single user restroom. Located upstairs next to the girls restroom B210, off hallway B213	19220800-198BF	4/26/2024	ND	Low		ND	Low
B210-Bathroom faucet. Right. Girl's restroom, upstairs in hallway B213 to Aux gym	19220800-199BF	4/25/2024	ND	Low		ND	Low
B210-Bathroom faucet. Center. Girl's restroom, upstairs in hallway B213 to Aux gym	19220800-200BF	4/25/2024	ND	Low		ND	Low
B210-Bathroom faucet. Left. Girl's restroom, upstairs in hallway B213 to Aux gym	19220800-201BF	4/26/2024	ND	Low		ND	Low
B209-Bathroom faucet. Right. Boy's restroom, upstairs in hallway B213 to Aux gym	19220800-203BF	4/25/2024	ND	Low		ND	Low
B209-Bathroom faucet. Center. Boy's restroom, upstairs in hallway B213 to Aux gym	19220800-204BF	4/25/2024	ND	Low		ND	Low
B209-Bathroom faucet. Left. Boy's restroom, upstairs in hallway B213 to Aux gym	19220800-205BF	4/25/2024	ND	Low		ND	Low
Z101- Concession stand. Kitchen faucet	19220801-229KF	4/25/2024	ND	Low		ND	Low
Z103- Bathroom faucet. Single user restroom	19220801-230BF	4/25/2024	1.1	Low		1.1	Low
Z104- Bathroom faucet. Single user restroom	19220801-231BF	4/25/2024	1.1	Low		1.1	Low