

Water Testing Results - Boeckman Creek primary

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
A150 Health room faucet	19220600-001NS	5/10/2023	ND
A150 Health room drinking water	19220600-086DW	5/10/2023	ND
A154 Staff room faucet	19220600-002SF	5/10/2023	ND
A152 Staff Bathroom	19220600-003BF	5/10/2023	ND
A151 Staff Bathroom	19220600-004BF	5/10/2023	ND
A158 Bathroom faucet "Mens restroom"	19220600-005BF	5/10/2023	ND
A159 Classroom faucet	19220600-006CF	5/10/2023	ND
A159 Classroom Drinking water	19220600-007DW	5/10/2023	ND
A160 Classroom faucet	19220600-008CF	5/10/2023	ND
A160 Classroom Drinking water	19220600-009DW	5/10/2023	1.6
A161 Classroom faucet	19220600-010CF	5/10/2023	ND
A161 Classroom Drinking water	19220600-011DW	5/10/2023	ND
A162 Classroom faucet	19220600-012CF	5/10/2023	ND
A162 Classroom Drinking water	19220600-013DW	5/10/2023	ND
A166 Bathroom faucet "Womens restroom"	19220600-014BF	5/10/2023	4.2
Hall 179 Water Chiller "Located Outside Womens restroom A166"	19220600-015WC	5/10/2023	ND
A172 Classroom faucet	19220600-016CF	5/10/2023	ND
A172 Classroom Drinking water	19220600-017DW	5/10/2023	ND
A173 Classroom faucet	19220600-018CF	5/10/2023	ND
A173 Classroom drinking water	19921700-019DW	5/10/2023	ND
A174 Classroom faucet	19220600-020CF	5/10/2023	ND
A174 Classroom drinking water	19220600-021DW	5/10/2023	ND
A175 Classroom faucet	19220600-022CF	5/10/2023	ND
A175 Classroom drinking water	19220600-023DW	5/10/2023	ND
A183 Bathroom faucet "Mens Restroom"	19220600-024BF	5/10/2023	ND
A184 Bathroom faucet "Unisex , single restroom"	19220600-025BF	5/10/2023	ND
A185 Bathroom faucet "Unisex, single restroom"	19220600-026BF	5/10/2023	ND
A100 Classroom faucet	19220600-027CF	5/10/2023	ND
A100 Classroom drinking water	19220600-028DW	5/10/2023	ND
A101 Classroom faucet	19220600-029CF	5/10/2023	ND
A101 Classroom drinking water	19220600-030DW	5/10/2023	ND
A102 Classroom faucet	19220600-031CF	5/10/2023	ND
A102 Classroom drinking water	19220600-032DW	5/10/2023	1.3
A103 Classroom faucet	19220600-033CF	5/10/2023	ND
A103 Classroom drinking water	19220600-034DW	5/10/2023	ND
A181 Staff faucet "Library workroom/office"	19220600-035SF	5/10/2023	ND
Hall A107 Drinking fountain "Located across from Courtyard A182, Left fixture"	19220600-036DW	5/10/2023	ND
Hall A107 Drinking fountain "Located across from the Courtyard A182, Right fixture"	19220600-037DW	5/10/2023	ND
A108 Bathroom faucet "Womens restroom"	19220600-038BF	5/10/2023	ND
A110 Classroom faucet	19220600-039CF	5/10/2023	ND
A110 Classroom drinking water	19220600-040DW	5/10/2023	ND
A111 Classroom faucet	19220600-041CF	5/10/2023	ND
A111 Classroom drinking water	19220600-042DW	5/10/2023	ND
A112 Classroom faucet	19220600-043CF	5/10/2023	ND
A112 Classroom drinking water	19220600-044DW	5/10/2023	1.7
A113 Classroom faucet	19220600-045CF	5/10/2023	ND
A113 Classroom drinking water	19220600-046DW	5/10/2023	ND
A114 Classroom faucet	19220600-047CF	5/10/2023	ND
A114 Classroom faucet	19220600-048DW	5/10/2023	ND
A115 Classroom faucet	19220600-049CF	5/10/2023	ND
A115 Classroom drinking water	19220600-050DW	5/10/2023	ND
Hall A134 Water chiller "Located outside Mens restroom A130"	19220600-051WC	5/10/2023	ND
A130 Bathroom faucet "Mens restroom"	19220600-052BF	5/10/2023	ND
A122 Classroom faucet	19220600-053CF	5/10/2023	ND
A122 Classroom drinking water	19220600-054DW	5/10/2023	ND
A123 Classroom faucet	19220600-055CF	5/10/2023	ND
A123 Classroom drinking water	19220600-056DW	5/10/2023	ND
A124 Classroom faucet	19220600-057CF	5/10/2023	ND
A124 Classroom drinking water	19220600-058DW	5/10/2023	ND
A125 Classroom faucet	19220600-059CF	5/10/2023	ND
A125 Classroom drinking water	19220600-060DW	5/10/2023	ND
A126 Classroom faucet	19220600-061CF	5/10/2023	ND
A126 Classroom drinking water	19220600-062DW	5/10/2023	ND
A127 Classroom faucet	19220600-063CF	5/10/2023	ND

A127 Classroom drinking water	19220600-064DW	5/10/2023	ND
A128 Classroom faucet	19220600-065CF	5/10/2023	ND
A128 Classroom drinking water	19220600-066DW	5/10/2023	ND
A136 Bathroom faucet "Womens Restroom"	19220600-067BF	5/10/2023	1
A138 Classroom faucet "Right fixture"	19220600-068CF	5/10/2023	1.1
A138 Classroom faucet "Left fixture"	19220600-069CF	5/10/2023	ND
Hall A143 Water bottle filler "Located in hallway off the Gym B101"	19220600-070WB	5/11/2023	ND
Hall A143 Water chiller "Located in hallway off the Gym B101"	19220600-079WC	5/10/2023	ND
A141 Bathroom faucet "Womens restrooms, located near the Gym"	19220600-071BF	5/10/2023	1
A142 Bathroom faucet "Mens restrooms, located near the Gym "	19220600-072BF	5/10/2023	3.5
B102 Water Chiller " Located in the Multi purpose room B102, Cafeteria"	19220600-073WC	5/10/2023	ND
B114 Kitchen faucet "SW hand washing sink"	19220600-074KF	5/10/2023	1.6
B114 Kitchen faucet "South facing sink, right"	19220600-075KF	5/10/2023	ND
B114 Kitchen faucet "South facing sink, left"	19220600-076KF	5/10/2023	1.6
B114 Kitchen faucet "South facing pot washing sink"	19220600-077KF	5/10/2023	ND
B112 Staff Bathroom "Kitchen staff restroom"	19220600-083BF	5/10/2023	ND
B117 Bathroom faucet "Located off the PE office, single staff restroom"	19220600-078BF	5/10/2023	ND
A168 Courtyard outside spigot	19220600-080OS	5/10/2023	ND
Outside rm. B108 outside spigot- "Keyed"	19220600-081OS	Exempt	
Outside rm. A142 outside spigot- "Keyed"	19220600-082OS	Exempt	
Outside rm A114 outside spigot- "Keyed"	19220600-084OS	Exempt	
Outside rm A103 outside spigot- "Keyed"	19220600-085OS	Exempt	
Outside rm A100 outside spigot- "Keyed"	19220600-087OS	Exempt	
Outside rm A157 outside spigot- "Keyed"	19220600-088OS	Exempt	
M1 Classroom Faucet	19220602-001CF	5/10/2023	ND
M1 Classroom Drinking water	19220602-002DW	5/10/2023	ND
M4 Classroom Faucet	19220602-003CF	5/10/2023	1.5
M4 Classroom Drinking water	19220602-004DW	5/10/2023	ND
M2 Classroom Faucet	19220602-005CF	5/10/2023	ND
M2 Classroom Drinking water	19220602-006DW	5/10/2023	1.7
M3 Classroom Faucet	19220602-007CF	5/10/2023	3.5
M3 Classroom Drinking water	19220602-008DW	5/10/2023	2.8
M6 Bathroom Faucet "Unisex single restroom"	19220602-009BF	5/10/2023	ND
M7 Bathroom Faucet "Unisex single restroom"	19220602-010BF	5/10/2023	ND
M8 Bathroom Faucet "Unisex teacher restroom"	19220602-011BF	5/10/2023	ND
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing			
ND = Non Detect - Lead level is below the set detection limits of 1 ppb			