

Water Testing Results - Bolton Primary School

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Room A111A Nurses Station Bathroom Faucet	19221100-001BF	5/3/2023	ND
Room A111 Nurses Station Faucet	19221100-002NS	5/3/2023	ND
Room 110 Classroom Faucet "SE facing far right"	19221100-003CF	5/3/2023	ND
Room 110 Classroom Drinking Fountain "SE facing center fixture"	19221100-004DW	5/3/2023	ND
Room 110 Classroom Faucet "SE facing far left"	19221100-005CF	5/3/2023	ND
Room 113 Classroom Drinking Fountain	19221100-006DW	5/3/2023	2.3
Room 113 Classroom Faucet	19221100-007CF	5/3/2023	ND
Room 114 Classroom Drinking Fountain	19221100-008DW	5/3/2023	ND
Room 114 Classroom Faucet	19221100-009CF	5/3/2023	ND
Room 115 Classroom Drinking Fountain	19221100-010DW	5/3/2023	ND
Room 115 Classroom Faucet	19221100-011CF	5/3/2023	ND
Room 116 Classroom Drinking Fountain	19221100-012DW	5/3/2023	ND
Room 116 Classroom Faucet	19221100-013CF	5/3/2023	ND
Room 119 Classroom Faucet	19221100-014CF	5/3/2023	ND
Room 119 Classroom Drinking Fountain	19221100-015DW	5/3/2023	ND
Room 120 Classroom Faucet	19221100-016CF	5/3/2023	ND
Room 120 Classroom Drinking Fountain	19221100-017DW	5/3/2023	ND
Room 122 Classroom Faucet	19221100-018CF	5/3/2023	ND
Room 122 Classroom Drinking Fountain	19221100-019DW	5/3/2023	ND
Room A106 Classroom Faucet	19221100-020CF	5/3/2023	ND
Room A106 Classroom Drinking Fountain	19221100-021DW	5/3/2023	ND
Room 124 Bathroom faucet "Girls bathroom, left faucet"	19221100-022BF	5/3/2023	ND
Room 124 Bathroom faucet "Girls bathroom, right faucet"	19221100-023BF	5/3/2023	ND
Hall Outside Room 124 Drinking Fountain "Across from room 110, right"	19221100-024DW	5/3/2023	ND
Hall Outside Room 124 Drinking Fountain "Across from room 110, left"	19221100-025DW	5/3/2023	ND
Hall "Outside boys bathroom 127" Water Bottle Filling Station	19221100-026WB	5/3/2023	ND
Room 127 Bathroom faucet "Boys bathroom, right faucet"	19221100-027BF	5/3/2023	ND
Room 127 Bathroom faucet "Boys bathroom, left faucet"	19221100-028BF	5/3/2023	ND
Room A104 Single Bathroom faucet	19221100-029BF	5/3/2023	ND
Room A103 Single Bathroom faucet	19221100-030BF	5/3/2023	ND
Room A114 Staff faucet "Staff room, left faucet"	19221100-031SF	5/3/2023	ND
Room A114 Staff faucet "Staff room, right faucet"	19221100-032SF	5/3/2023	1.9
Room A115 Drinking Fountain	19221100-033DW	5/3/2023	1.5

Room A115 Classroom Faucet	19221100-034CF	5/3/2023	1.5
Room A116 Classroom Faucet	19221100-035CF	5/3/2023	ND
Room A116 Classroom Drinking Fountain	19221100-036DW	5/3/2023	1.7
Room 135 "Gym" Drinking Fountain	19221100-037DW	5/3/2023	ND
Room 160 Classroom Faucet	19221100-038CF	5/3/2023	ND
Room 160 Classroom Drinking Fountain	19221100-039DW	5/3/2023	ND
Room 159 Classroom Faucet	19221100-040CF	5/3/2023	ND
Room 159 Classroom Drinking Fountain	19221100-041DW	5/3/2023	1.2
Room A101 Classroom Faucet	19221100-042CF	5/3/2023	ND
Room A101 Classroom Drinking Fountain	19221100-043DW	5/3/2023	ND
Room A100 Classroom Faucet	19221100-044CF	5/3/2023	ND
Room A100 Classroom Drinking Fountain	19221100-045DW	5/3/2023	ND
Room A156 Classroom Faucet	19221100-046CF	5/3/2023	ND
Room A156 Classroom Drinking Fountain	19221100-047DW	5/3/2023	ND
Room 155 Classroom Faucet	19221100-048CF	5/3/2023	2.9
Room 155 Classroom Drinking Fountain	19221100-049DW	5/3/2023	ND
Room 154 Classroom Faucet	19221100-050CF	5/3/2023	12.7
Room 154 Classroom Drinking Fountain	19221100-051DW	5/3/2023	7.2
Room 153 Classroom Faucet	19221100-052CF	5/3/2023	ND
Room 153 Classroom Drinking Fountain	19221100-053DW	5/3/2023	ND
Room 150 Single Bathroom faucet	19221100-054BF	5/3/2023	ND
Room 148 Bathroom faucet "Girls restroom right fixture"	19221100-055BF	5/3/2023	ND
Room 148 Bathroom faucet "Girls restroom left fixture"	19221100-056BF	5/3/2023	ND
Room 147 Bathroom faucet "Boys restroom left fixture"	19221100-057BF	5/3/2023	ND
Room 147 Bathroom faucet "Boys restroom right fixture"	19221100-058BF	5/3/2023	ND
Hall " Between girls bathroom and boys bathrooms. Right fountain"	19221100-059DW	5/3/2023	ND
Hall "Between girls bathroom and boys bathrooms. Left fountain"	19221100-060DW	5/3/2023	ND
Room 004 Classroom Faucet "right"	19221100-061CF	5/3/2023	ND
Room 004 Classroom Faucet "left"	19221100-062CF	5/3/2023	ND
Room A014 Classroom Faucet "sink faucet"	19221100-063CF	5/3/2023	ND
Room A014 Classroom Faucet "sprayer"	19221100-071CF	5/3/2023	ND
Room A015 Staff faucet "left faucet"	19221100-072SF	5/3/2023	ND
Room A015 Staff faucet "right faucet"	19221100-073SF	5/3/2023	ND
Single Bathroom faucet Outside A006	19221100-064BF	5/3/2023	ND
Room A006 Kitchen faucet "SE wall, hand washing sink	19221100-065KF	5/3/2023	3.5
Room A006 Kitchen faucet "NE wall,potawashing sink"	19221100-066KF	5/3/2023	18.1
Room A006 Kitchen faucet "SE facing sink"	19221100-067KF	5/3/2023	2.0
Room A006 Kitchen faucet "SE facing , hand washing sink"	19221100-068KF	5/3/2023	4.0
Room 005 Bathroom faucet "Downstairs boys restroom"	19221100-069BF	5/3/2023	ND

Room 004 Bathroom faucet "Downstairs girls restroom"	19221100-070BF	5/3/2023	ND
Outside Rm. A014 outside spigot "keyed"	19221100-074OS	Exempt	Exempt
Outside Rm. A156 outside spigot "keyed"	19221100-075OS	Exempt	Exempt
Outside Rm.135 outside spigot "keyed"	19221100-076OS	Exempt	Exempt
Outside Rm.110 outside spigot "keyed"	19221100-077OS	Exempt	Exempt
Outside Rm. 115 outside spigot "keyed"	19221100-078OS	Exempt	Exempt
Outside Rm. 116 outside spigot "keyed"	19221100-079OS	Exempt	Exempt
Outside Rm. 120 outside spigot "keyed"	19221100-080OS	Exempt	Exempt
Outside Rm. A106 outside spigot "keyed"	19221100-081OS	Exempt	Exempt

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing

RETESTS			
Room A006 Kitchen faucet "NE wall,potawashing sink"	19221100-066KF	5/12/2023	1.3

ND = Non Detect - Lead level is below the set detection limits			of 1 ppb
--	--	--	----------