

Lead in Water Test Results Summary: Sunset Primary School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[1] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
A155- Nurses Station faucet	19220400-001NS	3/21/2025	ND	Non-Detect			ND
A157- Bathroom faucet. Nurses station bathroom	19220400-002BF	3/21/2025	ND	Non-Detect			ND
A159- Bathroom faucet. Single user staff bathroom	19220400-004BF	3/21/2025	ND	Non-Detect			ND
A164- Staff faucet. Staff break room	19220400-005SF	3/21/2025	ND	Non-Detect			ND
A181-Kitchette off gym. Staff faucet.	19220400-006SF	3/21/2025	ND	Non-Detect			ND
A180- Water Bottle filler. Wellness/Commons water bottle filler. Left	19220400-007WB	3/21/2025	ND	Non-Detect			ND
A180- Water Chiller. Wellness/Commons water chiller. Center	19220400-008WC	3/21/2025	ND	Non-Detect			ND
A180- Water Chiller. Wellness/Commons water chiller. Right	19220400-009WC	3/21/2025	ND	Non-Detect			ND
A191- Bathroom Faucet. Single user. Family Toilet	19220400-010BF	3/21/2025	ND	Non-Detect			ND
A192- Bathroom Faucet. Girls restroom. Right	19220400-011BF	3/21/2025	ND	Non-Detect			ND
A192- Bathroom Faucet. Girls restroom. Center right	19220400-012BF	3/21/2025	ND	Non-Detect			ND
A192- Bathroom Faucet. Girls restroom. Center left	19220400-013BF	3/21/2025	ND	Non-Detect			ND
A192- Bathroom Faucet. Girls restroom. Left	19220400-014BF	3/21/2025	12.9	High			12.9
A193- Bathroom Faucet. Boys restroom. Left	19220400-015BF	3/21/2025	ND	Non-Detect			ND
A193- Bathroom Faucet. Boys restroom. Center left	19220400-016BF	3/21/2025	ND	Non-Detect			ND
A193- Bathroom Faucet. Boys restroom. Right center	19220400-017BF	3/21/2025	ND	Non-Detect			ND
A193- Bathroom Faucet. Boys restroom. Right	19220400-018BF	3/21/2025	ND	Non-Detect			ND
A197- Bathroom Faucet. Single user staff restroom	19220400-019BF	3/21/2025	ND	Non-Detect			ND
B142- Staff faucet. Library workroom	19220400-021SF	3/21/2025	2.4	Low			2.4
Bathroom Faucet. Located between B145 Boys restroom and B146 Girls restroom	19220400-022BF	3/21/2025	ND	Non-Detect			ND
B147- Bathroom faucet. Staff restroom	19220400-023BF	3/21/2025	ND	Non-Detect			ND
B110- Classroom faucet. Right	19220400-024CF	3/21/2025	ND	Non-Detect			ND
B110- Drinking water. Left	19220400-025DW	3/21/2025	ND	Non-Detect			ND
B111- Classroom faucet. Left	19220400-026CF	3/21/2025	ND	Non-Detect			ND
B111- Drinking water. Right	19220400-027DW	3/21/2025	ND	Non-Detect			ND
B112- Drinking water. Left	19220400-028DW	3/21/2025	ND	Non-Detect			ND
B112- Classroom faucet. Right	19220400-029CF	3/21/2025	ND	Non-Detect			ND
B113- Classroom faucet. Left	19220400-030CF	3/21/2025	ND	Non-Detect			ND
B113- Drinking water. Right	19220400-031DW	3/21/2025	ND	Non-Detect			ND
B114- Drinking water. Left	19220400-032DW	3/21/2025	3.4	Low			3.4
B114- Classroom faucet. Right	19220400-033CF	3/21/2025	ND	Non-Detect			ND
Porch B116- Classroom faucet	19220400-034CF	3/21/2025	ND	Non-Detect			ND
B120- Water Chiller. Right	19220400-035WC	3/21/2025	ND	Non-Detect			ND
B120- Water bottle filler. Center	19220400-036WB	3/21/2025	ND	Non-Detect			ND
B120- Water Chiller. Left	19220400-037WC	3/21/2025	ND	Non-Detect			ND
C134- Kitchen faucet. Hand washing sink	19220400-038KF	3/21/2025	ND	Non-Detect			ND
C134- Kitchen faucet. Food prep sink. Sprayer	19220400-039KF	3/21/2025	ND	Non-Detect			ND

C134- Kitchen faucet. Food prep sink. Located below fixture# 19220400-039KF	19220400-095KF	3/21/2025	ND	Non-Detect			ND
C134-Kitchen faucet. Hand washing sink	19220400-041KF	3/21/2025	1	Low			1
Bathroom faucet. Located between Girls bathroom C133 and Boys bathroom C132	19220400-042BF	3/21/2025	ND	Non-Detect			ND
C131- Bathroom faucet. Single user	19220400-043BF	3/21/2025	ND	Non-Detect			ND
C101- Classroom faucet. Left	19220400-044CF	3/21/2025	1	Low			1
C101- Drinking water. Right	19220400-045DW	3/21/2025	1.3	Low			1.3
C102- Drinking water. Left	19220400-046DW	3/21/2025	ND	Non-Detect			ND
C102- Classroom faucet. Right	19220400-047CF	3/21/2025	1.4	Low			1.4
C103- Drinking water. Right	19220400-048DW	3/21/2025	ND	Non-Detect			ND
C103- Classroom faucet. Left	19220400-049CF	3/21/2025	ND	Non-Detect			ND
C104- Drinking water. Left	19220400-050DW	3/21/2025	ND	Non-Detect			ND
C104- Classroom faucet. Right	19220400-051CF	3/21/2025	ND	Non-Detect			ND
C105- Classroom faucet. Right	19220400-052CF	3/21/2025	ND	Non-Detect			ND
C105- Classroom faucet. Left	19220400-053DW	3/21/2025	3.1	Low			3.1
Porch C107- Classroom faucet	19220400-054CF	3/21/2025	ND	Non-Detect			ND
Bathroom faucet located between Girls bathroom B245 and boys bathroom B246	19220400-055BF	3/21/2025	ND	Non-Detect			ND
B247- Bathroom faucet. Single user restroom	19220400-056BF	3/21/2025	ND	Non-Detect			ND
B210- Drinking water. Left	19220400-057DW	3/21/2025	ND	Non-Detect			ND
B210- Staff Faucet. Right	19220400-058SF	3/21/2025	ND	Non-Detect			ND
B211- Classroom faucet. Left	19220400-059CF	3/21/2025	ND	Non-Detect			ND
B211- Drinking water. Right	19220400-060DW	3/21/2025	ND	Non-Detect			ND
B212- Drinking water. Left	19220400-061DW	3/21/2025	ND	Non-Detect			ND
B212- Classroom faucet. Right	19220400-062CF	3/21/2025	ND	Non-Detect			ND
B213- Drinking water. Left	19220400-063DW	3/21/2025	ND	Non-Detect			ND
B213- Classroom faucet. Right	19220400-064CF	3/21/2025	ND	Non-Detect			ND
B214- Drinking water. Left	19220400-065DW	3/21/2025	ND	Non-Detect			ND
B214- Classroom faucet. Right	19220400-066CF	3/21/2025	ND	Non-Detect			ND
Porch B216- Classroom faucet	19220400-067CF	3/21/2025	2.5	Low			ND
Hall B240- Water chiller. Right	19220400-068WC	3/21/2025	ND	Non-Detect			ND
Hall B240- Water bottle filler. Center	19220400-069WB	3/21/2025	ND	Non-Detect			ND
Hall B240- Water chiller. Left	19220400-070WC	3/21/2025	ND	Non-Detect			ND
C234- Kitchen/Servery- Kitchen Faucet. Hand washing sink	19220400-071KF	3/21/2025	14.2	High			14.2
C234- Kitchen/Servery- Kitchen Faucet. Food Prep sink	19220400-072KF	3/21/2025	ND	Non-Detect			ND
C234- Kitchen/Servery. Kitchen Faucet. Sprayer	19220400-073KF	3/21/2025	1.8	Low			1.8
Bathroom faucet located between Girls bathroom C233 and boys bathroom C232	19220400-074BF	3/21/2025	ND	Non-Detect			ND
C231- Bathroom faucet. Single user restroom	19220400-075BF	3/21/2025	ND	Non-Detect			ND
C201- Classroom faucet. Left	19220400-076CF	3/21/2025	ND	Non-Detect			ND
C201- Drinking water. Right	19220400-077DW	3/21/2025	ND	Non-Detect			ND
C202- Drinking water. Left	19220400-078DW	3/21/2025	ND	Non-Detect			ND
C202- Classroom faucet. Right	19220400-079CF	3/21/2025	ND	Non-Detect			ND
C203- Drinking water. Left	19220400-080DW	3/21/2025	ND	Non-Detect			ND
C203- Classroom faucet. Right	19220400-081CF	3/21/2025	ND	Non-Detect			ND
C204- Classroom faucet. Left	19220400-082CF	3/21/2025	ND	Non-Detect			ND
C204- Drinking water. Right	19220400-083DW	3/21/2025	ND	Non-Detect			ND
C205- Classroom faucet. Left	19220400-084CF	3/21/2025	ND	Non-Detect			ND
C205- Drinking water. Right	19220400-085DW	3/21/2025	ND	Non-Detect			ND
Porch C207- Classroom faucet	19220400-086CF	3/21/2025	1.4	Low			1.4