



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

LEAD & COPPER RULE REPORT

Client Name: West Linn - Wilsonville School District
2755 SW Borland Rd.
Tualatin, OR 97062

Reference Number: **23-11110**

Project: Trillium Creek Primary

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 4/19/2023
Report Date: 4/28/2023
Approved By: anp
Authorized by:

Thanh B Phan
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
23_22069	4/19/2023	19221500-001SF - A106 Work room Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	72.1	ppb	1300	5	200.8	4072	
23_22070	4/19/2023	19221500-002DW - A106 Work room Drinking fountain	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	32.1	ppb	1300	5	200.8	4072	
23_22071	4/19/2023	19221500-003BF - A110 Staff Bathroom	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	41.2	ppb	1300	5	200.8	4072	
23_22072	4/19/2023	19221500-004BF - A111 Health room Bathroom	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	42.8	ppb	1300	5	200.8	4072	
23_22073	4/19/2023	19221500-005NS - A112 Nurses Station faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	47.6	ppb	1300	5	200.8	4072	
23_22074	4/19/2023	19221500-006SF - A117 Staff room sink "Left faucet"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	43.4	ppb	1300	5	200.8	4072	
23_22075	4/19/2023	19221500-113SF - A117 Staff room sink "Right faucet"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	44.6	ppb	1300	5	200.8	4072	
23_22076	4/19/2023	19221500-007WB - A120A Water bottle filler "Left"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	9.9	ppb	1300	5	200.8	4072	
23_22077	4/19/2023	19221500-008DW - A120A Drinking Fountain "Right"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	10.1	ppb	1300	5	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
23_22078	4/19/2023	19221500-009BF - A120 Bathroom faucet "Far Left #1"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	28.2	ppb	1300	5	200.8	4072	
23_22079	4/19/2023	19221500-010BF - A120 Bathroom faucet "Left center #2"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	26.9	ppb	1300	5	200.8	4072	
23_22080	4/19/2023	19221500-011BF - A120 Bathroom faucet "Right center #3"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	23.2	ppb	1300	5	200.8	4072	
23_22081	4/19/2023	19221500-012BF - A120 Bathroom faucet "Far Right #4"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	19.6	ppb	1300	5	200.8	4072	
23_22082	4/19/2023	19221500-013BF - A121 Bathroom faucet "Far Right #1"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	13.9	ppb	1300	5	200.8	4072	
23_22083	4/19/2023	19221500-014BF - A121 Bathroom faucet "Right center #2"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	13.2	ppb	1300	5	200.8	4072	
23_22084	4/19/2023	19221500-015BF - A121 Bathroom faucet "Left center #3"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	13.2	ppb	1300	5	200.8	4072	
23_22085	4/19/2023	19221500-016BF - A121 Bathroom faucet "Far Left #4"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	10.5	ppb	1300	5	200.8	4072	
23_22086	4/19/2023	19221500-017BF - A122 Staff bathroom faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	14.3	ppb	1300	5	200.8	4072	
23_22087	4/19/2023	19221500-018CF - A119 Gym faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	24.3	ppb	1300	5	200.8	4072	
23_22088	4/19/2023	19221500-019CF - A133 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	25.5	ppb	1300	5	200.8	4072	
23_22089	4/19/2023	19221500-020DW - A133 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	31.0	ppb	1300	5	200.8	4072	
23_22090	4/19/2023	19221500-021CF - B101 Classroom faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	41.9	ppb	1300	5	200.8	4072	
23_22091	4/19/2023	19221500-022DW - B101 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
23_22091	4/19/2023	19221500-022DW - B101 Classroom Drinking water	1022	COPPER	63.2	ppb	1300	5	200.8	4072	
23_22092	4/19/2023	19221500-023CF - B102 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	41.5	ppb	1300	5	200.8	4072	
23_22093	4/19/2023	19221500-024DW - B102 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	46.7	ppb	1300	5	200.8	4072	
23_22094	4/19/2023	19221500-025CF - B103 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	53.3	ppb	1300	5	200.8	4072	
23_22095	4/19/2023	19221500-026DW - B103 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	58.9	ppb	1300	5	200.8	4072	
23_22096	4/19/2023	19221500-027CF - B104 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	41.0	ppb	1300	5	200.8	4072	
23_22097	4/19/2023	19221500-028DW - B104 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	54.5	ppb	1300	5	200.8	4072	
23_22098	4/19/2023	19221500-029CF - B105 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	36.5	ppb	1300	5	200.8	4072	
23_22099	4/19/2023	19221500-030DW - B105 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	50.7	ppb	1300	5	200.8	4072	
23_22100	4/19/2023	19221500-031CF - B111 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	49.1	ppb	1300	5	200.8	4072	
23_22101	4/19/2023	19221500-032BF - B122 Bathroom Faucet "Far Right #1"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	21.4	ppb	1300	5	200.8	4072	
23_22102	4/19/2023	19221500-033BF - B122 Bathroom Faucet "Right center #2"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	13.2	ppb	1300	5	200.8	4072	
23_22103	4/19/2023	19221500-034BF - B122 Bathroom Faucet "Left center #3"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	20.6	ppb	1300	5	200.8	4072	
23_22104	4/19/2023	19221500-035BF - B122 Bathroom Faucet "Far Left #4"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	12.0	ppb	1300	5	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
23_22105	4/19/2023	19221500-036DW - Hall outside B122 Drinking water "Right"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	47.7	ppb	1300	5	200.8	4072	
23_22106	4/19/2023	19221500-037WB - Hall outside B121 Water Bottle filler "Left"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	49.4	ppb	1300	5	200.8	4072	
23_22107	4/19/2023	19221500-038BF - B121 Bathroom Faucet "Far Left #1"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	32.2	ppb	1300	5	200.8	4072	
23_22108	4/19/2023	19221500-039BF - B121 Bathroom Faucet "Left center #2"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	30.7	ppb	1300	5	200.8	4072	
23_22109	4/19/2023	19221500-041BF - B121 Bathroom Faucet "Far Right #4"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	28.7	ppb	1300	5	200.8	4072	
23_22110	4/19/2023	19221500-042BF - B120 Bathroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	12.7	ppb	1300	5	200.8	4072	
23_22111	4/19/2023	19221500-043CF - B106 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	41.8	ppb	1300	5	200.8	4072	
23_22112	4/19/2023	19221500-044DW - B106 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	73.5	ppb	1300	5	200.8	4072	
23_22113	4/19/2023	19221500-045CF - B107 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	35.6	ppb	1300	5	200.8	4072	
23_22114	4/19/2023	19221500-046DW - B107 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	47.8	ppb	1300	5	200.8	4072	
23_22115	4/19/2023	19221500-047CF - B108 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	33.4	ppb	1300	5	200.8	4072	
23_22116	4/19/2023	19221500-048DW - B108 Classroom Drinking water	1030	LEAD	19.0	ppb	15	1	200.8	4072	
			1022	COPPER	944	ppb	1300	5	200.8	4072	
23_22117	4/19/2023	19221500-049CF - B109 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	16.4	ppb	1300	5	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
23_22118	4/19/2023	19221500-050DW - B109 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	44.8	ppb	1300	5	200.8	4072	
23_22119	4/19/2023	19221500-051CF - B110 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	24.2	ppb	1300	5	200.8	4072	
23_22120	4/19/2023	19221500-052DW - B110 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	38.1	ppb	1300	5	200.8	4072	
23_22121	4/19/2023	19221500-053CF - B112 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	40.9	ppb	1300	5	200.8	4072	
23_22122	4/19/2023	19221500-054KF - B127 Kitchen Faucet "South facing, hand washing sink"	1030	LEAD	16.2	ppb	15	1	200.8	4072	
			1022	COPPER	38.0	ppb	1300	5	200.8	4072	
23_22123	4/19/2023	19221500-055KF - B127 Kitchen Faucet "North facing, right, hand washing sink"	1030	LEAD	3.6	ppb	15	1	200.8	4072	
			1022	COPPER	11.0	ppb	1300	5	200.8	4072	
23_22124	4/19/2023	19221500-056KF - B127 Kitchen Faucet "North facing, center, sink"	1030	LEAD	1.1	ppb	15	1	200.8	4072	
			1022	COPPER	21.7	ppb	1300	5	200.8	4072	
23_22125	4/19/2023	19221500-057KF - B127 Kitchen Faucet "North facing, Left, hand washing sink"	1030	LEAD	21.4	ppb	15	1	200.8	4072	
			1022	COPPER	18.3	ppb	1300	5	200.8	4072	
23_22126	4/19/2023	19221500-058KF - B127 Kitchen Faucet "South facing, pot washing sink"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	7.2	ppb	1300	5	200.8	4072	
23_22127	4/19/2023	19221500-112KF - B127 Kitchen Faucet "South facing, located in the serving line"	1030	LEAD	1.5	ppb	15	1	200.8	4072	
			1022	COPPER	51.1	ppb	1300	5	200.8	4072	
23_22128	4/19/2023	19221500-059CF - C101 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	38.8	ppb	1300	5	200.8	4072	
23_22129	4/19/2023	19221500-060DW - C101 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	85.9	ppb	1300	5	200.8	4072	
23_22130	4/19/2023	19221500-061CF - C102 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
23_22130	4/19/2023	19221500-061CF - C102 Classroom Faucet	1022	COPPER	57.3	ppb	1300	5	200.8	4072	
23_22131	4/19/2023	19221500-062DW - C102 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	94.4	ppb	1300	5	200.8	4072	
23_22132	4/19/2023	19221500-063CF - C103 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	51.6	ppb	1300	5	200.8	4072	
23_22133	4/19/2023	19221500-064DW - C103 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	78.1	ppb	1300	5	200.8	4072	
23_22134	4/19/2023	19221500-065CF - C104 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	54.0	ppb	1300	5	200.8	4072	
23_22135	4/19/2023	19221500-066DW - C104 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	72.1	ppb	1300	5	200.8	4072	
23_22136	4/19/2023	19221500-067CF - C105 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	48.9	ppb	1300	5	200.8	4072	
23_22137	4/19/2023	19221500-068DW - C105 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	59.8	ppb	1300	5	200.8	4072	
23_22138	4/19/2023	19221500-069CF - C106 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	68.6	ppb	1300	5	200.8	4072	
23_22139	4/19/2023	19221500-070DW - C106 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	56.0	ppb	1300	5	200.8	4072	
23_22140	4/19/2023	19221500-071WB - C106 Water Bottle Filler	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	60.1	ppb	1300	5	200.8	4072	
23_22141	4/19/2023	19221500-072BF - C106 Bathroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	32.8	ppb	1300	5	200.8	4072	
23_22142	4/19/2023	19221500-073KF - C109 kitchen Faucet	1030	LEAD	6.4	ppb	15	1	200.8	4072	
			1022	COPPER	23.1	ppb	1300	5	200.8	4072	
23_22143	4/19/2023	19221500-074KF - C109 kitchen Faucet	1030	LEAD	25.4	ppb	15	1	200.8	4072	
			1022	COPPER	131	ppb	1300	5	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
23_22144	4/19/2023	19221500-075BF - C111 Staff bathroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	12.4	ppb	1300	5	200.8	4072	
23_22145	4/19/2023	19221500-076CF - B201 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	43.8	ppb	1300	5	200.8	4072	
23_22146	4/19/2023	19221500-077DW - B201 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	59.1	ppb	1300	5	200.8	4072	
23_22147	4/19/2023	19221500-078CF - B202 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	40.8	ppb	1300	5	200.8	4072	
23_22148	4/19/2023	19221500-079DW - B202 Classroom Drinking	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	64.5	ppb	1300	5	200.8	4072	
23_22149	4/19/2023	19221500-080CF - B203 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	40.5	ppb	1300	5	200.8	4072	
23_22150	4/19/2023	19221500-081DW - B203 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	47.7	ppb	1300	5	200.8	4072	
23_22151	4/19/2023	19221500-082CF - B204 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	31.2	ppb	1300	5	200.8	4072	
23_22152	4/19/2023	19221500-083DW - B204 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	68.3	ppb	1300	5	200.8	4072	
23_22153	4/19/2023	19221500-084CF - B205 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	38.0	ppb	1300	5	200.8	4072	
23_22154	4/19/2023	19221500-085DW - B205 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	41.0	ppb	1300	5	200.8	4072	
23_22155	4/19/2023	19221500-086CF - B211 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	47.7	ppb	1300	5	200.8	4072	
23_22156	4/19/2023	19221500-087BF - B222 Bathroom Faucet "Far Left #1"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	27.5	ppb	1300	5	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
23_22157	4/19/2023	19221500-088BF - B222 Bathroom Faucet "Left center #2"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	19.6	ppb	1300	5	200.8	4072	
23_22158	4/19/2023	19221500-089BF - B222 Bathroom Faucet "Right center #3"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	26.5	ppb	1300	5	200.8	4072	
23_22159	4/19/2023	19221500-090BF - B222 Bathroom Faucet "Far Right #4"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	9.9	ppb	1300	5	200.8	4072	
23_22160	4/19/2023	19221500-091BF - B222 Bathroom Faucet "Far Right #1"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	28.5	ppb	1300	5	200.8	4072	
23_22161	4/19/2023	19221500-092BF - B222 Bathroom Faucet "Right center #2 "	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	33.3	ppb	1300	5	200.8	4072	
23_22162	4/19/2023	19221500-093BF - B222 Bathroom Faucet "Left center #3"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	33.2	ppb	1300	5	200.8	4072	
23_22163	4/19/2023	19221500-094BF - B222 Bathroom Faucet "Far left #4"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	27.2	ppb	1300	5	200.8	4072	
23_22164	4/19/2023	19221500-095WB - Outside rm 222 Water bottle filler "Right"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	44.4	ppb	1300	5	200.8	4072	
23_22165	4/19/2023	19221500-096DW - Outside rm. 221 Drinking Fountain "Left"	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	47.1	ppb	1300	5	200.8	4072	
23_22166	4/19/2023	19221500-097BF - B220 Staff bathroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	14.8	ppb	1300	5	200.8	4072	
23_22167	4/19/2023	19221500-098CF - B212 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	41.8	ppb	1300	5	200.8	4072	
23_22168	4/19/2023	19221500-099CF - B206 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	36.5	ppb	1300	5	200.8	4072	
23_22169	4/19/2023	19221500-100DW - B206 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	52.3	ppb	1300	5	200.8	4072	
23_22170	4/19/2023	19221500-101CF - B207 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
23_22170	4/19/2023	19221500-101CF - B207 Classroom Faucet	1022	COPPER	25.5	ppb	1300	5	200.8	4072	
23_22171	4/19/2023	19221500-102DW - B207 Classroom Drinking Water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	33.7	ppb	1300	5	200.8	4072	
23_22172	4/19/2023	19221500-103CF - B208 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	29.5	ppb	1300	5	200.8	4072	
23_22173	4/19/2023	19221500-104DW - B208 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	44.4	ppb	1300	5	200.8	4072	
23_22174	4/19/2023	19221500-105CF - B209 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	28.5	ppb	1300	5	200.8	4072	
23_22175	4/19/2023	19221500-106DW - B209 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	40.2	ppb	1300	5	200.8	4072	
23_22176	4/19/2023	19221500-107SF - B210 Classroom Faucet	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	38.1	ppb	1300	5	200.8	4072	
23_22177	4/19/2023	19221500-108DW - B210 Classroom Drinking water	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	36.3	ppb	1300	5	200.8	4072	
23_22178	4/19/2023	19221500-109KF - B227 Kitchen Faucet "West facing, pot washing sink"	1030	LEAD	3.9	ppb	15	1	200.8	4072	
			1022	COPPER	103	ppb	1300	5	200.8	4072	
23_22179	4/19/2023	19221500-110KF - B227 Kitchen Faucet "North facing, hand washing sink"	1030	LEAD	5.4	ppb	15	1	200.8	4072	
			1022	COPPER	136	ppb	1300	5	200.8	4072	
23_22180	4/19/2023	19221500-111KF - B227 Kitchen Faucet "South facing, located in the serving line"	1030	LEAD	1.4	ppb	15	1	200.8	4072	
			1022	COPPER	72.8	ppb	1300	5	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.



Burlington, WA *Corporate Laboratory (a)*
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA *Microbiology (b)*
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*
9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR *Microbiology/Chemistry (d)*
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR *Microbiology (e)*
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

LEAD & COPPER RULE REPORT

Client Name: West Linn - Wilsonville School District
2755 SW Borland Rd.
Tualatin, OR 97062

Reference Number: **23-11184**

Project: Trillium Creek Primary

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 4/20/2023
Report Date: 4/28/2023
Approved By: anp
Authorized by:

Thanh B Phan
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
23_22277	4/19/2023	19221500-040BF - B121 "Bathroom Faucet Right center #3"	1030	LEAD	3.8	ppb	15	1	200.8	4072	
			1022	COPPER	128	ppb	1300	5	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.



Burlington, WA *Corporate Laboratory (a)*
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA *Microbiology (b)*
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR *Microbiology/Chemistry (d)*
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR *Microbiology (e)*
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

LEAD & COPPER RULE REPORT

Client Name: West Linn - Wilsonville School District
 2755 SW Borland Rd.
 Tualatin, OR 97062

Reference Number: **23-14387**
 Project: Trillium Creek Primary

System Name:
 System ID Number:
 DWP Source Number:
 Multiple Sources:
 Sample Type:
 Sample Purpose: Investigative or Other
 County:

Analyst: bj
 Date Received: 5/18/2023
 Report Date: 5/25/2023
 Approved By: anp
 Authorized by:

Thanh B Phan
 Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
23_29147	5/18/2023	19221500-048DW - B108 Classroom Drinking Water	1030	LEAD	1.3	ppb	15	1	200.8	4072	
			1022	COPPER	42.4	ppb	1300	5	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

LEAD & COPPER RULE REPORT

Client Name: West Linn - Wilsonville School District
2755 SW Borland Rd.
Tualatin, OR 97062

Reference Number: **23-16203**

Project: Trillium Creek Primary

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: tjb
Date Received: 6/6/2023
Report Date: 6/19/2023
Approved By: bj
Authorized by:

Thanh B Phan
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
23_32200	6/6/2023	19221500-054KF - B127 Kitchen Faucet "South facing, handwashing sink"	1030	LEAD	5.9	ppb	15	1	200.8	4072	
			1022	COPPER	88.0	ppb	1300	5	200.8	4072	
23_32201	6/6/2023	19221500-057KF - B127 Kitchen Faucet "North facing, left, hand washing sink"	1030	LEAD	10.1	ppb	15	1	200.8	4072	
			1022	COPPER	326	ppb	1300	5	200.8	4072	
23_32202	6/6/2023	19221500-074KF - C109 "Kitchen, pot washing sink, right side"	1030	LEAD	1.5	ppb	15	1	200.8	4072	
			1022	COPPER	99.2	ppb	1300	5	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.