

Water Testing Results -

Trillium Creek Primary

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
A106 "Staff workroom,sink faucet, left side"	19221500-001SF	4/19/2023	ND
A106 "Staff workroom,instant hot water, right side"	19221500-002DW	4/19/2023	ND
A110 "Staff, unisex bathroom in front office"	19221500-003BF	4/19/2023	ND
A111 "Nurses station, unisex bathroom in Health room"	19221500-004BF	4/19/2023	ND
A112 " Sink in Health room"	19221500-005NS	4/19/2023	ND
A117 "Staff room faucet,left side"	19221500-006SF	4/19/2023	ND
A117 "Staff room instant hot water,right side"	19221500-113SF	4/19/2023	ND
A120A "Outside boys bathroom in Gym, left side"	19221500-007WB	4/19/2023	ND
A120A "Outside girls bathroom in Gym,right side"	19221500-008DW	4/19/2023	ND
A120 "Boys bathroom in Gym.Far Left, # 1"	19221500-009BF	4/19/2023	ND
A120 "Boys bathroom in Gym.Left center, # 2"	19221500-010BF	4/19/2023	ND
A120 "Boys bathroom in Gym. Right center, # 3"	19221500-011BF	4/19/2023	ND
A120 "Boys bathroom in Gym. Far Right, # 4"	19221500-012BF	4/19/2023	ND
A121 " Girls bathroom in Gym. Far Right, # 1"	19221500-013BF	4/19/2023	ND
A121 "Girls bathroom in Gym. Right center, # 2"	19221500-014BF	4/19/2023	ND
A121 "Girls bathroom in Gym.Left center, # 3"	19221500-015BF	4/19/2023	ND
A121 "Girls bathroom in Gym. Far Left, # 4"	19221500-016BF	4/19/2023	ND
A122 "Staff bathroom in Gym."	19221500-017BF	4/19/2023	ND
A119 "Classroom faucet in Gym"	19221500-018CF	4/19/2023	ND
A133 "Music room, off the Gym"	19221500-019CF	4/19/2023	ND
A133 "Music room, off the Gym"	19221500-020DW	4/19/2023	ND
B101 Classroom faucet	19221500-021CF	4/19/2023	ND
B101 Classroom Drinking water	19221500-022DW	4/19/2023	ND
B102 Classroom Faucet	19221500-023CF	4/19/2023	ND
B102 Classroom Drinking water	19221500-024DW	4/19/2023	ND
B103 Classroom Faucet	19221500-025CF	4/19/2023	ND
B103 Classroom Drinking water	19221500-026DW	4/19/2023	ND
B104 Classroom Faucet	19221500-027CF	4/19/2023	ND
B104 Classroom Drinking water	19221500-028DW	4/19/2023	ND
B105 Classroom Faucet	19221500-029CF	4/19/2023	ND
B105 Classroom Drinking water	19221500-030DW	4/19/2023	ND
B111 "Porch, Classroom faucet"	19221500-031CF	4/19/2023	ND
B122 "Girls bathroom down stairs. Far Right # 1"	19221500-032BF	4/19/2023	ND
B122 "Girls bathroom down stairs.Right center # 2"	19221500-033BF	4/19/2023	ND
B122 "Girls bathroom down stairs. Left center # 3"	19221500-034BF	4/19/2023	ND
B122 "Girls bathroom down stairs. Far Left # 4"	19221500-035BF	4/19/2023	ND
Hall B122 "Outside girls bathroom.Right side"	19221500-036DW	4/19/2023	ND
Hall B121 " Outside boys bathroom. Left side"	19221500-037WB	4/19/2023	ND
B121 "Boys bathroom down stairs. Far Left # 1"	19221500-038BF	4/19/2023	ND
B121 " Boys bahtroom down stairs.Left center # 2"	19221500-039BF	4/19/2023	ND
B121 "Boys bathroom down stairs.Right center # 3"	19221500-040BF	4/20/2023	3.8
B121 " Boys bathroom down stairs. Far Right # 4"	19221500-041BF	4/19/2023	ND
B120 "Unisex, Staff bathroom"	19221500-042BF	4/19/2023	ND
B106 Classroom Faucet	19221500-043CF	4/19/2023	ND
B106 Classroom Drinking water	19221500-044DW	4/19/2023	ND
B107 Classroom Faucet	19221500-045CF	4/19/2023	ND
B107 Classroom Drinking water	19221500-046DW	4/19/2023	ND
B108 Classroom Faucet	19221500-047CF	4/19/2023	ND
B108 Classroom Drinking water	19221500-048DW	4/19/2023	19.0
B109 Classroom Faucet	19221500-049CF	4/19/2023	ND
B109 Classroom Drinking water	19221500-050DW	4/19/2023	ND
B110 Classroom Faucet	19221500-051CF	4/19/2023	ND
B110 Classroom Drinking water	19221500-052DW	4/19/2023	ND
B112 "Porch, Classroom faucet"	19221500-053CF	4/19/2023	ND
B127 Kitchen Faucet "South facing, handwashing sink"	19221500-054KF	4/19/2023	16.2
B127 Kitchen Faucet "North facing,right, hand washing sink"	19221500-055KF	4/19/2023	3.6
B127 Kitchen Faucet "North facing , center, sink"	19221500-056KF	4/19/2023	1.1
B127 Kitchen Faucet "North facing, left,hand washing sink"	19221500-057KF	4/19/2023	21.4
B127 Kitchen Faucet "South facing, pot washing sink"	19221500-058KF	4/19/2023	ND
B127 Kitchen Faucet "South facing, located in the serving line	19221500-112KF	4/19/2023	1.5
C101 Classroom Faucet	19221500-059CF	4/19/2023	ND
C101 Classroom Drinking water	19221500-060DW	4/19/2023	ND
C102 Classroom Faucet	19221500-061CF	4/19/2023	ND

C102 Classroom Drinking water	19221500-062DW	4/19/2023	ND
C103 Classroom Faucet	19221500-063CF	4/19/2023	ND
C103 Classroom Drinking water	19221500-064DW	4/19/2023	ND
C104 Classroom Faucet	19221500-065CF	4/19/2023	ND
C104 Classroom Drinking water	19221500-066DW	4/19/2023	ND
C105 Classroom Faucet	19221500-067CF	4/19/2023	ND
C105 Classroom Drinking	19221500-068DW	4/19/2023	ND
C106 "Porch, Classroom faucet"	19221500-069CF	4/19/2023	ND
C106 "Located on porch C106, right of C109 Kitchen. Right side"	19221500-070DW	4/19/2023	ND
C106 "Located on porch C106, right of C109 Kitchen.Left side"	19221500-071WB	4/19/2023	ND
C106 "Located between bathrooms C107 and C108"	19221500-072BF	4/19/2023	ND
C109 "Kitchen , hand washing sink,left side"	19221500-073KF	4/19/2023	6.4
C109 "Kitchen , pot washing sink, right side"	19221500-074KF	4/19/2023	25.4
C111 "Staff, unisex bathroom"	19221500-075BF	4/19/2023	ND
B201 Classroom Faucet	19221500-076CF	4/19/2023	ND
B201 Classroom Drinking water	19221500-077DW	4/19/2023	ND
B202 Classroom Faucet	19221500-078CF	4/19/2023	ND
B202 Classroom Drinking	19221500-079DW	4/19/2023	ND
B203 Classroom Faucet	19221500-080CF	4/19/2023	ND
B203 Classroom Drinking water	19221500-081DW	4/19/2023	ND
B204 Classroom Faucet	19221500-082CF	4/19/2023	ND
B204 Classroom Drinking water	19221500-083DW	4/19/2023	ND
B205 Classroom Faucet	19221500-084CF	4/19/2023	ND
B205 Classroom Drinking water	19221500-085DW	4/19/2023	ND
B211 "Porch, Classroom faucet"	19221500-086CF	4/19/2023	ND
B222 "Girls bathroom upstairs.Far left, # 1"	19221500-087BF	4/19/2023	ND
B222 "Girls bathroom upstairs.Left center # 2"	19221500-088BF	4/19/2023	ND
B222 "Girls bathroom upstairs. Right center # 3"	19221500-089BF	4/19/2023	ND
B222 "Girls bathroom upstairs. Far right, # 4"	19221500-090BF	4/19/2023	ND
B221 "Boys bathroom upstairs. Far right # 1"	19221500-091BF	4/19/2023	ND
B221 "Boys bathroom upstairs. Right center # 2"	19221900-092BF	4/19/2023	ND
B221 "Boys bathroom upstairs. Left center # 3"	19221500-093BF	4/19/2023	ND
B221 "Boys bathroom upstairs. Far left # 4"	19221500-094BF	4/19/2023	ND
Outside B221 boys bathroom upstairs. Far Right"	19221500-095WB	4/19/2023	ND
Outside B222 girls bathroom upstairs. Far Left"	19221500-096DW	4/19/2023	ND
B220 "Unisex, staff bathroom up stairs"	19221500-097BF	4/19/2023	ND
B212 "Porch classroom faucet"	19221500-098CF	4/19/2023	ND
B206 Classroom Faucet	19221500-099CF	4/19/2023	ND
B206 Classroom Drinking water	19221500-100DW	4/19/2023	ND
B207 Classroom Faucet	19221500-101CF	4/19/2023	ND
B207 Classroom Drinking Water	19221500-102DW	4/19/2023	ND
B208 Classroom Faucet	19221500-103CF	4/19/2023	ND
B208 Classroom Drinking water	19221500-104DW	4/19/2023	ND
B209 Classroom Faucet	19221500-105CF	4/19/2023	ND
B209 Classroom Drinking water	19221500-106DW	4/19/2023	ND
B210 Classroom Faucet	19221500-107SF	4/19/2023	ND
B210 Classroom Drinking water	19221500-108DW	4/19/2023	ND
B227 Kitchen sink "West facing , pot washing sink"	19221500-109KF	4/19/2023	3.9
B227 Kitchen sink "North facing , hand washing sink"	19221500-110KF	4/19/2023	5.4
B227 Kitchen sink "South facing, located in serving line"	19221500-111KF	4/19/2023	1.4
Outside room A116 Outside Spigot "Keyed"	19221500-114OS	Exempt	Exempt
Outside room C104 Outside Spigot "keyed"	19221500-115OS	Exempt	Exempt
Outside room B109 Outside Spigot "keyed"	19221500-116OS	Exempt	Exempt
Outside room A132 Outside Spigot "keyed"	19221500-117OS	Exempt	Exempt
Outside room A131 Outside Spigot "signage"	19221500-118OS	Exempt	Exempt
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing			
RETESTS			
B108 Classroom Drinking water	19221500-048DW	5/18/2023	1.3
B127 Kitchen Faucet "South facing, handwashing sink"	19221500-054KF	6/6/2023	5.9
B127 Kitchen Faucet "North facing, left,hand washing sink"	19221500-057KF	6/6/2023	10.1
C109 "Kitchen , pot washing sink, right side"	19221500-074KF	6/6/2023	1.5
ND = Non Detect - Lead level is below the set detection limits			of 1 ppb