

## Lead in Water Test Results Summary: West Linn High School

### Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

*Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.*

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[1] ppb**.

### Legend:

- Test results **equal to or greater than the Action Level** of 15 ppb are **highlighted in red and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **near the Action Level** of 15 ppb (11.99 to 14.99 ppb) are **highlighted in yellow and precede a "Med" (Medium) value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
A107 - "1A" Porch, classroom faucet. Left	19220500-001CF	1/16/2025	ND	Low		ND	Low
A107 - "1A" Porch drinking water. Right	19220500-002DW	1/16/2025	ND	Low		ND	Low
F103 - Library office. Staff faucet	19220500-003SF	1/16/2025	4.8	Low		4.8	Low
B107 - "1B" Porch, classroom faucet. Left	19220500-004CF	1/16/2025	ND	Low		ND	Low
B107 - "1B" Porch drinking water. Right	19220500-005DW	1/16/2025	ND	Low		ND	Low
C113-Right of the boy's restroom. Water chiller. Left	19220500-006WC	1/16/2025	ND	Low		ND	Low
C113-Right of the boy's restroom. Water chiller. Right	19220500-007WC	1/16/2025	ND	Low		ND	Low
C112 - Boy's restroom. Bathroom faucet	19220500-008BF	1/16/2025	1	Low		1	Low
C101 - Classroom faucet. Northeast facing, right	19220500-009CF	1/16/2025	ND	Low		ND	Low
C101 - Classroom faucet. Northeast facing, center	19220500-010CF	1/16/2025	ND	Low		ND	Low
C101 - Classroom faucet. Northeast facing, left	19220500-011CF	1/16/2025	ND	Low		ND	Low
C101 - Classroom faucet. South facing	19220500-012CF	1/16/2025	ND	Low		ND	Low
C101B - Science prep room. Classroom faucet	19220500-013CF	1/16/2025	7.1	Low		7.1	Low
C107C - Snack storage. Staff Faucet	19220500-278SF	1/16/2025	48	High			
C102 - Classroom faucet. South facing, left	19220500-014CF	1/16/2025	1.9	Low		1.9	Low
C102 - Classroom faucet. South facing, Center	19220500-015CF	1/16/2025	ND	Low		ND	Low
C102 - Classroom faucet. South facing, right	19220500-016SF	1/16/2025	ND	Low		ND	Low
C102 - Classroom faucet. Northwest facing, right	19220500-017CF	1/16/2025	1.4	Low		1.4	Low
C102 - Classroom faucet. Northeast facing, left	19220500-018CF	1/16/2025	ND	Low		ND	Low
C102 - Classroom faucet. Northeast facing, center	19220500-019CF	1/16/2025	ND	Low		ND	Low
C102 - Classroom faucet. Northeast facing, right	19220500-020CF	1/16/2025	ND	Low		ND	Low
C102A - Classroom faucet. Science prep room, right	19220500-021CF	1/16/2025	1.2	Low		1.2	Low
C103 - Classroom faucet. West facing, left	19220500-022CF	1/16/2025	ND	Low		ND	Low
C103 - Classroom faucet. West facing, center	19220500-023CF	1/16/2025	ND	Low		ND	Low
C103 - Classroom faucet. West facing, right	19220500-024CF	1/16/2025	ND	Low		ND	Low
C103 - Classroom faucet. Northwest facing, left	19220500-025CF	1/16/2025	3.5	Low		3.5	Low
C103 - Classroom faucet. Northeast facing, left	19220500-026CF	1/16/2025	ND	Low		ND	Low
C103 - Classroom faucet. Northeast facing, center	19220500-027CF	1/16/2025	ND	Low		ND	Low
C103 - Classroom faucet. Northeast facing, right	19220500-028CF	1/16/2025	ND	Low		ND	Low
C104 - Classroom faucet. Southeast facing, left	19220500-029CF	1/16/2025	ND	Low		ND	Low

C104 - Classroom faucet. Southeast facing, center	19220500-030CF	1/16/2025	ND	Low		ND	Low
C104 - Classroom faucet. Southeast facing, right	19220500-031CF	1/16/2025	ND	Low		ND	Low
C104 - Classroom faucet. Northwest facing, left	19220500-032CF	1/16/2025	ND	Low		ND	Low
C104 - Classroom faucet. Northwest facing , center	19220500-033CF	1/16/2025	ND	Low		ND	Low
C104 - Classroom faucet. Northwest facing, right	19220500-034CF	1/16/2025	ND	Low		ND	Low
C104 - Classroom faucet. Right of prep room doors.	19220500-035CF	1/16/2025	59.9	High			
C105 - Science prep room. Classroom faucet.	19220500-036CF	1/16/2025	ND	Low		ND	Low
C106 - Classroom faucet. Southeast facing, left	19220500-037CF	1/16/2025	ND	Low		ND	Low
C106 - Classroom faucet. Southeast facing, center	19220500-038CF	1/16/2025	ND	Low		ND	Low
C106 - Classroom faucet. Southeast facing, right	19220500-039CF	1/16/2025	ND	Low		ND	Low
C106 - Classroom faucet. Northwest facing, left	19220500-040CF	1/16/2025	ND	Low		ND	Low
C106 - Classroom faucet. Northwest facing, center	19220500-041CF	1/16/2025	ND	Low		ND	Low
C106 - Classroom faucet. Northwest facing, right	19220500-042CF	1/16/2025	ND	Low		ND	Low
C106 -Classroom faucet. Southeast facing	19220500-043CF	1/16/2025	1.1	Low		1.1	Low
C110- Water cooler. Left	19220500-044WC	1/16/2025	ND	Low		ND	Low
C110 - Water cooler. Right	19220500-045WC	1/16/2025	ND	Low		ND	Low
C111 - Bathroom faucet. Girl's restroom	19220500-046BF	1/16/2025	1.6	Low		1.6	Low
D101A - Bathroom faucet. Single user restroom	19220500-047BF	1/16/2025	1.3	Low		1.3	Low
D101B - Bathroom faucet. Single user restroom	19220500-048BF	1/16/2025	ND	Low		ND	Low
D101 - Classroom faucet. Left	19220500-049CF	1/16/2025	ND	Low		ND	Low
D101 - Drinking water. Right	19220500-240DW	1/16/2025	ND	Low		ND	Low
D103 - Classroom faucet. Northwest facing. Far right	19220500-050CF	1/16/2025	3.5	Low		3.5	Low
D103- Classroom faucet. center	19220500-051CF	1/16/2025	2.8	Low		2.8	Low
D103 - Classroom faucet. Far left	19220500-052CF	1/16/2025	4.6	Low		4.6	Low
D103B - Classroom faucet. Handwashing sink. East facing	19220500-053CF	1/16/2025	ND	Low		ND	Low
E107 - Classroom faucet. "1E" Porch. Left	19220500-055CF	1/16/2025	ND	Low		ND	Low
E107 - Drinking water. "1E" Porch. Right	19220500-056DW	1/16/2025	ND	Low		ND	Low
A207 - Classroom faucet. "2A" Porch Left	19220500-057CF	1/16/2025	ND	Low		ND	Low
A207 - Drinking water. " 2A" Porch .Right	19220500-058DW	1/16/2025	ND	Low		ND	Low
B207 - Classroom faucet. "2B" Porch. Left	19220500-059CF	1/16/2025	ND	Low		ND	Low
B207 - Drinking water. "2B" Porch. Right	19220500-060DW	1/16/2025	ND	Low		ND	Low
C212- Water cooler to the right of the upstairs boys bathroom. Left	19220500-061WC	1/16/2025	ND	Low		ND	Low
C212-Water Cooler to the right of the upstairs boys restroom. Right	19220500-062WC	1/16/2025	ND	Low		ND	Low
C211- Bathroom faucet. Upstairs Men's restroom	19220500-063BF	1/16/2025	ND	Low		ND	Low
C201 - Classroom faucet. Northeast facing, far right	19220500-064CF	1/16/2025	3.4	Low		3.4	Low
C201 - Classroom faucet. Northeast facing, center right	19220500-065CF	1/16/2025	1.6	Low		1.6	Low
C201 - Classroom faucet. Northeast facing, center left	19220500-066CF	1/16/2025	ND	Low		ND	Low
C201 - Classroom faucet. Northeast facing, far left	19220500-067CF	1/16/2025	ND	Low		ND	Low
C206B - Staff faucet. Storage room	19220500-068SF	1/16/2025	5.8	Low		5.8	Low
C202 - Classroom faucet. Southwest facing, left	19220500-069CF	1/16/2025	ND	Low		ND	Low

C202 - Classroom faucet. Southwest facing, center	19220500-070CF	1/16/2025	ND	Low		ND	Low
C202 - Classroom faucet. Southwest facing, right	19220500-071CF	1/16/2025	ND	Low		ND	Low
C202 - Classroom faucet. Northwest facing, only sink located on exterior wall with windows	19220500-072CF	1/16/2025	1.9	Low		1.9	Low
C202 - Classroom faucet. Northeast facing, left	19220500-073CF	1/16/2025	ND	Low		ND	Low
C202 - Classroom faucet. Northeast facing, center	19220500-074CF	1/16/2025	ND	Low		ND	Low
C202 - Classroom faucet. Northeast facing, right	19220500-075CF	1/16/2025	ND	Low		ND	Low
C202A - Classroom faucet. Science prep room	19220500-076CF	1/16/2025	2.2	Low		2.2	Low
C203 - Classroom faucet. Southwest facing, left	19220500-077CF	1/16/2025	ND	Low		ND	Low
C203 - Classroom faucet. Southwest facing, center	19220500-078CF	1/16/2025	ND	Low		ND	Low
C203 - Classroom faucet. Southwest facing, right	19220500-079CF	1/16/2025	ND	Low		ND	Low
C203 - Classroom faucet. Northwest facing, only sink located on exterior wall with windows	19220500-080CF	1/16/2025	4.8	Low		4.8	Low
C203 - Classroom faucet. Northeast facing, left	19220500-081CF	1/16/2025	ND	Low		ND	Low
C203 - Classroom faucet. Northeast facing, center	19220500-082CF	1/16/2025	ND	Low		ND	Low
C203 - Classroom faucet. Northeast facing, right	19220500-083CF	1/16/2025	ND	Low		ND	Low
C204 - Classroom faucet. East facing, left	19220500-084CF	1/16/2025	ND	Low		ND	Low
C204 - Classroom faucet. East facing, center	19220500-085CF	1/16/2025	ND	Low		ND	Low
C204 - Classroom faucet. East facing, right	19220500-086CF	1/16/2025	ND	Low		ND	Low
C204 - Classroom faucet. Northwest facing, right	19220500-087CF	1/16/2025	ND	Low		ND	Low
C204 - Classroom faucet. Northwest facing, center	19220500-088CF	1/16/2025	ND	Low		ND	Low
C204 - Classroom faucet. Northwest facing, left	19220500-089CF	1/16/2025	ND	Low		ND	Low
C204 - Classroom faucet. Southwest facing	19220500-090CF	1/16/2025	1.8	Low		1.8	Low
C205A - Science prep room. Classroom faucet	19220500-091CF	1/16/2025	1.3	Low		1.3	Low
C205 - Classroom faucet. Southwest facing, left	19220500-092CF	1/16/2025	ND	Low		ND	Low
C205 - Classroom faucet. Southwest facing, center	19220500-093CF	1/16/2025	7.5	Low		7.5	Low
C205 - Classroom faucet. Southwest facing, right	19220500-094CF	1/16/2025	ND	Low		ND	Low
C205 - Classroom faucet. Northeast facing, right	19220500-095CF	1/16/2025	ND	Low		ND	Low
C205 - Classroom faucet. Northeast facing, center	19220500-096CF	1/16/2025	ND	Low		ND	Low
C205 - Classroom faucet. Northeast facing, left	19220500-097CF	1/16/2025	ND	Low		ND	Low
C205 - Classroom faucet. Southwest facing on the exterior wall under the windows.	19220500-098CF	1/16/2025	8.1	Low		8.1	Low
C209 - Water chiller. Outside the women's restroom, left	19220500-099WC	1/16/2025	ND	Low		ND	Low
C209 - Water chiller. Outside the women's restroom, right	19220500-100WC	1/16/2025	ND	Low		ND	Low
C210 - Bathroom faucet. Women's restroom	19220500-101BF	1/16/2025	2.4	Low		2.4	Low
F210 - Classroom faucet	19220500-102CF	1/16/2025	ND	Low		ND	Low
F210A- Bathroom faucet. Single user, right	19220500-103BF	1/17/2025	1.5	Low		1.5	Low
F210B- Bathroom faucet. Single user, left	19220500-104BF	1/16/2025	1	Low		1	Low
D206 - Classroom faucet. "2D" Porch, left	19220500-105CF	1/16/2025	ND	Low		ND	Low

D206 - Classroom faucet. "2D" Porch, right	19220500-106DW	1/16/2025	ND	Low		ND	Low
E207 - Classroom faucet. "2E" Porch, left	19220500-107CF	1/16/2025	ND	Low		ND	Low
E207 - Classroom faucet. "2E" Porch, right	19220500-108DW	1/16/2025	ND	Low		ND	Low
G207 - Staff faucet. Staffroom	19220500-109SF	1/16/2025	ND	Low		ND	Low
G208B- Bathroom faucet. Staff men's restroom	19220500-110BF	1/16/2025	ND	Low		ND	Low
G208A - Bathroom faucet. Staff women's restroom, right	19220500-111BF	1/16/2025	ND	Low		ND	Low
G208A- Bathroom faucet. Women's restroom, left	19220500-112BF	1/16/2025	ND	Low		ND	Low
G210 - Bathroom faucet. Men's restroom	19220500-113BF	1/16/2025	ND	Low		ND	Low
G204- Water chiller, right	19220500-114WC	1/16/2025	ND	Low		ND	Low
G204- Water chiller, left	19220500-115WC	1/16/2025	ND	Low		ND	Low
G211 - Bathroom faucet. Women's restroom	19220500-116BF	1/16/2025	ND	Low		ND	Low
G136 - Water bottle filler, right. Located on student street	19220500-117WB	1/16/2025	ND	Low		ND	Low
G136 - Drinking water, center. Located on student street	19220500-118DW	1/16/2025	ND	Low		ND	Low
G136 - Drinking water, left. Located on student street	19220500-119DW	1/16/2025	ND	Low		ND	Low
G141- Staff faucet. Custodial Office	19220500-120SF	1/16/2025	1.8	Low		1.8	Low
G141C - Bathroom faucet. Custodial bathroom	19220500-121BF	1/16/2025	ND	Low		ND	Low
G142B - Bathroom faucet. Single user restroom, right	19220500-122BF	1/16/2025	ND	Low		ND	Low
G142C - Bathroom faucet. Single user restroom, left	19220500-123BF	1/16/2025	ND	Low		ND	Low
G143 - Classroom faucet. ASB Office	19220500-124CF	1/16/2025	1.3	Low		1.3	Low
G144 - Bathroom faucet. Women's restroom	19220500-125BF	1/16/2025	ND	Low		ND	Low
G145 - Bathroom faucet. Men's restroom	19220500-126BF	1/16/2025	ND	Low		ND	Low
G146A - Classroom faucet. Student Store	19220500-127CF	1/16/2025	ND	Low		ND	Low
G129 - Nurse's office sink	19220500-128NS	1/16/2025	ND	Low		ND	Low
G129A - Bathroom faucet. Single user restroom. Located off the Nurse's Station	19220500-129BF	1/16/2025	ND	Low		ND	Low
G122 - Bathroom faucet. Single user located in the main office	19220500-130BF	1/16/2025	ND	Low		ND	Low
G123- Bathroom faucet. Single user located in the main office	19220500-131BF	1/16/2025	ND	Low		ND	Low
G127- Staff faucet. Located in the staff room	19220500-132SF	1/16/2025	ND	Low		ND	Low
H132 - Water bottle filler. Left	19220500-133WB	1/16/2025	ND	Low		ND	Low
H132 - Drinking water. Right	19220500-134DW	1/16/2025	ND	Low		ND	Low
H118 - Bathroom faucet. Girl's restroom. Farthest right	19220500-135BF	1/16/2025	ND	Low		ND	Low
H118 - Bathroom faucet. Girl's restroom. Right center	19220500-136BF	1/16/2025	ND	Low		ND	Low
H118 - Bathroom faucet. Girl's restroom. Left center	19220500-137BF	1/16/2025	ND	Low		ND	Low
H118 - Bathroom faucet. Girl's restroom. Farthest left	19220500-138BF	1/16/2025	ND	Low		ND	Low
H117 - Bathroom faucet. Boy's restroom. Left	19220500-139BF	1/16/2025	ND	Low		ND	Low
H117 - Bathroom faucet. Boy's restroom. Left center	19220500-140BF	1/16/2025	ND	Low		ND	Low
H117 - Bathroom faucet. Boy's restroom. Right center	19220500-141BF	1/16/2025	ND	Low		ND	Low
H117 - Bathroom faucet. Boy's restroom. Right	19220500-142BF	1/16/2025	ND	Low		ND	Low
H116 - Bathroom faucet. Single user restroom located in the kitchen	19220500-143BF	1/16/2025	ND	Low		ND	Low
H120 - Ice Machine. Kitchen	19220500-235IM	1/16/2025	ND	Low		ND	Low
H120 - Kitchen faucet. Handwashing sink. Northeast facing	19220500-144KF	1/16/2025	ND	Low		ND	Low
H120 - Kitchen faucet. Dishwashing sink, Southwest facing, right	19220500-145KF	1/16/2025	ND	Low		ND	Low

H120 - Kitchen faucet. Dishwashing sink, Southwest facing, center	19220500-146KF	1/16/2025	ND	Low		ND	Low
H120 - Kitchen faucet. Dishwashing sink. Northeast facing	19220500-147KF	1/16/2025	ND	Low		ND	Low
H121 - Kitchen faucet. Handwashing sink. Northeast facing	19220500-148KF	1/16/2025	ND	Low		ND	Low
H121 - Kitchen faucet. Kitchen prep sink located in first island. Northeast facing	19220500-149KF	1/16/2025	ND	Low		ND	Low
H121 - Kitchen faucet. Kitchen prep sink located in center island	19220500-150KF	1/16/2025	ND	Low		ND	Low
H121 - Kitchen faucet. Handwashing sink. Southeast facing, right of stoves	19220500-151KF	1/16/2025	ND	Low		ND	Low
H121 - Kitchen faucet. Southwest facing pot filler, left of the stoves	19220500-153KF	1/16/2025	48.6	High			
H108 - Water bottle filler. Left of Kitchen entrance	19220500-154WB	1/16/2025	ND	Low		ND	Low
H108 - Drinking water. Left. Left of the Aux gym doors	19220500-155DW	1/16/2025	ND	Low		ND	Low
H108 - Drinking water. Right. Left of the Aux gym doors	19220500-156DW	1/16/2025	ND	Low		ND	Low
H110 - Kitchen faucet. Serving handwashing sink	19220500-157KF	1/16/2025	8.8	Low		8.8	Low
H111 - Kitchen faucet. Food Service kitchen. Hand washing sink, left	19220500-158KF	1/16/2025	3.4	Low		3.4	Low
H111 - Kitchen faucet. Food Service kitchen. Hand washing sink, right.	19220500-159KF	1/16/2025	2.1	Low		2.1	Low
H021 - Drinking fountain. Left	19220500-160DW	1/17/2025	ND	Low		ND	Low
H021 - Drinking fountain. Center	19220500-161DW	1/17/2025	ND	Low		ND	Low
H021 - Water bottle filler. Right	19220500-162WB	1/17/2025	ND	Low		ND	Low
H022 - Classroom faucet. Athletic Training room	19220500-163CF	1/17/2025	ND	Low		ND	Low
H022 - Ice Machine. Training room, left	19220500-164IM	1/17/2025	ND	Low		ND	Low
H022 - Ice Machine. Training room, right . ***EXEMPT*** This is off	19220500-165IM	1/17/2025	ND	Low		ND	Low
H024- Staff faucet. Laundry room. Right sink	19220500-166SF	1/17/2025	344	High			
H024- Staff faucet. Laundry room. Left sink	19220500-167SF	1/17/2025	ND	Low		ND	Low
H011A - Bathroom faucet. Women's locker room Coaches' Office	19220500-168BF	1/17/2025	ND	Low		ND	Low
H015- Bathroom faucet. Women's locker room, right	19220500-169BF	1/17/2025	ND	Low		ND	Low
H015 - Bathroom faucet. Women's locker room, left	19220500-170BF	1/17/2025	ND	Low		ND	Low
H003C- Bathroom faucet. Northeast facing. Men's bathroom located off the Men's locker room to the right of the main doors.	19220500-171BF	1/17/2025	ND	Low		ND	Low
H007C - Water cooler. Southeast facing. Team "A" toilets	19220500-172WC	1/17/2025	ND	Low		ND	Low
H007C - Bathroom faucet. Team "A" toilets	19220500-173BF	1/17/2025	ND	Low		ND	Low
H006A - Bathroom faucet .Located at Team "B" Toilets	19220500-174BF	1/17/2025	ND	Low		ND	Low
H006A- Water cooler. Located at Team "B" Toilets	19220500-175WC	1/17/2025	ND	Low		ND	Low
H005A- Bathroom faucet. Located at Coaches Toilet	19220500-176BF	1/17/2025	ND	Low		ND	Low
H003 - Water cooler. Located in the Men's locker room	19220500-177WC	1/17/2025	ND	Low		ND	Low
M004 - Water Bottle Filler- Left of the Box Office door	19220501-178WB	1/17/2025	ND	Low		ND	Low
M004- Drinking water. Left	19220501-179DW	1/17/2025	ND	Low		ND	Low
M004 - Drinking water. Right	19220501-180DW	1/17/2025	1	Low		1	Low
M001C - Bathroom faucet. Men's Restroom, Furthest left #1	19220501-181BF	1/17/2025	ND	Low		ND	Low
M001C- Bathroom faucet. Men's Restroom, center left #2	19220501-182BF	1/17/2025	ND	Low		ND	Low

M001C - Bathroom faucet. Men's Restroom, center right #3	19220501-183BF	1/17/2025	ND	Low		ND	Low
M001C- Bathroom faucet. Men's Restroom, Furthest right #4	19220501-184BF	1/17/2025	ND	Low		ND	Low
M001B- Bathroom faucet. Women's restroom. Furthest right #1	19220501-185BF	1/17/2025	ND	Low		ND	Low
M001B -Bathroom faucet. Women's restroom. Center right #2	19220501-186BF	1/17/2025	ND	Low		ND	Low
M001B -Bathroom faucet. Women's restroom. Center left #3	19220501-187BF	1/17/2025	ND	Low		ND	Low
M001B- Bathroom faucet. Women's restroom. Furthest left #4	19220501-188BF	1/17/2025	ND	Low		ND	Low
M040A - Bathroom faucet. Single user restroom	19220501-189BF	1/17/2025	ND	Low		ND	Low
M043 - Classroom faucet. Green Room	19220501-190CF	1/17/2025	ND	Low		ND	Low
M050-Drinking water. Left	19220501-191DW	1/17/2025	ND	Low		ND	Low
M050-Drinking water. Right	19220501-192DW	1/17/2025	ND	Low		ND	Low
M050C- Bathroom faucet. Men's restroom outside Black Box	19220501-193BF	1/17/2025	ND	Low		ND	Low
M050D- Bathroom faucet. Women's restroom outside Black Box	19220501-194BF	1/17/2025	ND	Low		ND	Low
M060A- Classroom faucet. Laundry room	19220501-195CF	1/17/2025	1.1	Low		1.1	Low
M055 - Classroom faucet. Makeup room	19220501-196CF	1/17/2025	ND	Low		ND	Low
M070A- Classroom faucet. Scene shop	19220501-197CF	1/17/2025	ND	Low		ND	Low
710- Water bottle filler. Right	19220502-198WB	1/17/2025	ND	Low		ND	Low
710- Water cooler. Below fixture 19220502-198WB. Center	19220502-333WC	1/17/2025	ND	Low		ND	Low
710- Drinking water. Left	19220502-199WC	1/17/2025	ND	Low		ND	Low
716- Bathroom faucet. Girl's restroom	19220502-200BF	1/17/2025	ND	Low		ND	Low
714- Bathroom faucet. Boy's restroom	19220502-201BF	1/17/2025	ND	Low		ND	Low
701- Classroom faucet. Art room. Furthest left #1	19220502-202CF	1/17/2025	ND	Low		ND	Low
701- Classroom faucet. Art room. Left #2	19220502-203CF	1/17/2025	ND	Low		ND	Low
701- Classroom faucet. Art room. Kitchen sprayer. Center left #3	19220502-204CF	1/17/2025	ND	Low		ND	Low
701- Classroom faucet. Art room. Center right #4	19220502-205CF	1/17/2025	ND	Low		ND	Low
701- Classroom faucet. Art room. Right #5	19220502-206CF	1/17/2025	ND	Low		ND	Low
701- Classroom faucet. Art room. Kitchen sprayer. Furthest right #6	19220502-207CF	1/17/2025	ND	Low		ND	Low
704- Classroom faucet. Furthest right, kitchen sprayer #1	19220502-208CF	1/17/2025	ND	Low		ND	Low
704- Classroom faucet. Right #2	19220502-209CF	1/17/2025	ND	Low		ND	Low
704- Classroom faucet. Center right #3	19220502-210CF	1/17/2025	ND	Low		ND	Low
704- Classroom faucet. Center left, kitchen sprayer #4	19220502-211CF	1/17/2025	ND	Low		ND	Low
704- Classroom faucet. Left #5	19220502-212CF	1/17/2025	ND	Low		ND	Low
704- Classroom faucet. Furthest left, kitchen sprayer #6	19220502-213CF	1/17/2025	ND	Low		ND	Low
705- Classroom faucet. Right	19220502-214CF	1/17/2025	ND	Low		ND	Low
705- Classroom faucet. Left	19220502-215CF	1/17/2025	ND	Low		ND	Low
706- Classroom faucet. Left	19220502-216CF	1/17/2025	ND	Low		ND	Low
706- Classroom faucet. Right	19220502-217CF	1/17/2025	ND	Low		ND	Low
BB Concession Stand. Kitchen faucet	19220505-219KF	1/17/2025	ND	Low		ND	Low
BB Concession Stand. Kitchen faucet. Coffee maker	19220505-220KF	1/17/2025	29.3	High			
BB Concession Stand- Right of door outside spigot-keyed. Used for drinking water	19220505-279OS	1/17/2025	ND	Low		ND	Low
BB men's RR- Bathroom faucet.	19220505-221BF	1/17/2025	ND	Low		ND	Low
BB girls RR- Bathroom faucet	19220505-222BF	1/17/2025	1.5	Low		1.5	Low
Single User Restroom- Bathroom Faucet. Left # 1	19220503-223BF	1/17/2025	ND	Low		ND	Low
Single User Restroom- Bathroom Faucet. Left # 2	19220503-224BF	1/17/2025	ND	Low		ND	Low
Men's Restroom- Bathroom faucet. Left #2	19220503-225BF	1/17/2025	ND	Low		ND	Low

Men's Restroom- Bathroom faucet. Center #3	19220503-226BF	1/17/2025	ND	Low		ND	Low
Men Restroom-Bathroom faucet. Right #4	19220503-227BF	1/17/2025	ND	Low		ND	Low
Concession Stand- Kitchen faucet	19220503-228KF	1/17/2025	ND	Low		ND	Low
Girls Restroom- Bathroom faucet. Right #1	19220503-229BF	1/17/2025	ND	Low		ND	Low
Girls Restroom- Bathroom faucet. Center #2	19220503-230BF	1/17/2025	ND	Low		ND	Low
Girls Restroom- Bathroom faucet. Left #3	19220503-231BF	1/17/2025	ND	Low		ND	Low
Single User Restroom- Bathroom faucet	19220503-232BF	1/17/2025	ND	Low		ND	Low
Family Restroom. Bathroom faucet	19220503-233BF	1/17/2025	ND	Low		ND	Low