

Water Testing Results

Willamette Primary School

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result-ppb
Room 014 Boys Bathroom Faucet "Down stairs boys bathroom"	19221100-001BF/19220700-001BF	4/12/2023	2.8
Room 017 Girls Bathroom Faucet "Down stairs girls bathroom"	19221100-002BF/19220700-002BF	4/12/2023	1.6
Hall 018 Water Chiller Drinking water "Located between boys bathroom 014 and girls bathroom 017"	19221100-003WC/19220700-003WC	4/12/2023	ND
Room 019 Classroom Faucet	19221100-004CF/19220700-004CF	4/12/2023	ND
Room 020 Classroom Faucet	19221100-005CF/19220700-005CF	4/12/2023	ND
Room 020 Classroom Drinking Fountain	19221100-006DW/19220700-006DW	4/12/2023	ND
Room 025 Staff Room Faucet "Staff room faucet "	19221100-007SF/19220700-007SF	4/12/2023	ND
Room 025 Staff Room Faucet "Staff room instant hot water fixture"	19221100-085SF/19220700-085SF	4/12/2023	ND
Room 026 Staff Bathroom Faucet "Staff bathroom faucet, right"	19221100-008BF/19220700-008BF	4/12/2023	ND
Room 026 Staff Bathroom Faucet "Large utility sink, left"	19221100-086BF/19220700-086BF	4/12/2023	3.5
Room 027 Kitchen "East facing sink"	19221100-009KF/19220700-009KF	4/12/2023	1.3
Room 027 Kitchen "SE hand washing sink"	19221100-010KF/19220700-010KF	4/12/2023	ND
Room 028 Kitchen "NE Pot washing sink"	19221100-011KF/19220700-011KF	4/12/2023	ND
Room 029 Servery Sink Faucet	19221100-012CF/19220700-012CF	4/12/2023	ND
Room 030 Cafeteria sink Faucet	19221100-013CF/19220700-013CF	4/12/2023	ND
Room 032 Boys Bathroom Faucet "Boys bathroom by Cafeteria"	19221100-014BF/19220700-014BF	4/12/2023	ND
Room 033 Girls Bathroom Faucet "Girls bathroom by Cafeteria"	19221100-015BF/19220700-015BF	4/12/2023	ND
Hall 035 Water Chiller Drinking water "Located between 032 boys restroom and 033 girls restroom"	19221100-016WC/19220700-016WC	4/12/2023	ND
Room 038 Classroom Faucet	19221100-017CF/19220700-017CF	4/12/2023	ND
Room 038 Classroom Drinking Fountain	19221100-018DW/19220700-018DW	4/12/2023	ND
Room 039 Classroom Faucet	19221100-019CF/19220700-019CF	4/12/2023	ND
Room 039 Classroom Drinking Fountain	19221100-020DW/19220700-020DW	4/12/2023	ND
Hall 037 Water Chiller Drinking water "Located outside 040 Girls bathroom "	19221100-021WC/19220700-021WC	4/12/2023	ND
Room 040 Girls Bathroom "Girls bathroom,right faucet"	19221100-022BF/19220700-022BF	4/12/2023	ND
Room 040 Girls Bathroom "Girls bathroom,left faucet"	19221100-023BF/19220700-023BF	4/12/2023	ND
Room 042 Classroom Faucet	19221100-024CF/19220700-024CF	4/12/2023	ND
Room 042 Classroom Drinking Fountain	19221100-025DW/19220700-025DW	4/12/2023	ND
Room 044 Classroom Faucet	19221100-026CF/19220700-026CF	4/12/2023	ND
Room 044 Classroom Drinking Fountain	19221100-027DW/19220700-027DW	4/12/2023	1.5
Room 045 Boys Bathroom "Boys bathroom,right faucet"	19221100-028BF/19220700-028BF	4/12/2023	1.2
Room 045 Boys Bathroom "Boys bathroom, left faucet"	19221100-029BF/19220700-029BF	4/12/2023	ND
Room 047 Classroom Faucet	19221100-030CF/19220700-030CF	4/12/2023	ND
Room 047 Classroom Drinking Fountain	19221100-031DW/19220700-031DW	4/12/2023	ND
Room 048 Classroom Faucet	19221100-032CF/19220700-032CF	4/12/2023	ND
Room 048 Classroom Drinking Fountain	19221100-033DW/19220700-033DW	4/12/2023	ND
Room 107 Nurses Station Sink Faucet	19221100-034NS/19220700-034NS	4/12/2023	ND
Room 109 Staff Sink Faucet	19221100-035SF/19220700-035SF	4/12/2023	ND
Room 110 Staff Workroom Faucet	19221100-036SF/19220700-036SF	4/12/2023	ND
Room 111 Classroom Faucet "Classroom faucet, located by the door"	19221100-037CF/19220700-037CF	4/12/2023	ND
Room 111 Classroom Drinking Fountain "Classroom drinking water, located by the door"	19221100-038DW/19220700-038DW	4/12/2023	ND
Room 111 Classroom Faucet "Classroom faucet, south facing sink"	19221100-087CF/19220700-087CF	4/12/2023	5.5
Room 112 Classroom Faucet	19221100-039CF/19220700-039CF	4/12/2023	ND
Room 112 Classroom Drinking Fountain	19221100-040DW/19220700-040DW	4/12/2023	1.4
Room 113 Classroom Faucet	19221100-041CF/19220700-041CF	4/12/2023	ND
Room 113 Classroom Drinking Fountain	19221100-042DW/19220700-042DW	4/12/2023	3.5
Room 114 Counseling office Staff Faucet	19221100-043SF/19220700-043SF	4/12/2023	5.1
Room 115 Classroom Faucet	19221100-044CF/19220700-044CF	4/12/2023	1.0
Room 115 Classroom Drinking Fountain	19221100-045DW/19220700-045DW	4/12/2023	2.1
Room 117 Classroom Faucet	19221100-046CF/19220700-046CF	4/12/2023	ND
Room 119 Classroom Faucet	19221100-047CF/19220700-047CF	4/12/2023	ND
Room 119 Classroom Drinking Fountain	19221100-048DW/19220700-048DW	4/12/2023	4.2
Room 121 Boys Bathroom Sink Faucet "Girls bathroom by Gym"	19221100-049BF/19220700-049BF	4/12/2023	2.0
Room 125 Boys Bathroom Sink Faucet "Boys bathroom by Gym"	19221100-050BF/19220700-050BF	4/12/2023	2.8
Room 126 Gymnasium Drinking Fountain "Gym, drinking fountain"	19221100-051DW/19220700-051DW	4/12/2023	ND
Hall 130 Drinking Fountain "Located outside Workroom 110"	19221100-052DW/19220700-052DW	4/12/2023	ND
Room 133 Classroom Faucet	19221100-053CF/19220700-053CF	4/12/2023	ND
Room 133 Classroom Drinking Fountain	19221100-054DW/19220700-054DW	4/12/2023	ND
Room 134 Bathroom Faucet "Unisex bathroom"	19221100-055BF/19220700-055BF	4/12/2023	ND
Room 138 Classroom Faucet	19221100-056CF/19220700-056CF	4/12/2023	2.6
Room 138 Classroom Drinking Fountain	19221100-057DW/19220700-057DW	4/12/2023	3.1
Hall 139 Drinking Fountain "Located outside classroom 140"	19221100-058DW/19220700-058DW	4/12/2023	ND
Room 140 Classroom Faucet	19221100-059CF/19220700-059CF	4/12/2023	ND
Room 140 Classroom Drinking Fountain	19221100-060DW/19220700-060DW	4/12/2023	ND
Room 141 Classroom Faucet	19221100-061CF/19220700-061CF	4/12/2023	ND
Room 141 Classroom Drinking Fountain	19221100-062DW/19220700-062DW	4/12/2023	1.1
Room 143 Classroom Faucet	19221100-063CF/19220700-063CF	4/12/2023	1.9
Room 143 Classroom Drinking Fountain	19221100-064DW/19220700-064DW	4/12/2023	ND
Room 144 Classroom Faucet	19221100-065CF/19220700-065CF	4/12/2023	ND
Room 144 Classroom Drinking Fountain	19221100-066DW/19220700-066DW	4/12/2023	1.2
Room 145 Girls Bathroom Faucet "Girls bathroom, right faucet"	19221100-067BF/19220700-067BF	4/12/2023	ND
Room 145 Girls Bathroom Faucet "Girls bathroom, left faucet"	19221100-068BF/19220700-068BF	4/12/2023	ND
Room 147 Classroom Faucet	19221100-069CF/19220700-069CF	4/12/2023	1.0
Room 147 Classroom Drinking Fountain	19221100-070DW/19220700-070DW	4/12/2023	ND

Room 148 Classroom Faucet	19221100-071CF/19220700-071CF	4/12/2023	ND
Room 148 Classroom Drinking Fountain	19221100-072DW/19220700-072DW	4/12/2023	ND
Room 149 Boys Bathroom "Boys bathroom, right faucet"	19221100-073BF/19220700-073BF	4/12/2023	1.4
Room 149 Boys Bathroom "Boys bathroom, left faucet"	19221100-074BF/19220700-074BF	4/12/2023	ND
Room 151 Classroom Faucet	19221100-075CF/19220700-075CF	4/12/2023	ND
Room 151 Classroom Drinking Fountain	19221100-076DW/19220700-076DW	4/12/2023	ND
Room 152 Classroom Faucet	19221100-077CF/19220700-077CF	4/12/2023	ND
Room 152 Classroom Drinking Fountain	19221100-078DW/19220700-078DW	4/12/2023	ND
Room 201 Classroom Faucet	19221100-079CF/19220700-079CF	4/12/2023	ND
Room 201 Classroom Drinking Fountain	19221100-080DW/19220700-080DW	4/12/2023	3.5
Room 202 Classroom Faucet	19221100-081CF/19220700-081CF	4/12/2023	1.7
Room 202 Drinking Fountain	19221100-082DW/19220700-082DW	4/12/2023	ND
Room 203 Classroom Faucet	19221100-083CF/19220700-083CF	4/12/2023	ND
Room 203 Classroom Drinking Fountain	19221100-084DW/19220700-084DW	4/12/2023	1.4
Outside Rm. 042 "keyed"	19221100-088OS/19220700-088OS	Exempt	Exempt
Outside Rm.038 "keyed"	19221100-089OS/19220700-089OS	Exempt	Exempt
Outside Rm.202 "Keyed"	19222200-090OS/19220700-090OS	Exempt	Exempt
Outside Rm.044 "Keyed"	19221100-091OS/19220700-091OS	Exempt	Exempt
Outside Rm. 048 "Keyed"	19221100-092OS/19220700-092OS	Exempt	Exempt
Greenhouse -LEFT Side-"Non Potable sign"	19221100-093OS/19220700-093OS	Exempt	Exempt
Greenhouse -Right side-"Non Potable sign"	19221100-094OS/19220700-094OS	Exempt	Exempt
Outside Rm.113 "Keyed"	19221100-095OS/19220700-095OS	Exempt	Exempt
Outside Rm.111 "Keyed"	19221100-096OS/19220700-096OS	Exempt	Exempt
Outside Rm.138 "Keyed"	19221100-097OS/19220700-097OS	Exempt	Exempt
Outside Rm.141 "Keyed"	19221100-098OS/19220700-098OS	Exempt	Exempt
Any fixture testing at or above the action level of 15 ppb is immediately removed from service			
RETESTS			
ND = Non Detect - Lead level is below the set detection limits			of X ppb