

Lead in Water Test Results Summary: Wilsonville High School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[1] ppb**.

Legend:

- Test results **equal to or greater than the Action Level** of 15 ppb are **highlighted in red and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **near the Action Level** of 15 ppb (11.99 to 14.99 ppb) are **highlighted in yellow and precede a "Med" (Medium) value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
94D-Staff faucet. Work room 94D. Sprayer. Right	19220900-001SF	5/22/2024	ND	Low	5/22/2024	ND	Low
94D-Staff faucet. Work room 94D. Center	19220900-002SF	5/22/2024	ND	Low	5/22/2024	ND	Low
94D-Staff faucet. Work room 94D. Left. Instant hot water	19220900-003SF	5/22/2024	ND	Low	5/22/2024	ND	Low
94K-Bathroom faucet. Women's restroom. Single user. Across the hallway from Work room 94D in the main office	19220900-004BF	5/22/2024	ND	Low	5/22/2024	ND	Low
94K-Bathroom faucet. Men's restroom. Single user. Across the hallway from Work room 94D in the main office	19220900-005BF	5/22/2024	ND	Low	5/22/2024	ND	Low
98D-Bathroom faucet. Uni single user restroom. Located off Life learner classroom in room 98C	19220900-006BF	5/22/2024	ND	Low	5/22/2024	ND	Low
98I-Kitchen faucet. Life learner classroom. Right	19220900-007KF	5/22/2024	ND	Low	5/22/2024	ND	Low
98I-Kitchen faucet. Life learner classroom. Left. Instant hot water	19220900-008KF	5/22/2024	ND	Low	5/22/2024	ND	Low
98J-Classroom faucet. Laundry room	19220900-009CF	5/22/2024	2	Low	5/22/2024	2	Low
Hall 150- Drinking water. Right. Outside men's restroom rm. 140 entrance	19220900-010DW	5/22/2024	ND	Low	5/22/2024	ND	Low
Hall 150- Drinking water. Left. Outside men's restroom rm. 140 entrance	19220900-011DW	5/22/2024	ND	Low	5/22/2024	ND	Low
140-Bathroom faucet. Farthest left. First floor Men's restroom Rm.140. Across the hallway from Open resource classroom Rm. 98H	19220900-012BF	5/22/2024	ND	Low	5/22/2024	ND	Low
140-Bathroom faucet. Center left. First floor Men's restroom Rm.140. Across the hallway from Open resource classroom Rm. 98H	19220900-013BF	5/22/2024	ND	Low	5/22/2024	ND	Low
140-Bathroom faucet. Center right. First floor Men's restroom Rm.140. Across the hallway from Open resource classroom Rm. 98H	19220900-014BF	5/22/2024	ND	Low	5/22/2024	ND	Low
140-Bathroom faucet. Farthest right. First floor Men's restroom Rm.140. Across the hallway from Open resource classroom Rm. 98H	19220900-015BF	5/22/2024	ND	Low	5/22/2024	ND	Low
Hall 152-Water bottle filler. Across the hallway from the first floor Men's restroom Rm. 140	19220900-016WB	5/22/2024	ND	Low	5/22/2024	ND	Low
104-Classroom faucet. West facing. Farthest right	19220900-017CF	5/22/2024	ND	Low	5/22/2024	ND	Low
104-Classroom faucet. West facing. Right center	19220900-018CF	5/22/2024	ND	Low	5/22/2024	ND	Low
104-Classroom faucet. West facing. Center. Emergency eye wash station	19220900-019CF	5/22/2024	ND	Low	5/22/2024	ND	Low
104-Classroom faucet. West facing. Left center	19220900-020CF	5/22/2024	ND	Low	5/22/2024	ND	Low

104-Classroom faucet. West facing. Farthest left	19220900-021CF	5/22/2024	ND	Low	5/22/2024	ND	Low
104-Classroom faucet. South facing. Left of Prep room door	19220900-022CF	5/22/2024	ND	Low	5/22/2024	ND	Low
104A-Classroom faucet. Science prep room	19220900-023CF	5/22/2024	ND	Low	5/22/2024	ND	Low
114-Classroom faucet. Northwest facing. Right	19220900-025CF	5/22/2024	1.9	Low	5/22/2024	1.9	Low
114-Classroom faucet. Northwest facing. Center	19220900-026CF	5/22/2024	ND	Low	5/22/2024	ND	Low
114-Classroom faucet. Northwest facing. Left	19220900-027CF	5/22/2024	ND	Low	5/22/2024	ND	Low
114-Classroom faucet. West facing. Right	19220900-028CF	5/22/2024	ND	Low	5/22/2024	ND	Low
114-Classroom faucet. West facing. Left	19220900-029CF	5/22/2024	ND	Low	5/22/2024	ND	Low
114-Classroom faucet. South facing. Right	19220900-030CF	5/22/2024	ND	Low	5/22/2024	ND	Low
114-Classroom faucet. South facing. Center right	19220900-031CF	5/22/2024	ND	Low	5/22/2024	ND	Low
114-Classroom faucet. South facing. Left	19220900-032CF	5/22/2024	ND	Low	5/22/2024	ND	Low
114A-Classroom faucet. Science prep room	19220900-033CF	5/22/2024	ND	Low	5/22/2024	ND	Low
116-Classroom faucet. North facing. Right	19220900-034CF	5/22/2024	ND	Low	5/22/2024	ND	Low
116-Classroom faucet. North facing. Center	19000900-035CF	5/22/2024	ND	Low	5/22/2024	ND	Low
116-Classroom faucet. North facing. Left	19220900-036CF	5/22/2024	ND	Low	5/22/2024	ND	Low
116-Classroom faucet. West facing. Right	19220900-037CF	5/22/2024	ND	Low	5/22/2024	ND	Low
116-Classroom faucet. West facing. Left	19220900-038CF	5/22/2024	1	Low	5/22/2024	1	Low
116-Classroom faucet. South facing. Right	19220900-039CF	5/22/2024	ND	Low	5/22/2024	ND	Low
116-Classroom faucet. South facing. Center	19220900-040CF	5/22/2024	1.3	Low	5/22/2024	1.3	Low
116-Classroom faucet. South facing. Left	19220900-041CF	5/22/2024	ND	Low	5/22/2024	ND	Low
118-Classroom faucet. Northeast facing. Right	19220900-042CF	5/22/2024	ND	Low	5/22/2024	ND	Low
118-Classroom faucet. Northeast facing. Center	19220900-043CF	5/22/2024	ND	Low	5/22/2024	ND	Low
118-Classroom faucet. Northeast facing. Left	19220900-044CF	5/22/2024	ND	Low	5/22/2024	ND	Low
118-Classroom faucet. West facing. Right	19220900-045CF	5/22/2024	ND	Low	5/22/2024	ND	Low
118-Classroom faucet. West facing. Left	19220900-046CF	5/22/2024	ND	Low	5/22/2024	ND	Low
118-Classroom faucet. Southeast facing. Right	19220900-047CF	5/22/2024	ND	Low	5/22/2024	ND	Low
118-Classroom faucet. Southeast facing. Center	19220900-048CF	5/22/2024	ND	Low	5/22/2024	ND	Low
118-Classroom faucet. Southeast facing. Left	19220900-049CF	5/22/2024	ND	Low	5/22/2024	ND	Low
118A-Classroom faucet. Science prep room	19220900-051CF	5/22/2024	ND	Low	5/22/2024	ND	Low
120-Classroom faucet. Northwest facing. Right	19220900-052CF	5/22/2024	ND	Low	5/22/2024	ND	Low
120-Classroom faucet. Northwest facing. Center	19220900-053CF	5/22/2024	ND	Low	5/22/2024	ND	Low
120-Classroom faucet. Northwest facing. Left	19220900-054CF	5/22/2024	ND	Low	5/22/2024	ND	Low
120-Classroom faucet. Southwest facing. Right	19220900-055CF	5/22/2024	ND	Low	5/22/2024	ND	Low
120-Classroom faucet. Southwest facing. Left	19220900-056CF	5/22/2024	ND	Low	5/22/2024	ND	Low
120-Classroom faucet. South facing. Right	19220900-057CF	5/22/2024	ND	Low	5/22/2024	ND	Low
120-Classroom faucet. South facing. Center	19220900-058CF	5/22/2024	ND	Low	5/22/2024	ND	Low
120-Classroom faucet. South facing. Left	19220900-059CF	5/22/2024	ND	Low	5/22/2024	ND	Low
Hall 161- Water bottle filler.	19220900-060WB	5/22/2024	ND	Low	5/22/2024	ND	Low
165-Classroom faucet. Porch 165. Outside classroom 125	19220900-061CF	5/22/2024	ND	Low	5/22/2024	ND	Low
CORR.164-Drinking water. Left. Outside Men's restroom Rm.132	19220900-062DW	5/22/2024	ND	Low	5/22/2024	ND	Low
CORR.164-Drinking water. Right. Outside Men's restroom Rm.132	19220900-063DW	5/22/2024	ND	Low	5/22/2024	ND	Low
132-Bathroom faucet. Farthest left. Men's restroom. Across from classroom 121 and 123	19220900-064BF	5/22/2024	ND	Low	5/22/2024	ND	Low

132-Bathroom faucet. Center left. Men's restroom. Across from classroom 121 and 123	19220900-065BF	5/22/2024	ND	Low	5/22/2024	ND	Low
132-Bathroom faucet. Center right. Men's restroom. Across from classroom 121 and 123	19220900-066BF	5/22/2024	ND	Low	5/22/2024	ND	Low
132-Bathroom faucet. Farthest right. Men's restroom. Across from classroom 121 and 123	19220900-067BF	5/22/2024	ND	Low	5/22/2024	ND	Low
133-Bathroom faucet. Farthest right. Women's restroom. Across from classroom 121 and 123	19220900-068BF	5/22/2024	ND	Low	5/22/2024	ND	Low
133-Bathroom faucet. Center right. Women's restroom. Across from classroom 121 and 123	19220900-069BF	5/22/2024	ND	Low	5/22/2024	ND	Low
133-Bathroom faucet. Center left. Women's restroom. Across from classroom 121 and 123	19220900-070BF	5/22/2024	ND	Low	5/22/2024	ND	Low
133-Bathroom faucet. Farthest left. Women's restroom. Across from classroom 121 and 123	19220900-071BF	5/22/2024	ND	Low	5/22/2024	ND	Low
163-Classroom faucet. Porch 163. Outside room 119	19220900-072CF	5/22/2024	ND	Low	5/22/2024	ND	Low
124-Staff faucet. Library workroom	19220900-073SF	5/22/2024	ND	Low	5/22/2024	ND	Low
HALL 151-Drinking water. Right. Outside women's restroom Rm.141	19220900-074DW	5/22/2024	ND	Low	5/22/2024	ND	Low
HALL 151-Drinking water. Left. Outside women's restroom Rm.141	19220900-075DW	5/22/2024	38	High	8/1/2024	2.2	Low
141-Bathroom faucet. Farthest right. First story women's restroom. Located next to Rm. 81 Yr.Bk./Dig Pub/Journ./Gr.Des.	19220900-076BF	5/22/2024	ND	Low	5/22/2024	ND	Low
141-Bathroom faucet. Center right. First story women's restroom. Located next to Rm. 81 Yr.Bk./Dig Pub/Journ./Gr.Des.	19220900-077BF	5/22/2024	ND	Low	5/22/2024	ND	Low
141-Bathroom faucet. Center left. First story women's restroom. Located next to Rm. 81 Yr.Bk./Dig Pub/Journ./Gr.Des.	19220900-078BF	5/22/2024	ND	Low	5/22/2024	ND	Low
141-Bathroom faucet. Farthest left. First story women's restroom. Located next to Rm. 81 Yr.Bk./Dig Pub/Journ./Gr.Des.	19220900-079BF	5/22/2024	ND	Low	5/22/2024	ND	Low
110C-Staff faucet. Located in the kitchen of the teachers Cluster Rm.110	19220900-080SF	5/22/2024	ND	Low	5/22/2024	ND	Low
110A-Bathroom faucet. First story, single user, women's restroom. Located in the teachers Cluster Rm.110	19220900-081BF	5/22/2024	ND	Low	5/22/2024	ND	Low
110D-Bathroom faucet. First story, single user, men's restroom. Located in the teachers Cluster Rm.110	19220900-082BF	5/22/2024	ND	Low	5/22/2024	ND	Low
HALL 250-Drinking water. Right. Second story outside the men's restroom. Across from the Fan rm.242	19220900-083DW	5/22/2024	3.7	Low	5/22/2024	3.7	Low
HALL 250-Drinking water. Left. Second story outside the men's restroom. Across from the Fan rm.242	19220900-084DW	5/22/2024	6.9	Low	5/22/2024	6.9	Low
240-Bathroom faucet. Farthest left. Second story Men's restroom. Across from Fan Rm.242	19220900-085BF	5/22/2024	ND	Low	5/22/2024	ND	Low
240-Bathroom faucet. Left center. Second story Men's restroom. Across from Fan Rm.242	19220900-086BF	5/22/2024	ND	Low	5/22/2024	ND	Low
240-Bathroom faucet. Right center. Second story Men's restroom. Across from Fan Rm.242	19220900-087BF	5/22/2024	ND	Low	5/22/2024	ND	Low

240-Bathroom faucet. Farthest right. Second story Men's restroom. Across from Fan Rm.242	19220900-088BF	5/22/2024	ND	Low	5/22/2024	ND	Low
214-Classroom faucet. North facing. Right	19220900-089CF	5/22/2024	ND	Low	5/22/2024	ND	Low
214-Classroom faucet. North facing. Left	19220900-090CF	5/22/2024	ND	Low	5/22/2024	ND	Low
214-Classroom faucet. West facing. Right	19220900-091CF	5/22/2024	ND	Low	5/22/2024	ND	Low
214-Classroom faucet. West facing. Left	19220900-092CF	5/22/2024	ND	Low	5/22/2024	ND	Low
214-Classroom faucet. South facing. Right	19220900-093CF	5/22/2024	ND	Low	5/22/2024	ND	Low
214-Classroom faucet. South facing. Left	19220900-094CF	5/22/2024	ND	Low	5/22/2024	ND	Low
214A-Staff faucet. Science prep room	19220900-096SF	5/22/2024	ND	Low	5/22/2024	ND	Low
216-Classroom faucet. North facing. Right	19220900-097CF	5/23/2024	ND	Low	5/23/2024	ND	Low
216-Classroom faucet. North facing. Left	19220900-098CF	5/22/2024	1.3	Low	5/22/2024	1.3	Low
216-Classroom faucet. Southwest facing. Right	19220900-099CF	5/22/2024	ND	Low	5/22/2024	ND	Low
216-Classroom faucet. Southwest facing. Left	19220900-100CF	5/22/2024	1.2	Low	5/22/2024	1.2	Low
216-Classroom faucet. Southeast facing. Right	19220900-101CF	5/22/2024	1.5	Low	5/22/2024	1.5	Low
216-Classroom faucet. Southeast facing. Left	19220900-102CF	5/22/2024	ND	Low	5/22/2024	ND	Low
218-Classroom faucet. North facing. Right	19220900-103CF	5/22/2024	ND	Low	5/22/2024	ND	Low
218-Classroom faucet. North facing. Left	19220900-104CF	5/22/2024	ND	Low	5/22/2024	ND	Low
218-Classroom faucet. West facing. Right	19220900-105CF	5/22/2024	ND	Low	5/22/2024	ND	Low
218-Classroom faucet. West facing. Center	19220900-106CF	5/22/2024	ND	Low	5/22/2024	ND	Low
218-Classroom faucet. West facing. Left	19220900-107CF	5/22/2024	ND	Low	5/22/2024	ND	Low
218-Classroom faucet. South facing. Right	19220900-108CF	5/23/2024	ND	Low	5/23/2024	ND	Low
218-Classroom faucet. South facing. Left	19220900-109CF	5/22/2024	ND	Low	5/22/2024	ND	Low
218A-Staff faucet. Science prep room	19220900-110SF	5/22/2024	ND	Low	5/22/2024	ND	Low
220-Ice machine.	19220900-295IM	5/23/2024	ND	Low	5/23/2024	ND	Low
220-Classroom faucet. North facing. Right	19220900-111CF	5/22/2024	ND	Low	5/22/2024	ND	Low
220-Classroom faucet. North facing. Left	19220900-112CF	5/22/2024	ND	Low	5/22/2024	ND	Low
220-Classroom faucet. West facing. Right	19220900-113CF	5/22/2024	ND	Low	5/22/2024	ND	Low
220-Classroom faucet. West facing. Center	19220900-114CF	5/22/2024	ND	Low	5/22/2024	ND	Low
220-Classroom faucet. West facing. Left	19220900-115CF	5/23/2024	ND	Low	5/23/2024	ND	Low
220-Classroom faucet. South facing. Right	19220900-116CF	5/23/2024	ND	Low	5/23/2024	ND	Low
220-Classroom faucet. South facing. Right	19220900-117CF	5/22/2024	ND	Low	5/22/2024	ND	Low
265-Classroom faucet. Porch 265. Outside classroom 225	19220900-118CF	5/22/2024	ND	Low	5/22/2024	ND	Low
CORR.264-Drinking water. Left	19220900-119DW	5/22/2024	ND	Low	5/22/2024	ND	Low
CORR.264-Drinking water. Right	19220900-120DW	5/22/2024	ND	Low	5/22/2024	ND	Low
232-Bathroom faucet. Left. Men's restroom across from classroom 221 and classroom 223	19220900-121BF	5/22/2024			5/22/2024		
232-Bathroom faucet. Center left. Men's restroom across from classroom 221 and classroom 223	19220900-122BF	5/22/2024	ND	Low	5/22/2024	ND	Low
232-Bathroom faucet. Center right. Men's restroom across from classroom 221 and classroom 223	19220900-123BF	5/22/2024	ND	Low	5/22/2024	ND	Low
232-Bathroom faucet. Right. Men's restroom across from classroom 221 and classroom 223	19220900-124BF	5/22/2024	ND	Low	5/22/2024	ND	Low
233-Bathroom faucet. Right. Women's restroom across from classroom 221 and classroom 223	19220900-125BF	5/22/2024	ND	Low	5/22/2024	ND	Low
233-Bathroom faucet. Right center. Women's restroom across from classroom 221 and classroom 223	19220900-126BF	5/22/2024	ND	Low	5/22/2024	ND	Low
233-Bathroom faucet. Left center. Women's restroom across from classroom 221 and classroom 223.	19220900-127BF	5/22/2024	ND	Low	5/22/2024	ND	Low
233-Bathroom faucet. Left. Women's restroom across from classroom 221 and classroom 223.	19220900-128BF	5/22/2024	ND	Low	5/22/2024	ND	Low

263-Classroom faucet. Porch 263. Outside classroom 219	19220900-129CF	5/22/2024	ND	Low	5/22/2024	ND	Low
HALL 251-Drinking water- Left. Outside the women's restroom.	19220900-130DW	5/22/2024	ND	Low	5/22/2024	ND	Low
HALL 251-Drinking water- Right. Outside the women's restroom.	19220900-131DW	5/22/2024	ND	Low	5/22/2024	ND	Low
241-Bathroom faucet. Women's restroom. Right. Second level across from the Fan Rm.243	19220900-132BF	5/22/2024	ND	Low	5/22/2024	ND	Low
241-Bathroom faucet. Women's restroom. Center right. Second level across from Fan Rm.243	19220900-133BF	5/22/2024	ND	Low	5/22/2024	ND	Low
241-Bathroom faucet. Women's restroom. Center left. Second level across from Fan Rm.243	19220900-134BF	5/22/2024	ND	Low	5/22/2024	ND	Low
241-Bathroom faucet. Women's restroom. Left. Second level across from Fan Rm.243	19220900-135BF	5/22/2024	ND	Low	5/22/2024	ND	Low
HALL 253- Water bottle filler	19220900-136WB	5/22/2024	ND	Low	5/22/2024	ND	Low
210C- Staff faucet. Staff kitchen	19220900-137SF	5/22/2024	2.6	Low	5/22/2024	2.6	Low
210A-Bathroom faucet. Single user women's restroom	19220900-138BF	5/22/2024	ND	Low	5/22/2024	ND	Low
210D-Bathroom faucet. Single user men's restroom	19220900-139BF	5/22/2024	ND	Low	5/22/2024	ND	Low
81-Classroom faucet. Right	19220900-140CF	5/23/2024	ND	Low	5/23/2024	ND	Low
81-Classroom faucet. Left	19220900-141CF	5/23/2024	ND	Low	5/23/2024	ND	Low
82-Classroom faucet.3D Art room. Right	19220900-145CF	5/23/2024	ND	Low	5/23/2024	ND	Low
82-Classroom faucet.3D Art room. Left	19220900-146CF	5/23/2024	ND	Low	5/23/2024	ND	Low
80-Classroom faucet-2D Art room. Left	19220900-147CF	5/23/2024	ND	Low	5/23/2024	ND	Low
80-Classroom faucet-2D Art room. Right	19220900-148CF	5/23/2024	ND	Low	5/23/2024	ND	Low
80-Classroom faucet-2D Art room. Center	19220900-149CF	5/23/2024	ND	Low	5/23/2024	ND	Low
93A-Classroom faucet.	19220900-150CF	5/23/2024	ND	Low	5/23/2024	ND	Low
70F-Nurses station faucet.	19220900-151NS	5/23/2024	5.6	Low	5/23/2024	5.6	Low
70E-Bathroom faucet. Bathroom off the nurses Station	19220900-152BF	5/23/2024	ND	Low	5/23/2024	ND	Low
HALL 70K-Classroom faucet. Across from the Registrar's office	19220900-153CF	5/23/2024	2.4	Low	5/23/2024	2.4	Low
72-Bathroom faucet. Unisex restroom.	19220900-154BF	5/23/2024	ND	Low	5/23/2024	ND	Low
74-Classroom faucet. ASB room	19220900-155CF	5/23/2024	2.6	Low	5/23/2024	2.6	Low
73-kitchen faucet. Espresso Bar. Northeast facing. Right *** REMOVED FROM SERVICE	19220900-156KF	5/23/2024	41.4	High	REMOVED FROM SERVICE		
73-kitchen faucet. Espresso Bar. East facing. Right *** REMOVED FROM SERVICE	19220900-158KF	5/23/2024	37.7	High	REMOVED FROM SERVICE		
73-kitchen faucet. Espresso Bar. East facing. Center *** REMOVED FROM SERVICE	19220900-159KF	5/23/2024	28.7	High	REMOVED FROM SERVICE		
73-kitchen faucet. Espresso Bar. East facing. Hand washing sink. Left.	19220900-160KF	5/23/2024	39.2	High	8/15/2024	ND	Low
71B-Staff faucet. Left	19220900-161SF	5/23/2024	ND	Low	5/23/2024	ND	Low
71B-Staff faucet. Right. Instant hot water	19220900-162SF	5/23/2024	ND	Low	5/23/2024	ND	Low
49A-Kitchen faucet. Faculty dining	19220900-163KF	5/23/2024	8.5	Low	5/23/2024	8.5	Low
34-Kitchen faucet. West facing. Left. Located in the island closest to the walk-ins.	19220900-164KF	5/23/2024	1	Low	5/23/2024	1	Low
34-Kitchen faucet. West facing. Right. Located in the island closest to the walk-ins.	19220900-165KF	5/23/2024	32.4	High	8/1/2024	1.3	Low
34- Kitchen faucet. West facing. Sprayer. Right. Located in the island closest to the walk-ins. Attached to the same faucet as 19220900-165KF	19220900-166KF	5/23/2024	16.5	High	8/1/2024	ND	Low
34-Kitchen faucet. North facing. Handwashing sink	19220900-167KF	5/23/2024	1.1	Low	5/23/2024	1.1	Low

34-Kitchen faucet. West facing pot filler. Right. Located in the center island.	19220900-168KF	5/23/2024	11	Low	5/23/2024	11	Low
34-Kitchen faucet. West facing pot filler. Sprayer. Right. Located in the center island. Attached to the same fixture as 19220900-168KF	19220900-169KF	5/23/2024	9.9	Low	5/23/2024	9.9	Low
34-Kitchen faucet. Food prep sink. Located in the last island closest to the office.	19220900-171KF	5/23/2024	1.4	Low	5/23/2024	1.4	Low
34-Kitchen faucet. Hand washing sink. West facing. Next to the office door.	19220900-172KF	5/23/2024	ND	Low	5/23/2024	ND	Low
34- Ice machine. East facing, just outside 49C. Left of hand washing sink	19220900-173IM	5/23/2024	ND	Low	5/23/2024	ND	Low
34-Kitchen faucet. Hand washing sink. East facing. Right of the ice machine	19220900-174KF	5/23/2024	11.5	Low	5/23/2024	11.5	Low
49C-Kitchen faucet. Dishwasher area. East facing. Left. Pot washer	19220900-175KF	5/23/2024	ND	Low	5/23/2024	ND	Low
49C-Kitchen faucet. Dishwasher area. East facing. Right. Sprayer.	19220900-176KF	5/23/2024	5	Low	5/23/2024	5	Low
49C- Kitchen faucet. Dishwasher area. West facing. Pot sprayer	19220900-177KF	5/23/2024	ND	Low	5/23/2024	ND	Low
49-Drinking water-Cafeteria. Right	19220900-178DW	5/23/2024	5.3	Low	5/23/2024	5.3	Low
49-Drinking water-Cafeteria. Left	19220900-179DW	5/23/2024	11.7	Low	5/23/2024	11.7	Low
61-Bathroom faucet. Single user. Across from the old box office	19220900-180BF	5/23/2024	ND	Low	5/23/2024	ND	Low
58A-Bathroom faucet. Single user.	19220900-182BF	5/23/2024	4.6	Low	5/23/2024	4.6	Low
58B-Bathroom faucet. Single user.	19220900-183BF	5/23/2024	3.1	Low	5/23/2024	3.1	Low
58-Classroom faucet. Right	19220900-184CF	5/23/2024	1.5	Low	5/23/2024	1.5	Low
58-Classroom faucet. Left	19220900-185CF	5/23/2024	ND	Low	5/23/2024	ND	Low
		5/23/2024	ND	Low	5/23/2024	ND	Low
HALL 59- Drinking water. Outside the choir room.	19220900-187DW						
36-Water chiller in the Student Commons by the Men's restroom. Right. Located in the same fixture as water bottle filler 19220900-189WB	19220900-188WC	5/23/2024	ND	Low	5/23/2024	ND	Low
36- Water bottle filler in the Student Commons by the men's restroom. Right. Located in the same fixture as water chiller 19220900-188WC	19220900-189WB	5/23/2024	ND	Low	5/23/2024	ND	Low
36- Water chiller in the Student Commons by the men's restroom. Left	19220900-190WC	5/23/2024	ND	Low	5/23/2024	ND	Low
44-Bathroom faucet. Men's restroom off the student commons. Sink # 1 Farthest left.	19220900-191BF	5/23/2024	ND	Low	5/23/2024	ND	Low
44-Bathroom faucet. Men's restroom off the student commons. Sink # 2 Left center	19220900-192BF	5/23/2024	ND	Low	5/23/2024	ND	Low
44- Bathroom faucet. Men's restroom off the student commons. Sink # 3 Center	19220900-193BF	5/23/2024	ND	Low	5/23/2024	ND	Low
44- Bathroom faucet. Men's restroom off the student commons. Sink # 4 Right center	19220900-194BF	5/23/2024	ND	Low	5/23/2024	ND	Low
44-Bathroom faucet. Men's restroom off the student commons. Farthest right # 5	19220900-195BF	5/23/2024	ND	Low	5/23/2024	ND	Low
43- Kitchen faucet. Gym concession stand. Southeast facing	19220900-196KF	5/23/2024	6	Low	5/23/2024	6	Low
43- Kitchen faucet. Gym concession stand. West facing. Coffee maker water line.	19220900-197KF	5/23/2024	1.4	Low	5/23/2024	1.4	Low
45-Bathroom faucet. Women's restroom off the student commons. Sink # 1 Farthest left.	19220900-198BF	5/23/2024	ND	Low	5/23/2024	ND	Low
45-Bathroom faucet. Women's restroom off the student commons. Sink # 2. Left center	19220900-199BF	5/23/2024	ND	Low	5/23/2024	ND	Low
45- Bathroom faucet. Women's bathroom off the student commons. Sink # 3. Center	19220900-200BF	5/23/2024	ND	Low	5/23/2024	ND	Low
45-Bathroom faucet. Women's restroom off the student commons. Sink # 4. Right center	19220900-201BF	5/23/2024	ND	Low	5/23/2024	ND	Low
45- Bathroom faucet. Women's bathroom off the student commons. Sink # 5 Farthest right	19220900-202BF	5/23/2024	ND	Low	5/23/2024	ND	Low

40-Drinking water. Main gym. Far left	19220900-203DW	5/23/2024	ND	Low	5/23/2024	ND	Low
40-Water bottle filler. Main gym. Left center	19220900-204WB	5/23/2024	ND	Low	5/23/2024	ND	Low
40- Drinking water. Main gym. Right center	19220900-205DW	5/23/2024	ND	Low	5/23/2024	ND	Low
40- Water bottle filler. Main gym. Far right.	19220900-206WB	5/23/2024	ND	Low	5/23/2024	ND	Low
41- Drinking water. Entrance of Auxiliary gym. Right side	19220900-207DW	5/23/2024	ND	Low	5/23/2024	ND	Low
41- Drinking water. Entrance of Auxiliary gym. Left side	19220900-208DW	5/23/2024	ND	Low	5/23/2024	ND	Low
33- Staff faucet. Staff room	19220900-209SF	5/23/2024	51.1	High	8/1/2024	1.2	Low
33B- Bathroom faucet. Staff only	19220900-210BF	5/23/2024	2.2	Low	5/23/2024	2.2	Low
30-Staff faucet. Storage room. Slop sink	19220900-212SF	5/23/2024	2.1	Low	5/23/2024	2.1	Low
CORR.B50- Drinking water. At the entrance to the stairwell. Left side	19220900-213DW	5/23/2024	ND	Low	5/23/2024	ND	Low
B12- Ice machine. Training room. Closest to the door	19220900-215IM	5/23/2024	ND	Low	5/23/2024	ND	Low
B12- Classroom faucet. Training room. Left sink	19220900-216CF	5/23/2024	ND	Low	5/23/2024	ND	Low
B12-Classroom faucet. Training room. Right sink	19220900-217CF	5/23/2024	2.9	Low	5/23/2024	2.9	Low
B14-Bathroom faucet. Boy's locker room. Southwest facing. Left	19220900-218BF	5/23/2024	4.4	Low	5/23/2024	4.4	Low
B14- Bathroom faucet. Boys locker room. Southwest facing. Right	19220900-219BF	5/23/2024	1.1	Low	5/23/2024	1.1	Low
B14-Drinking water. Boy's locker room	19220900-220DW	5/23/2024	1.2	Low	5/23/2024	1.2	Low
B14-Bathroom faucet. Boy's locker room. Northeast facing .Left	19220900-221BF	5/23/2024	1	Low	5/23/2024	1	Low
B14- Bathroom faucet. Boys locker room. Northeast facing. Right	19220900-222BF	5/23/2024	ND	Low	5/23/2024	ND	Low
B31A- Bathroom faucet. Coaches office bathroom	19220900-354BF	5/23/2024	4	Low	5/23/2024	4	Low
CORR.B53- Drinking fountain-Outside the elevator. Left side	19220900-237DW	5/23/2024	70	High	8/1/2024	11.8	Low
CORR.B53- Drinking fountain-Outside the elevator. Right side	19220900-238DW	5/23/2024	ND	Low	5/23/2024	ND	Low
CORR.B55- Drinking fountain. Outside Team room B22. Right side	19220900-239DW	5/23/2024	ND	Low	5/23/2024	ND	Low
CORR.B55- Drinking fountain. Outside Team room B22. Left side	19220900-240DW	5/23/2024	ND	Low	5/23/2024	ND	Low
B30A- Bathroom faucet. Girl's locker room, Coaches office bathroom	19220900-241BF	5/23/2024	2.7	Low	5/23/2024	2.7	Low
B16- Drinking water. Girl's locker room	19220900-243DW	5/23/2024	16.1	High	8/1/2024	3.8	Low
B16- Bathroom faucet. Girl's locker room. Left. Southwest facing	19220900-244BF	5/23/2024	ND	Low	5/23/2024	ND	Low
B16- Bathroom faucet. Girl's locker room. Right. Southwest facing	19220900-245BF	5/23/2024	ND	Low	5/23/2024	ND	Low
B16-Bathroom faucet. Girl's locker room. Northeast facing. Left	19220900-246BF	5/23/2024	1.5	Low	5/23/2024	1.5	Low
B16- Bathroom faucet. Girl's locker room. Northeast facing . Right	19220900-247BF	5/23/2024	ND	Low	5/23/2024	ND	Low
CORR.B52- Drinking water. Left side	19220900-260DW	5/23/2024	ND	Low	5/23/2024	ND	Low
B13- Classroom faucet. Fitness room	19220900-262CF	5/23/2024	ND	Low	5/23/2024	ND	Low
B17-Drinking water. Wrestling room, center	19220900-264DW	5/23/2024	ND	Low	5/23/2024	ND	Low
B17-Drinking water. Wrestling room, far right. *** REMOVED FROM SERVICE	19220900-265DW	5/24/2024	258	High	REMOVED FROM SERVICE		
107C-Bathroom faucet. Single user restroom	19220900-266BF	5/23/2024	ND	Low	5/23/2024	ND	Low
107B- Bathroom faucet. Single user restroom	19220900-267BF	5/23/2024	ND	Low	5/23/2024	ND	Low
107A- Bathroom faucet. Single user restroom	19220900-268BF	5/23/2024	ND	Low	5/23/2024	ND	Low
127B-Bathroom faucet. Women's bathroom. Duo of sinks closest to the door. Left	19220900-269BF	5/23/2024	ND	Low	5/23/2024	ND	Low
127B-Bathroom faucet. Women's bathroom. Duo of sinks closest to the door. Right	19220900-270BF	5/23/2024	ND	Low	5/23/2024	ND	Low
127B-Bathroom faucet. Women's bathroom. Middle trio of sinks. Farthest left	19220900-271BF	5/23/2024	ND	Low	5/23/2024	ND	Low
127B-Bathroom faucet. Women's bathroom. Middle trio of sinks. Center	19220900-272BF	5/23/2024	2.9	Low	5/23/2024	2.9	Low

127B-Bathroom faucet. Women's bathroom. Middle trio of sinks. Farthest right	19220900-273BF	5/23/2024	ND	Low	5/23/2024	ND	Low
127B- Bathroom faucet. Women's bathroom. Farthest duo of sinks. Left side	19220900-274BF	5/23/2024	1.6	Low	5/23/2024	1.6	Low
127B-Bathroom faucet. Women's bathroom. Farthest Duo of sinks. Farthest Right	19220900-275BF	5/23/2024	ND	Low	5/23/2024	ND	Low
127C-Bathroom faucet. Men's restroom. Duo of sinks. Northwest facing. Far Right # 1	19220900-277BF	5/23/2024	9.4	Low	5/23/2024	9.4	Low
127C - Bathroom faucet. Men's restroom. Duo of sinks. Northwest facing. Right Center # 2	19220900-278BF	5/23/2024	13.7	Med	8/1/2024	1	Low
127C- Bathroom faucet. Men's restroom. Duo of sinks. Northwest facing. Left Center # 3	19220900-279BF	5/23/2024	ND	Low	5/23/2024	ND	Low
127C - Bathroom faucet. Men's restroom. Duo of sinks. Northwest facing. Far left # 4	19220900-280BF	5/23/2024	1.4	Low	5/23/2024	1.4	Low
127C- Bathroom faucet. Men's restroom. Duo of sinks. North facing. Left side	19220900-281BF	5/23/2024	12.4	Med	8/1/2024	1.3	Low
127C-Bathroom faucet. Men's restroom. Duo of sinks. North facing. Right side	19220900-282BF	5/23/2024	19.6	High	8/1/2024	1	Low
127A- Ice Machine.	19220900-181IM	5/23/2024	ND	Low	5/23/2024	ND	Low
A141B - Bathroom faucet-Single user restroom	19220900-284BF	5/23/2024	4.2	Low	5/23/2024	4.2	Low
A043-Classroom faucet	19220900-285CF	5/23/2024	ND	Low	5/23/2024	ND	Low
A041A-Bathroom faucet. Single user restroom	19220900-286BF	5/23/2024	ND	Low	5/23/2024	ND	Low
A044A-Bathroom faucet. Left. Makeup room bathroom faucets.	19220900-287BF	5/23/2024	1.5	Low	5/23/2024	1.5	Low
A044A-Bathroom faucet. Center. Makeup room bathroom faucets	19220900-288BF	5/23/2024	7.7	Low	5/23/2024	7.7	Low
A044A-Bathroom faucet. Right. Makeup room bathroom faucets	19220900-289BF	5/23/2024	ND	Low	5/23/2024	ND	Low
A044B-Bathroom faucet. Left . Makeup bathroom faucets.	19220900-290BF	5/23/2024	ND	Low	5/23/2024	ND	Low
A044B-Bathroom faucet. Center. Makeup room bathroom faucets	19220900-291BF	5/23/2024	2.8	Low	5/23/2024	2.8	Low
A044B-Bathroom faucet. Right. Makeup room bathroom faucets	19220900-292BF	5/23/2024	1	Low	5/23/2024	1	Low
Water chiller. Located outside room A038 to the right. Right fixture. Same fixture as the water bottle filler	19220900-293WC	5/23/2024	ND	Low	5/23/2024	ND	Low
Water bottle filler. Located outside room A038 to the right. Right fixture. Same fixture as the water chiller.	19220900-294WB	5/23/2024	ND	Low	5/23/2024	ND	Low
Water chiller. Located outside room A038 to the right. Left fixture	19220900-336WC	5/23/2024	ND	Low	5/23/2024	ND	Low
Bathroom faucet. Football Stadium Girls Restroom- Right	19220907-315BF	5/23/2024	ND	Low	5/23/2024	ND	Low
Bathroom faucet. Football Stadium Girls Restroom- Center	19220907-316BF	5/23/2024	ND	Low	5/23/2024	ND	Low
Bathroom faucet. Football Stadium Girls Restroom- Left	19220907-317BF	5/23/2024	ND	Low	5/23/2024	ND	Low
Bathroom faucet. Football Stadium Boys Restroom- Left	19220907-318BF	5/23/2024	ND	Low	5/23/2024	ND	Low
Bathroom faucet. Football Stadium Boys Restroom - Right	19220907-319BF	5/23/2024	ND	Low	5/23/2024	ND	Low
Kitchen faucet. Football concession stand	19220908-323KF	5/23/2024	ND	Low	5/23/2024	ND	Low
Bathroom faucet. Track women's restroom- Left sink	19220905-326BF	5/23/2024	ND	Low	5/23/2024	ND	Low
Bathroom faucet. Track women's restroom- Right sink	19220905-327BF	5/23/2024	ND	Low	5/23/2024	ND	Low
Kitchen faucet. Track Concession stand. Kitchen sink	19220905-328KF	5/23/2024	64.6	High	8/1/2024	1.7	Low
Bathroom faucet. Track Men's restroom-Left sink	19220905-329BF	5/23/2024	ND	Low	5/23/2024	ND	Low

Bathroom faucet. Track Men's restroom-Right sink	19220905-330BF	5/23/2024	ND	Low	5/23/2024	ND	Low
Other-Interior spigot. Track Shed. Located inside the garage to the right, interior spigot	19220905-331OT	5/23/2024	1.2	Low	5/23/2024	1.2	Low
Softball field concession stand. Kitchen faucet	19220901-341KF	5/23/2024	ND	Low	5/23/2024	ND	Low
Softball field. Men's restroom bathroom faucet	19220901-342BF	5/23/2024	ND	Low	5/23/2024	ND	Low
Softball field. Girl's restroom bathroom faucet	19220901-343BF	5/23/2024	ND	Low	5/23/2024	ND	Low
Softball field. Drinking water. Located on the exterior wall of the concession stand. Left	19220901-344DW	5/23/2024	ND	Low	5/23/2024	ND	Low
Softball field. Drinking water. Located on the exterior wall of the concession stand. Right	19220901-345DW	5/23/2024	ND	Low	5/23/2024	ND	Low