

Lead in Water Test Results Summary: Inza R. Wood Middle School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[1] ppb**.

Legend:

- Test results **equal to or greater than the Action Level** of 15 ppb are **highlighted in red and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **near the Action Level** of 15 ppb (11.99 to 14.99 ppb) are **highlighted in yellow and precede a "Med" (Medium) value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
C118- Staff faucet. Staff Workroom faucet	19220200-001SF	5/2/2024	ND	Low	5/2/2024	ND	Low
C116- Nurses Station faucet	19220200-002NS	5/2/2024	ND	Low	5/2/2024	ND	Low
C117- Nurses Station bathroom faucet	19220200-003BF	5/2/2024	ND	Low	5/2/2024	ND	Low
C114- Bathroom faucet. Single user staff restroom	19220200-005BF	5/2/2024	ND	Low	5/2/2024	ND	Low
C113- Bathroom faucet. Single user staff restroom	19220200-006BF	5/2/2024	ND	Low	5/2/2024	ND	Low
C107-Staff faucet. Staff breakroom sink faucet. Left	19220200-007SF	5/2/2024	ND	Low	5/2/2024	ND	Low
C107-Staff faucet. Staff breakroom sink. Instant hot water. Right	19220200-008SF	5/2/2024	ND	Low	5/2/2024	ND	Low
C102- Classroom drinking water . Left	19220200-009DW	5/2/2024	ND	Low	5/2/2024	ND	Low
C102- Classroom faucet . Right	19220200-010CF	5/2/2024	ND	Low	5/2/2024	ND	Low
C103- Classroom drinking water. Right	19220200-011DW	5/2/2024	ND	Low	5/2/2024	ND	Low
C103- Classroom faucet . Left	19220200-012CF	5/2/2024	ND	Low	5/2/2024	ND	Low
C104- Classroom faucet . Southeast facing	19220200-013CF	5/2/2024	2.2	Low	5/2/2024	2.2	Low
C104- Classroom faucet. Northeast facing. Right	19220200-014CF	5/2/2024	5.9	Low	5/2/2024	5.9	Low
C104-Classroom faucet. Northeast facing. Center	19220200-015CF	5/2/2024	29.4	High	7/24/2024	ND	Low
C104-Classroom faucet. Northeast facing. Left	19220200-016CF	5/2/2024	43.5	High	7/24/2024	ND	Low
C104-Classroom faucet. Southwest facing. Center	19220200-018CF	5/2/2024	1	Low	5/2/2024	1	Low
C104-Classroom faucet. Southwest facing. Left	19220200-019CF	5/2/2024	3.1	Low	5/2/2024	3.1	Low
E104- Boy's bathroom faucet. Located in hallway E105.Across from classroom E106	19220200-020BF	5/2/2024	3.6	Low	5/2/2024	3.6	Low
E103-Girl's bathroom faucet. Located in hallway E105. Across from classroom E106	19220200-021BF	5/2/2024	2.9	Low	5/2/2024	2.9	Low
E117- Drinking water. Located left of the door to room E102	19220200-022DW	5/2/2024	ND	Low	5/2/2024	ND	Low
E102- Classroom faucet. Left	19220200-023CF	5/2/2024	ND	Low	5/2/2024	ND	Low
E102- Classroom drinking water. Right	19220200-143DW	5/2/2024	1.5	Low	5/2/2024	1.5	Low
E100- Classroom faucet. Left	19220200-024CF	5/2/2024	1.8	Low	5/2/2024	1.8	Low
E100- Classroom drinking water. Right	19220200-025DW	5/2/2024	ND	Low	5/2/2024	ND	Low
E116- Classroom faucet. Left	19220200-026CF	5/2/2024	1.3	Low	5/2/2024	1.3	Low
E116-Classroom drinking water. Right	19220200-027DW	5/2/2024	ND	Low	5/2/2024	ND	Low
E115- Classroom drinking water. Right	19220200-028DW	5/2/2024	ND	Low	5/2/2024	ND	Low
E115- Classroom faucet. Left	19220200-029CF	5/2/2024	ND	Low	5/2/2024	ND	Low
E114-Classroom faucet. Left	19220200-030CF	5/2/2024	ND	Low	5/2/2024	ND	Low
E114- Classroom drinking water. Right	19220200-031DW	5/2/2024	1	Low	5/2/2024	1	Low
E111- Staff single user bathroom faucet	19220200-032BF	5/2/2024	ND	Low	5/2/2024	ND	Low
E107 -Classroom faucet. Northwest facing. Center	19220200-034CF	5/2/2024	ND	Low	5/2/2024	ND	Low
E107-Classroom faucet. Northwest facing. Right	19220200-035CF	5/2/2024	ND	Low	5/2/2024	ND	Low
E107-Classroom faucet. Northeast facing. Left	19220200-036CF	5/2/2024	ND	Low	5/2/2024	ND	Low

E107-Classroom faucet. Northeast facing. Right	19220200-037CF	5/2/2024	ND	Low	5/2/2024	ND	Low
E107-Classroom faucet. Southeast facing. Left	19220200-038CF	5/2/2024	ND	Low	5/2/2024	ND	Low
E107-Classroom faucet. Southeast facing. Center	19220200-039CF	5/2/2024	ND	Low	5/2/2024	ND	Low
E107-Classroom faucet. Southwest facing. Right	19220200-040CF	5/2/2024	29	High	7/24/2024	ND	Low
E107-Classroom faucet. Located in the island at the front of the classroom	19220200-041CF	5/2/2024	1.2	Low	5/2/2024	1.2	Low
E106- Classroom faucet	19220200-042CF	5/2/2024	ND	Low	5/2/2024	ND	Low
F107- Boys bathroom faucet. Located in hallway F106	19220200-043BF	5/2/2024	ND	Low	5/2/2024	ND	Low
F108- Girls bathroom faucet. Located in hallway F106	19220200-044BF	5/2/2024	ND	Low	5/2/2024	ND	Low
F106-Drinking water. Located in the hallway, outside classroom F109. Drinking fountain on the right side.	19220200-045DW	5/2/2024	ND	Low	5/2/2024	ND	Low
F106-Drinking water. Located in the hallway, outside classroom F109. Drinking fountain on the left	19220200-046DW	5/2/2024	ND	Low	5/2/2024	ND	Low
F101- Staff faucet. Science prep room	19220200-148SF	5/2/2024	112	High	7/24/2024	1.2	Low
F104-Single user staff bathroom faucet	19220200-056BF	5/2/2024	ND	Low	5/2/2024	ND	Low
F103- Classroom faucet. Left	19220200-057CF	5/2/2024	2.2	Low	5/2/2024	2.2	Low
F103- Classroom drinking water. Right	19220200-058DW	5/2/2024	1.8	Low	5/2/2024	1.8	Low
F112-Classroom faucet. Left	19220200-059CF	5/2/2024	1	Low	5/2/2024	1	Low
F112-Classroom drinking water. Right	19220200-060DW	5/2/2024	1.5	Low	5/2/2024	1.5	Low
F113-Classroom drinking water. Right	19220200-061DW	5/2/2024	ND	Low	5/2/2024	ND	Low
F113-Classroom faucet. Left	19220200-062CF	5/2/2024	1.2	Low	5/2/2024	1.2	Low
F115-Classroom drinking water. Right	19220200-063DW	5/2/2024	ND	Low	5/2/2024	ND	Low
F115-Classroom faucet. Left	19220200-064CF	5/2/2024	3.5	Low	5/2/2024	3.5	Low
F109-Classroom drinking water. Right	19220200-065DW	5/2/2024	1.9	Low	5/2/2024	1.9	Low
F109-Classroom faucet. Left	19220200-066CF	5/2/2024	2.8	Low	5/2/2024	2.8	Low
D115-Classroom faucet. North facing. Right	19220200-067CF	5/2/2024	1.5	Low	5/2/2024	1.5	Low
D115-Classroom faucet. North facing. Center	19220200-068CF	5/2/2024	ND	Low	5/2/2024	ND	Low
D115-Classroom faucet. South facing. Right	19220200-070CF	5/2/2024	1.8	Low	5/2/2024	1.8	Low
D115-Classroom faucet. South facing. Center	19220200-071CF	5/2/2024	3.4	Low	5/2/2024	3.4	Low
D115-Classroom faucet. South facing. Left	19220200-072CF	5/2/2024	ND	Low	5/2/2024	ND	Low
D115-Classroom faucet. Southeast facing	19220200-073CF	5/2/2024	3.4	Low	5/2/2024	3.4	Low
D116-Classroom drinking water. Left	19220200-074DW	5/2/2024	ND	Low	5/2/2024	ND	Low
D116-Classroom faucet. Right	19220200-075CF	5/2/2024	ND	Low	5/2/2024	ND	Low
D118-Classroom faucet. Right	19220200-076CF	5/2/2024	ND	Low	5/2/2024	ND	Low
D118-Classroom drinking water. Left	19220200-077DW	5/2/2024	ND	Low	5/2/2024	ND	Low
D119-Classroom drinking water. Left	19220200-078DW	5/2/2024	ND	Low	5/2/2024	ND	Low
D119-Classroom faucet .Right	19220200-079CF	5/2/2024	ND	Low	5/2/2024	ND	Low
D120-Classroom drinking water. Right	19220200-080DW	5/2/2024	ND	Low	5/2/2024	ND	Low
D120-Classroom faucet. Left	19220200-081CF	5/2/2024	ND	Low	5/2/2024	ND	Low
D121-Classroom drinking water. Left	19220200-082DW	5/2/2024	ND	Low	5/2/2024	ND	Low
D121-Classroom faucet. Right	19220200-083CF	5/2/2024	ND	Low	5/2/2024	ND	Low
137- Library Workroom staff faucet	19220200-084SF	5/2/2024	ND	Low	5/2/2024	ND	Low
D107- Ice machine	19220200-085IM	5/2/2024	ND	Low	5/2/2024	ND	Low
D107- Staff faucet.	19220200-086SF	5/3/2024	ND	Low	5/3/2024	ND	Low
D122- Bathroom faucet. Trio of sinks. Farthest right. Single user student restrooms located between the library and cafeteria	19220200-087BF	5/2/2024	ND	Low	5/2/2024	ND	Low
D122- Bathroom faucet. Trio of sinks. Center right. Single user student restrooms located between the library and cafeteria	19220200-088BF	5/2/2024	ND	Low	5/2/2024	ND	Low
D122- Bathroom faucet. Trio of sinks. Center. Single user student restrooms located between the library and cafeteria	19220200-089BF	5/2/2024	ND	Low	5/2/2024	ND	Low
D122-Bathroom faucet. Duo of sinks Center left. Single user student restrooms located between the library and cafeteria	19220200-090BF	5/2/2024	ND	Low	5/2/2024	ND	Low

D122A- Single user restroom. Bathroom faucet	19220200-147BF	5/2/2024	ND	Low	5/2/2024	ND	Low
D122-Bathroom faucet. Duo of sinks. Farthest Left. Single user student restrooms between the library and cafeteria	19220200-091BF	5/2/2024	ND	Low	5/2/2024	ND	Low
D125-Cafeteria student sink- Right side	19220200-092CF	5/2/2024	ND	Low	5/2/2024	ND	Low
D125-Cafeteria student sink- Left Side	19220200-093CF	5/2/2024	ND	Low	5/2/2024	ND	Low
C121-Classroom faucet. Right side	19220200-094CF	5/2/2024	ND	Low	5/2/2024	ND	Low
C121-Classroom faucet. Left side	19220200-095CF	5/2/2024	ND	Low	5/2/2024	ND	Low
B105-Kitchen faucet. Hand washing sink. Northeast facing. Right of office space	19220200-096KF	5/2/2024	ND	Low	5/2/2024	ND	Low
B105-Kitchen faucet. Food prep sink. Northeast facing. Left	19220200-097KF	5/2/2024	20.7	High	7/24/2024	ND	Low
B105-Kitchen faucet. Food prep sink. Northeast facing. Right	19220200-098KF	5/2/2024	16.9	High	7/24/2024	1.5	Low
B105- Kitchen faucet. Utility sink	19220200-099KF	5/2/2024	1	Low	5/2/2024	1	Low
5A- Kitchen faucet. Pot washing sink. Southeast fa	19220200-100KF	5/2/2024	5.2	Low	5/2/2024	5.2	Low
B105A-Kitchen faucet. Dish sprayer. Southeast facing. Attached to fixture # 19220200-099KF	19220200-101KF	5/2/2024	ND	Low	5/2/2024	ND	Low
5A-Kitchen faucet. Hand washing sink. Northeast fa	19220200-102KF	5/2/2024	3.4	Low	5/2/2024	3.4	Low
B105-Bathroom faucet. Kitchen staff bathroom	19220200-103BF	5/2/2024	2.5	Low	5/2/2024	2.5	Low
D124-Water bottle filler. Right side. Located to the right of the serving line in the hallway in front of the kitchen.	19220200-104WB	5/2/2024	ND	Low	5/2/2024	ND	Low
D124- Drinking fountain. Left side. Located to the right of the serving line in the hallway in front of the kitchen.	19220200-105WC	5/2/2024	ND	Low	5/2/2024	ND	Low
B118- Drinking fountain at gym entrance. Right	19220200-106DW	4/30/2024	ND	Low	4/30/2024	ND	Low
B118- Water bottle filler at gym entrance. Left	19220200-145WB	4/30/2024	ND	Low	4/30/2024	ND	Low
124-Boys locker room bathroom faucet just inside the door	19220200-107BF	5/2/2024	ND	Low	5/2/2024	ND	Low
B109- Bathroom faucet. Boys locker room further into the locker rooms at the bathrooms. Left side	19220200-108BF	5/2/2024	2	Low	5/2/2024	2	Low
B109- Bathroom faucet. Boys locker room further into the locker rooms at the bathrooms. Right side	19220200-109BF	5/2/2024	ND	Low	5/2/2024	ND	Low
B113-Bathroom faucet. Girls locker room just inside the door.	19220200-110BF	5/2/2024	ND	Low	5/2/2024	ND	Low
B114-Bathroom faucet. Girls locker room further into the locker rooms by the restroom stalls. Right side	19220200-111BF	5/2/2024	1	Low	5/2/2024	1	Low
B114-Bathroom faucet. Girls locker room further into the locker room by the restroom stalls. Left side	19220200-112BF	5/2/2024	1	Low	5/2/2024	1	Low
A119-Bathroom faucet. Boys restroom. Trio of sinks, farthest left. Boys restroom located closest to the band room	19220200-113BF	5/2/2024	ND	Low	5/2/2024	ND	Low
A119-Bathroom faucet. Boys restroom. Trio of sinks. Center. Boys restroom located closest to the band room.	19220200-114BF	5/2/2024	ND	Low	5/2/2024	ND	Low
A119-Bathroom faucet. Boys restroom. Trio of sinks. Farthest Right. Boys restroom located closest to the band room	19220200-115BF	5/2/2024	ND	Low	5/2/2024	ND	Low
A119-Bathroom faucet. Boys restroom. Duo of sinks. Left. Boys restroom located closest to the band room	19220200-116BF	5/2/2024	ND	Low	5/2/2024	ND	Low
A119-Bathroom faucet. Boys restroom. Duo of sinks. Right side. Boys restroom located closest to the band room	19220200-117BF	5/2/2024	ND	Low	5/2/2024	ND	Low

A116-Bathroom faucet. Girls Restroom. Duo of sinks. Left. Girls restroom located closest to the band room	19220200-118BF	5/2/2024	ND	Low	5/2/2024	ND	Low
A116-Bathroom faucet. Girls Restroom. Duo of sinks. Right. Girls restroom located closest to the band room	19220200-119BF	5/2/2024	ND	Low	5/2/2024	ND	Low
A116-Bathroom faucet. Girls Restroom. Trio of sinks. Farthest Left. Girls restroom located closest to the band room	19220200-120BF	5/2/2024	ND	Low	5/2/2024	ND	Low
A116-Bathroom faucet. Girls Restroom. Trio of sinks.Center. Girls restroom located closest to the band room.	19220200-121BF	5/2/2024	ND	Low	5/2/2024	ND	Low
A116-Bathroom faucet. Girls Restroom. Trio of sinks. Farthest right. Girls restroom located closest to the band room.	19220200-122BF	5/2/2024	ND	Low	5/2/2024	ND	Low
A120- Bathroom faucet. Single user restroom. Located between the boys and girls restrooms nearest the band room	19220200-123BF	5/2/2024	ND	Low	5/2/2024	ND	Low
A121-Bathroom faucet. Single user restroom. Located between the boys and girls restrooms nearest the band room	19220200-124BF	5/2/2024	ND	Low	5/2/2024	ND	Low
A103-Classroom faucet. Left	19220200-125CF	5/2/2024	1.2	Low	5/2/2024	1.2	Low
A103-Classroom drinking water. Right	19220200-126DW	5/2/2024	ND	Low	5/2/2024	ND	Low
A100-Classroom drinking water. Right	19220200-127DW	5/2/2024	ND	Low	5/2/2024	ND	Low
A100-Classroom faucet. Left	19220200-128CF	5/2/2024	2.3	Low	5/2/2024	2.3	Low
A101-Classroom faucet- Right side	19220200-129CF	5/2/2024	ND	Low	5/2/2024	ND	Low
A101-Classroom faucet. Left side	19220200-130CF	5/2/2024	ND	Low	5/2/2024	ND	Low
A117-Kitchen faucet. Consession stand	19220200-131KF	5/2/2024	ND	Low	5/2/2024	ND	Low