

PIXIS Labs

Accurate. Reliable. On Time.

Pixis Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

Job Number: 7062302
Report Date: 06/28/2017
ORELAP #: OR100028
Project Name: PWSID 4194063
Project No: Lead & Copper - June 2017

Cover Letter

Pat McGough
West Linn School District
2755 SW Borland
West Linn, OR 97068

Dear Pat McGough,

Enclosed please find Pixis Labs analytical report for samples received as order number 7062302 on 06/23/2017. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed
Richard Reid
Project Manager

Sample Results

Sample: Upper conference rm		Collected: 06/23/17 05:00		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 136768		Received: 06/23/17 09:30		Evidence of Cooling:N					

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0157	1.3	mg/L	0.0010	1	31989-97		06/26/17 14:01	
Lead	0.0006	0.02	mg/L	0.0002	1	31989-97		06/26/17 14:01	

Sample: HR sink		Collected: 06/23/17 05:03		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 136769		Received: 06/23/17 09:30		Evidence of Cooling:N					

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0139	1.3	mg/L	0.0010	1	31989-98		06/26/17 14:03	
Lead	0.0003	0.02	mg/L	0.0002	1	31989-98		06/26/17 14:03	

Sample: Board room		Collected: 06/23/17 05:05		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 136770		Received: 06/23/17 09:30		Evidence of Cooling:N					

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0952	1.3	mg/L	0.0010	1	31989-99		06/26/17 14:06	
Lead	0.0010	0.02	mg/L	0.0002	1	31989-99		06/26/17 14:06	

Sample: Staff room		Collected: 06/23/17 05:07		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 136771		Received: 06/23/17 09:30		Evidence of Cooling:N					

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0218	1.3	mg/L	0.0010	1	31989-100		06/26/17 14:08	
Lead	0.0008	0.02	mg/L	0.0002	1	31989-100		06/26/17 14:08	

Sample: Lower conference rm		Collected: 06/23/17 05:09		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 136778		Received: 06/23/17 09:30		Evidence of Cooling:N					

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0144	1.3	mg/L	0.0010	1	31989-101		06/26/17 14:10	
Lead	0.0010	0.02	mg/L	0.0002	1	31989-101		06/26/17 14:10	

Abbreviations

- MRL Method Reporting Limit
- ND None Detected at or above the MRL
- Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

Units of Measure:

mg/L Milligrams Per Liter



in of Custody Record

12423 NE Whitaker Way
 Portland, OR 97230
 Phone: (503) 254-1794 Fax: (503) 254-1452
www.pixislabs.com

Please inform us if you know or suspect that your sample contains hazardous chemicals.

Some or all of this analyses may be subcontracted to an ORELAP accredited lab.

Company: <u>West Linn-Wilsonville S.D.</u> Contact: <u>Jeff Chambers</u> Address: <u>2755 SW Portland Rd</u> <u>Tualatin, OR</u> Email: <u>ChamberJ2@wlv.k12.or.us</u> Phone: <u>(503) 710-5838</u> Fax: () Billing (if different): _____		Analysis Requested						Purchase Order Number: _____ Project Number: _____ Project Name: _____ <input type="checkbox"/> Report Instructions: <input type="checkbox"/> State Compliance Format <input type="checkbox"/> Email Final Results <input type="checkbox"/> Fax Final Results <input type="checkbox"/> Cash/Check/CC/Net 30 Other: _____						
Field ID	Date/Time Collected	* <u>Lead & Copper</u>						Matrix	Comments	#Cnr				
<u>Upper Conference Rm</u>	<u>6-23-17 5 AM</u>													
<u>H.R. Sink</u>	<u>6-23-17 5:07A</u>													
<u>Board Room</u>	<u>6-23-17 5:07A</u>													
<u>Staff Room</u>	<u>6-23-17 5:07A</u>													
<u>Lower Conference Rm</u>	<u>6-23-17 5:09A</u>													
Collected By: _____ <input type="checkbox"/> Standard <input type="checkbox"/> Rush (1.5 Times Standard) <input type="checkbox"/> Priority Rush (2 Times Standard) Ask About Availability		Relinquished By: <u>Steph Mallis</u>	Date: <u>6-23-17</u>	Time: <u>9:30A</u>	Received By: <u>MMWJ</u>	Date: <u>6/23/17</u>	Time: <u>0930</u>	Lab Use Only: Client Alias: <u>West Linn Sc</u> Order Number: <u>7062302</u> <input type="checkbox"/> Proper Container <input type="checkbox"/> Sample Condition <input type="checkbox"/> Temperature 4± 2°C <input type="checkbox"/> Shipped Via: _____ Evidence of cooling: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No						

23°C

SUBMISSION OF SAMPLES WITH TESTING REQUIREMENTS TO PIXIS WILL BE UNDERSTOOD TO BE AN AGREEMENT FOR SERVICES IN ACCORDANCE WITH THE CONDITIONS LISTED ON THE BACK OF THIS FORM. Please ask for a copy of conditions