



WEST LINN - WILSONVILLE SCHOOL DISTRICT

Water Quality Information

September 23, 2016

Dear District Administration Building Staff,

As you know, the West Linn-Wilsonville School District has tested the water in all schools and facilities during the past two months. As lab results from each site have been analyzed by Pixis Labs, they have been made available to the District, shared with families in schools, and shared with staff members at all sites.

The results from September testing at the West Linn-Wilsonville School District Administration Building show that out of 18 test locations, none indicated elevated levels of lead that exceed the action level of 20 parts per billion or elevated levels of copper that exceed the action level of 1,350 parts per billion.

More information about District water quality testing is available at <http://www.wlww.k12.or.us/Page/10603>.

West Linn-Wilsonville School District
Department of Operations
Tim K. Woodley, Director

22210 SW Stafford Road Tualatin OR 97062
Business: 503.673.7000 Fax: 503.673.7001

www.wlww.k12.or.us

22210 SW Stafford Road Tualatin OR 97062
Business: 503.673.7000 Fax: 503.673.7001

www.wlww.k12.or.us