



Accurate. Reliable. On Time.

Pixis Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

**Job
Number:** 6071211

**Report
Date:** 07/20/2016

ORELAP #: OR100028

Project No: 026-Arts & Technology
High

Cover Letter

Pat McGough
West Linn School District
2755 SW Borland
West Linn, OR 97068

Dear Pat McGough,

Enclosed please find Pixis Labs analytical report for samples received as order number 6071211 on 07/12/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed

Richard Reid

Project Manager

Sample Results

Sample: Girls RR across from Rm 102-A-1		Collected: 07/12/16 07:10		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 113976		Received: 07/12/16 10:22		Evidence of Cooling:N					

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.140	1.3	mg/L	0.0010	1	28845-142		07/15/16 17:09	
Lead	0.0009	0.02	mg/L	0.0002	1	28845-142		07/15/16 17:09	

Sample: Girls RR across from Rm 102-A-2		Collected: 07/12/16 07:11		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 113977		Received: 07/12/16 10:22		Evidence of Cooling:N					

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.156	1.3	mg/L	0.0010	1	28845-143		07/15/16 17:11	
Lead	0.0027	0.02	mg/L	0.0002	1	28845-143		07/15/16 17:11	

Sample: Girls RR across from Rm 102-A-3		Collected: 07/12/16 07:12		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 113978		Received: 07/12/16 10:22		Evidence of Cooling:N					

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.133	1.3	mg/L	0.0010	1	28845-148		07/15/16 17:21	
Lead	0.0025	0.02	mg/L	0.0002	1	28845-148		07/15/16 17:21	

Sample: Girls RR across from Rm 102-A-4		Collected: 07/12/16 07:13		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 113979		Received: 07/12/16 10:22		Evidence of Cooling:N					

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.171	1.3	mg/L	0.0010	1	28845-149		07/15/16 17:23	
Lead	0.0028	0.02	mg/L	0.0002	1	28845-149		07/15/16 17:23	

Sample: Girls RR across from Rm 102-A-5		Collected: 07/12/16 07:14		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 113980		Received: 07/12/16 10:22		Evidence of Cooling:N					

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.149	1.3	mg/L	0.0010	1	28845-150		07/15/16 17:25	
Lead	0.0018	0.02	mg/L	0.0002	1	28845-150		07/15/16 17:25	

Sample: Boys RR across from Rm 100-A-1		Collected: 07/12/16 07:15		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 113981		Received: 07/12/16 10:22		Evidence of Cooling:N					

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0917	1.3	mg/L	0.0010	1	28845-151		07/15/16 17:27	
Lead	0.0022	0.02	mg/L	0.0002	1	28845-151		07/15/16 17:27	

Sample: Boys RR across from Rm 100-A-2		Collected: 07/12/16 07:16		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 113982		Received: 07/12/16 10:22		Evidence of Cooling:N					

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.100	1.3	mg/L	0.0010	1	28845-152		07/15/16 17:29	

Lead	0.0014	0.02	mg/L	0.0002	1	28845-152	07/15/16 17:29
------	--------	------	------	--------	---	-----------	----------------

Sample: Boys RR across from Rm 100-A-3 Collected: 07/12/16 07:17						Temp: 23 C		Matrix: Drinking Water	
Lab ID: 113983 Received: 07/12/16 10:22						Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.113	1.3	mg/L	0.0010	1	28845-153		07/15/16 17:31	
Lead	0.0009	0.02	mg/L	0.0002	1	28845-153		07/15/16 17:31	

Sample: Boys RR across from Rm 100-A-4 Collected: 07/12/16 07:18						Temp: 23 C		Matrix: Drinking Water	
Lab ID: 113984		Received: 07/12/16 10:22				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.144	1.3	mg/L	0.0010	1	28845-154		07/15/16 17:32	
Lead	0.0015	0.02	mg/L	0.0002	1	28845-154		07/15/16 17:32	

Sample: Boys RR across from Rm 100-A-5 Collected: 07/12/16 07:19						Temp: 23 C		Matrix: Drinking Water	
Lab ID: 113985						Received: 07/12/16 10:22		Evidence of Cooling:N	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.148	1.3	mg/L	0.0010	1	28845-155		07/15/16 17:34	
Lead	0.0015	0.02	mg/L	0.0002	1	28845-155		07/15/16 17:34	

Sample: Drinking Fountain across from Rm 100-C-1					Collected: 07/12/16 07:07		Temp: 23 C		Matrix: Drinking Water	
Lab ID: 113986					Received: 07/12/16 10:22		Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.203	1.3	mg/L	0.0010	1	28845-156		07/15/16 17:36		
Lead	0.0002	0.02	mg/L	0.0002	1	28845-156		07/15/16 17:36		

Sample: Drinking Fountain across from Rm 100-C-2					Collected: 07/12/16 07:08		Temp: 23 C		Matrix: Drinking Water	
Lab ID: 113987					Received: 07/12/16 10:22		Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.172	1.3	mg/L	0.0010	1	28845-157		07/15/16 17:38		
Lead	0.0005	0.02	mg/L	0.0002	1	28845-157		07/15/16 17:38		

Sample: 100-A		Collected: 07/12/16 07:31				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 113988		Received: 07/12/16 10:22				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.129	1.3	mg/L	0.0010	1	28845-162		07/15/16 17:48	
Lead	0.0017	0.02	mg/L	0.0002	1	28845-162		07/15/16 17:48	

Sample: 100-B		Collected: 07/12/16 07:32				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 113989		Received: 07/12/16 10:22				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0981	1.3	mg/L	0.0010	1	28845-163		07/15/16 17:50	
Lead	0.0013	0.02	mg/L	0.0002	1	28845-163		07/15/16 17:50	

Sample: 102-A				Collected: 07/12/16 07:33		Temp: 23 C		Matrix: Drinking Water	
Lab ID: 113990				Received: 07/12/16 10:22		Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes

Method: EPA 200.8									
Copper	0.142	1.3	mg/L	0.0010	1	28845-164		07/15/16 17:52	
Lead	0.0003	0.02	mg/L	0.0002	1	28845-164		07/15/16 17:52	
Sample: Staff Lounge-A		Collected: 07/12/16 07:34			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 113991		Received: 07/12/16 10:22			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0701	1.3	mg/L	0.0010	1	28845-165		07/15/16 17:53	
Lead	0.0006	0.02	mg/L	0.0002	1	28845-165		07/15/16 17:53	
Sample: Drinking Fountain across from Rm 200-C-2		Collected: 07/12/16 07:04			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 113992		Received: 07/12/16 10:22			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.176	1.3	mg/L	0.0010	1	28845-166		07/15/16 17:55	
Lead	0.0002	0.02	mg/L	0.0002	1	28845-166		07/15/16 17:55	
Sample: Drinking Fountain across from Rm 200-C-2		Collected: 07/12/16 07:05			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 113993		Received: 07/12/16 10:22			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.167	1.3	mg/L	0.0010	1	28845-167		07/15/16 17:57	
Lead	0.0002	0.02	mg/L	0.0002	1	28845-167		07/15/16 17:57	
Sample: Bottle Filler across from Rm 200-D		Collected: 07/12/16 07:06			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 113994		Received: 07/12/16 10:22			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.140	1.3	mg/L	0.0010	1	28845-168		07/15/16 17:59	
Lead	0.0003	0.02	mg/L	0.0002	1	28845-168		07/15/16 17:59	
Sample: 200-A		Collected: 07/12/16 06:51			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 113995		Received: 07/12/16 10:22			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.116	1.3	mg/L	0.0010	1	28845-169		07/15/16 18:01	
Lead	0.0023	0.02	mg/L	0.0002	1	28845-169		07/15/16 18:01	
Sample: 200-B		Collected: 07/12/16 06:52			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 113996		Received: 07/12/16 10:22			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0949	1.3	mg/L	0.0010	1	28845-170		07/15/16 18:03	
Lead	0.0017	0.02	mg/L	0.0002	1	28845-170		07/15/16 18:03	
Sample: 201-A		Collected: 07/12/16 06:53			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 113997		Received: 07/12/16 10:22			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0821	1.3	mg/L	0.0010	1	28845-171		07/15/16 18:05	
Lead	0.0028	0.02	mg/L	0.0002	1	28845-171		07/15/16 18:05	

Sample: 201-B		Collected: 07/12/16 06:54		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 113998		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0946	1.3	mg/L	0.0010	1	28845-176		07/15/16 18:15	
Lead	0.0012	0.02	mg/L	0.0002	1	28845-176		07/15/16 18:15	
Sample: 202-A		Collected: 07/12/16 06:55		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 113999		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.110	1.3	mg/L	0.0010	1	28845-177		07/15/16 18:17	
Lead	0.0016	0.02	mg/L	0.0002	1	28845-177		07/15/16 18:17	
Sample: 202-B		Collected: 07/12/16 06:56		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 114000		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0994	1.3	mg/L	0.0010	1	28845-178		07/15/16 18:19	
Lead	0.0008	0.02	mg/L	0.0002	1	28845-178		07/15/16 18:19	
Sample: 203-A		Collected: 07/12/16 06:58		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 114001		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0991	1.3	mg/L	0.0010	1	28845-179		07/15/16 18:21	
Lead	0.0010	0.02	mg/L	0.0002	1	28845-179		07/15/16 18:21	
Sample: 203-B		Collected: 07/12/16 06:59		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 114002		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0810	1.3	mg/L	0.0010	1	28845-180		07/15/16 18:23	
Lead	0.0015	0.02	mg/L	0.0002	1	28845-180		07/15/16 18:23	
Sample: 204-A		Collected: 07/12/16 07:00		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 114003		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0840	1.3	mg/L	0.0010	1	28845-181		07/15/16 18:24	
Lead	0.0008	0.02	mg/L	0.0002	1	28845-181		07/15/16 18:24	
Sample: 204-B		Collected: 07/12/16 07:01		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 114004		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.144	1.3	mg/L	0.0010	1	28845-182		07/15/16 18:26	
Lead	0.0004	0.02	mg/L	0.0002	1	28845-182		07/15/16 18:26	
Sample: 114-A		Collected: 07/12/16 06:36		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 114005		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0240	1.3	mg/L	0.0010	1	28845-183		07/15/16 18:28	
Lead	0.0007	0.02	mg/L	0.0002	1	28845-183		07/15/16 18:28	

Sample: 116-A		Collected: 07/12/16 06:38		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 114006		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0322	1.3	mg/L	0.0010	1	28845-184		07/15/16 18:30	
Lead	0.0041	0.02	mg/L	0.0002	1	28845-184		07/15/16 18:30	
Sample: 118-A		Collected: 07/12/16 06:39		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 114007		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0294	1.3	mg/L	0.0010	1	28845-185		07/15/16 18:32	
Lead	0.0019	0.02	mg/L	0.0002	1	28845-185		07/15/16 18:32	
Sample: 119-A		Collected: 07/12/16 06:40		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 114008		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0232	1.3	mg/L	0.0010	1	28845-190		07/15/16 18:44	
Lead	0.0082	0.02	mg/L	0.0002	1	28845-190		07/15/16 18:44	
Sample: Kiva Entry-C		Collected: 07/12/16 06:23		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 114009		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.122	1.3	mg/L	0.0010	1	28845-191		07/15/16 18:46	
Lead	0.0072	0.02	mg/L	0.0002	1	28845-191		07/15/16 18:46	
Sample: Kiva Entry-D		Collected: 07/12/16 06:25		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 114010		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.121	1.3	mg/L	0.0010	1	28845-192		07/15/16 18:48	
Lead	0.0253	0.02	mg/L	0.0002	1	28845-192		07/15/16 18:48	
Sample: 214-A		Collected: 07/12/16 06:27		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 114011		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0522	1.3	mg/L	0.0010	1	28845-193		07/15/16 18:49	
Lead	0.0109	0.02	mg/L	0.0002	1	28845-193		07/15/16 18:49	
Sample: 215-A		Collected: 07/12/16 06:28		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 114012		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0441	1.3	mg/L	0.0010	1	28845-194		07/15/16 18:51	
Lead	0.0034	0.02	mg/L	0.0002	1	28845-194		07/15/16 18:51	
Sample: 217-A		Collected: 07/12/16 06:30		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 114013		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0806	1.3	mg/L	0.0010	1	28845-195		07/15/16 18:53	
Lead	0.0027	0.02	mg/L	0.0002	1	28845-195		07/15/16 18:53	

Sample: 110-C		Collected: 07/12/16 06:41		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 114014		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0810	1.3	mg/L	0.0010	1	28845-196		07/15/16 18:55	
Lead	0.0340	0.02	mg/L	0.0002	1	28845-196		07/15/16 18:55	

Abbreviations

MRL Method Reporting Limit

ND None Detected at or above the MRL

Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

Units of Measure:


mg/L Milligrams Per Liter

Chain of Custody Record-Water Samples
026-Arts and Technology High: 29796 SW Town Center Loop, Wilsonville, OR 97070

Location/Site	Date Collected	Collector's Name	Time	Date Delivered
Girl's RR across from Rm. 102-A-1	7/12/2016	Steve Matthias	7:10 AM	7/12/2016
Girl's RR across from Rm. 102-A-2	7/12/2016	Steve Matthias	7:11 AM	7/12/2016
Girl's RR across from Rm. 102-A-3	7/12/2016	Steve Matthias	7:12 AM	7/12/2016
Girl's RR across from Rm. 102-A-4	7/12/2016	Steve Matthias	7:13 AM	7/12/2016
Girl's RR across from Rm. 102-A-5	7/12/2016	Steve Matthias	7:14 AM	7/12/2016
Boy's RR across from Rm. 100-A-1	7/12/2016	Steve Matthias	7:15 AM	7/12/2016
Boy's RR across from Rm. 100-A-2	7/12/2016	Steve Matthias	7:16 AM	7/12/2016
Boy's RR across from Rm. 100-A-3	7/12/2016	Steve Matthias	7:17 AM	7/12/2016
Boy's RR across from Rm. 100-A-4	7/12/2016	Steve Matthias	7:18 AM	7/12/2016
Boy's RR across from Rm. 100-A-5	7/12/2016	Steve Matthias	7:19 AM	7/12/2016
Drinking Fountain across fr. Rm. 100-C-1	7/12/2016	Steve Matthias	7:07 AM	7/12/2016
Drinking Fountain across fr. Rm. 100-C-2	7/12/2016	Steve Matthias	7:08 AM	7/12/2016
100-A	7/12/2016	Steve Matthias	7:31 AM	7/12/2016
100-B	7/12/2016	Steve Matthias	7:32 AM	7/12/2016
102-A	7/12/2016	Steve Matthias	7:33 AM	7/12/2016
Staff Lounge-A	7/12/2016	Steve Matthias	7:34 AM	7/12/2016
Drinking Fountain across fr. Rm. 200-C-2	7/12/2016	Steve Matthias	7:04 AM	7/12/2016
Drinking Fountain across fr. Rm. 200-C-2	7/12/2016	Steve Matthias	7:05 AM	7/12/2016
Bottle Filler across fr. Rm 200-D	7/12/2016	Steve Matthias	7:06 AM	7/12/2016
200-A	7/12/2016	Steve Matthias	6:51 AM	7/12/2016

Justin S
6071211
Page 1 of 2

 7/12/16
 Collector's Signature Date

 7/12/16, 1022
 Laboratory Signature Date

22°C, no cooling

Chain of Custody Record-Water Samples
026-Arts and Technology High: 29796 SW Town Center Loop, Wilsonville, OR 97070

200-B	7/12/2016	Steve Matthias	6:52 AM	7/12/2016
201-A	7/12/2016	Steve Matthias	6:53 AM	7/12/2016
201-B	7/12/2016	Steve Matthias	6:54 AM	7/12/2016
202-A	7/12/2016	Steve Matthias	6:55 AM	7/12/2016
202-B	7/12/2016	Steve Matthias	6:56 AM	7/12/2016
203-A	7/12/2016	Steve Matthias	6:58 AM	7/12/2016
203-B	7/12/2016	Steve Matthias	6:59 AM	7/12/2016
204-A	7/12/2016	Steve Matthias	7:00 AM	7/12/2016
204-B	7/12/2016	Steve Matthias	7:01 AM	7/12/2016
114-A	7/12/2016	Steve Matthias	6:36 AM	7/12/2016
116-A	7/12/2016	Steve Matthias	6:38 AM	7/12/2016
118-A	7/12/2016	Steve Matthias	6:39 AM	7/12/2016
119-A	7/12/2016	Steve Matthias	6:40 AM	7/12/2016
Kiva Entry-C	7/12/2016	Steve Matthias	6:23 AM	7/12/2016
Kiva Entry-D	7/12/2016	Steve Matthias	6:25 AM	7/12/2016
214-A	7/12/2016	Steve Matthias	6:27 AM	7/12/2016
215-A	7/12/2016	Steve Matthias	6:28 AM	7/12/2016
217-A	7/12/2016	Steve Matthias	6:30 AM	7/12/2016
110-C	7/12/2016	Steve Matthias	6:41 AM	7/12/2016

0671211
 Page 2 of 2

Steve Matthias 7-12-16
 Collector's Signature Date

MW Led 7/12/16, 1022
 Laboratory Signature Date
 22°C, cooling