WLWSD QUARTERLY SAFETY INSPECTIONS

ISSUE LOG

DATE: March 22 2016 FACILITY: Athey Page:

Number	Location	Issue Code	Notes	W.O.
	Rm 173		No GFI plug next to sink	
	Rm 171		No GFI next to sink	
	Rm 178		No GFI plug next to sink	
	Rm 244		No GFI next to sink	
	Rm 230		Extension cord plugged to surge protector	
	Rm229		Cord under rug	
	Rm 224		No GFI next to sink	
	Rm 222		No GFI next to sink	
	Rm 217		Cord under rug	
	Rm 216		Cord under rug	
	Staff Lounge		No GFI next to sink	