

PIXIS Labs

Accurate. Reliable. On Time.

Pixis Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

Job Number: 6081024
Report Date: 08/19/2016
ORELAP #: OR100028
Project No: 006-Athey Creek Middle School

Cover Letter

Pat McGough
West Linn School District
2755 SW Borland
West Linn, OR 97068

Dear Pat McGough,

Enclosed please find Pixis Labs analytical report for samples received as order number 6081024 on 08/10/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,
Reviewed to be Signed on approval

Sample Results

| Sample: 107-C | | Collected: 08/09/16 09:59 | | Temp: 23 C | | Matrix: Drinking Water | | | |
|-------------------|--------|---------------------------|-------|-----------------------|------|------------------------|---------------|----------------|-------|
| Lab ID: 118037 | | Received: 08/10/16 13:40 | | Evidence of Cooling:N | | | | | |
| Analyte | Result | Limit | Units | MRL | Dil. | Batch | Start/Extract | Analyzed | Notes |
| Method: EPA 200.8 | | | | | | | | | |
| Copper | 0.0342 | 1.3 | mg/L | 0.0010 | 1 | 29177-31 | | 08/16/16 15:11 | |
| Lead | 0.0039 | 0.02 | mg/L | 0.0002 | 1 | 29177-31 | | 08/16/16 15:11 | |
| Sample: 171-A-1 | | Collected: 08/09/16 10:07 | | Temp: 23 C | | Matrix: Drinking Water | | | |
| Lab ID: 118038 | | Received: 08/10/16 13:40 | | Evidence of Cooling:N | | | | | |
| Analyte | Result | Limit | Units | MRL | Dil. | Batch | Start/Extract | Analyzed | Notes |
| Method: EPA 200.8 | | | | | | | | | |
| Copper | 0.373 | 1.3 | mg/L | 0.0010 | 1 | 29177-36 | | 08/16/16 15:22 | |
| Lead | 0.0023 | 0.02 | mg/L | 0.0002 | 1 | 29177-36 | | 08/16/16 15:22 | |
| Sample: 173-A-7 | | Collected: 08/10/16 10:06 | | Temp: 23 C | | Matrix: Drinking Water | | | |
| Lab ID: 118039 | | Received: 08/10/16 13:40 | | Evidence of Cooling:N | | | | | |
| Analyte | Result | Limit | Units | MRL | Dil. | Batch | Start/Extract | Analyzed | Notes |
| Method: EPA 200.8 | | | | | | | | | |
| Copper | 0.429 | 1.3 | mg/L | 0.0010 | 1 | 29177-37 | | 08/16/16 15:24 | |
| Lead | 0.0065 | 0.02 | mg/L | 0.0002 | 1 | 29177-37 | | 08/16/16 15:24 | |
| Sample: 207-A-3 | | Collected: 08/09/16 10:01 | | Temp: 23 C | | Matrix: Drinking Water | | | |
| Lab ID: 118040 | | Received: 08/10/16 13:40 | | Evidence of Cooling:N | | | | | |
| Analyte | Result | Limit | Units | MRL | Dil. | Batch | Start/Extract | Analyzed | Notes |
| Method: EPA 200.8 | | | | | | | | | |
| Copper | 0.381 | 1.3 | mg/L | 0.0010 | 1 | 29177-38 | | 08/16/16 15:26 | |
| Lead | 0.0013 | 0.02 | mg/L | 0.0002 | 1 | 29177-38 | | 08/16/16 15:26 | |
| Sample: 216-A | | Collected: 08/10/16 10:03 | | Temp: 23 C | | Matrix: Drinking Water | | | |
| Lab ID: 118041 | | Received: 08/10/16 13:40 | | Evidence of Cooling:N | | | | | |
| Analyte | Result | Limit | Units | MRL | Dil. | Batch | Start/Extract | Analyzed | Notes |
| Method: EPA 200.8 | | | | | | | | | |
| Copper | 0.369 | 1.3 | mg/L | 0.0010 | 1 | 29177-39 | | 08/16/16 15:28 | |
| Lead | 0.0074 | 0.02 | mg/L | 0.0002 | 1 | 29177-39 | | 08/16/16 15:28 | |

Abbreviations

MRL Method Reporting Limit
 ND None Detected at or above the MRL
 Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

Units of Measure:

mg/L Milligrams Per Liter

Chain of Custody Record-Water Samples
006 - Athey Creek Middle School: 2900 SE Borland Rd., Tualatin, OR 97062

| Location/Site | Date Collected | Collector's Name | Time | Date Delivered |
|---------------|----------------|------------------|----------|----------------|
| 107-C | 8/9/2016 | Steve Matthias | 9:59 AM | 8/10/2016 |
| 171-A-1 | 8/9/2016 | Steve Matthias | 10:07 AM | 8/10/2016 |
| 173-A-7 | 8/10/2016 | Steve Matthias | 10:06 AM | 8/10/2016 |
| 207-A-3 | 8/9/2016 | Steve Matthias | 10:01 AM | 8/10/2016 |
| 216-A | 8/10/2016 | Steve Matthias | 10:03 AM | 8/10/2016 |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| 207-A-3 | | Retest | | |
| 171-A-1 | | Retest | | |

Westlins Sc
 6081024
 Page 1 of 1

23.0°C
 No cooling

Steve Matthias 8-10-16
 Collector's Signature Date

mew 8-10-16 230
 Laboratory Signature Date 1340