

PIXIS Labs

Accurate. Reliable. On Time.

Pixis Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

Job Number: 6072220
Report Date: 08/03/2016
ORELAP #: OR100028
Project No: 006-Athey Creek Middle School

Cover Letter

Pat McGough
West Linn School District
2755 SW Borland
West Linn, OR 97068

Dear Pat McGough,

Enclosed please find Pixis Labs analytical report for samples received as order number 6072220 on 07/22/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed
Richard Reid
Project Manager

Sample Results

Sample:	Collected:	Temp:	Matrix:						
Lab ID:	Received:	Evidence of Cooling:							
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.247	1.3	mg/L	0.0010	1	28933-38		07/25/16 15:43	
Lead	0.0006	0.02	mg/L	0.0002	1	28933-38		07/25/16 15:43	
Method: EPA 200.8									
Copper	0.254	1.3	mg/L	0.0010	1	28933-39		07/25/16 15:45	
Lead	0.0009	0.02	mg/L	0.0002	1	28933-39		07/25/16 15:45	
Method: EPA 200.8									
Copper	0.225	1.3	mg/L	0.0010	1	28933-40		07/25/16 15:47	
Lead	0.0009	0.02	mg/L	0.0002	1	28933-40		07/25/16 15:47	
Method: EPA 200.8									
Copper	0.336	1.3	mg/L	0.0010	1	28933-41		07/25/16 15:50	
Lead	0.0037	0.02	mg/L	0.0002	1	28933-41		07/25/16 15:50	
Method: EPA 200.8									
Copper	0.331	1.3	mg/L	0.0010	1	28933-42		07/25/16 15:52	
Lead	0.0101	0.02	mg/L	0.0002	1	28933-42		07/25/16 15:52	
Method: EPA 200.8									
Copper	0.132	1.3	mg/L	0.0010	1	28933-43		07/25/16 15:54	
Lead	0.0029	0.02	mg/L	0.0002	1	28933-43		07/25/16 15:54	
Method: EPA 200.8									
Copper	0.136	1.3	mg/L	0.0010	1	28933-44		07/25/16 15:56	

Lead 0.0126 0.02 mg/L 0.0002 1 28933-44 07/25/16 15:56

Sample: 109-A-4 Collected: 07/22/16 05:20 Temp: 23 C Matrix: Drinking Water
Lab ID: 115113 Received: 07/22/16 10:55 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper 0.342 1.3 mg/L 0.0010 1 28933-49 07/25/16 16:07

Lead 0.0038 0.02 mg/L 0.0002 1 28933-49 07/25/16 16:07

Sample: 109-A-5 Collected: 07/22/16 05:21 Temp: 23 C Matrix: Drinking Water
Lab ID: 115114 Received: 07/22/16 10:55 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper 0.309 1.3 mg/L 0.0010 1 28933-50 07/25/16 16:09

Lead 0.0035 0.02 mg/L 0.0002 1 28933-50 07/25/16 16:09

Sample: 109-A-6 Collected: 07/22/16 05:22 Temp: 23 C Matrix: Drinking Water
Lab ID: 115115 Received: 07/22/16 10:55 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper 0.362 1.3 mg/L 0.0010 1 28933-51 07/25/16 16:11

Lead 0.0030 0.02 mg/L 0.0002 1 28933-51 07/25/16 16:11

Sample: 109-A-7 Collected: 07/22/16 05:23 Temp: 23 C Matrix: Drinking Water
Lab ID: 115116 Received: 07/22/16 10:55 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper 0.349 1.3 mg/L 0.0010 1 28933-52 07/25/16 16:13

Lead 0.0019 0.02 mg/L 0.0002 1 28933-52 07/25/16 16:13

Sample: 112-A Collected: 07/22/16 05:54 Temp: 23 C Matrix: Drinking Water
Lab ID: 115117 Received: 07/22/16 10:55 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper 0.344 1.3 mg/L 0.0010 1 28933-53 07/25/16 16:15

Lead 0.0004 0.02 mg/L 0.0002 1 28933-53 07/25/16 16:15

Sample: 113-A Collected: 07/22/16 05:27 Temp: 23 C Matrix: Drinking Water
Lab ID: 115118 Received: 07/22/16 10:55 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper 0.238 1.3 mg/L 0.0010 1 28933-54 07/25/16 16:17

Lead 0.0007 0.02 mg/L 0.0002 1 28933-54 07/25/16 16:17

Sample: 119-C Collected: 07/22/16 05:25 Temp: 23 C Matrix: Drinking Water
Lab ID: 115119 Received: 07/22/16 10:55 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper 0.343 1.3 mg/L 0.0010 1 28933-55 07/25/16 16:19

Lead 0.0019 0.02 mg/L 0.0002 1 28933-55 07/25/16 16:19

Sample: 119-D Collected: 07/22/16 05:26 Temp: 23 C Matrix: Drinking Water
Lab ID: 115120 Received: 07/22/16 10:55 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.351	1.3	mg/L	0.0010	1	28933-56		07/25/16 16:21	
Lead	0.0026	0.02	mg/L	0.0002	1	28933-56		07/25/16 16:21	

Sample: 140-A	Collected: 07/22/16 05:28	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115121	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.319	1.3	mg/L	0.0010	1	28933-57		07/25/16 16:24	
Lead	0.0042	0.02	mg/L	0.0002	1	28933-57		07/25/16 16:24	

Sample: 141-A	Collected: 07/22/16 05:29	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115122	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.262	1.3	mg/L	0.0010	1	28933-58		07/25/16 16:26	
Lead	0.0015	0.02	mg/L	0.0002	1	28933-58		07/25/16 16:26	

Sample: 143-A	Collected: 07/22/16 05:30	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115123	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.139	1.3	mg/L	0.0010	1	28933-63		07/25/16 16:37	
Lead	0.0011	0.02	mg/L	0.0002	1	28933-63		07/25/16 16:37	

Sample: 149-A	Collected: 07/22/16 05:40	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115124	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.437	1.3	mg/L	0.0010	1	28933-64		07/25/16 16:39	
Lead	0.0092	0.02	mg/L	0.0002	1	28933-64		07/25/16 16:39	

Sample: 155-A-1	Collected: 07/22/16 05:41	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115125	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.321	1.3	mg/L	0.0010	1	28933-65		07/25/16 16:41	
Lead	0.0020	0.02	mg/L	0.0002	1	28933-65		07/25/16 16:41	

Sample: 155-A-2	Collected: 07/22/16 05:42	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115126	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.278	1.3	mg/L	0.0010	1	28933-66		07/25/16 16:43	
Lead	0.0022	0.02	mg/L	0.0002	1	28933-66		07/25/16 16:43	

Sample: 155-A-3	Collected: 07/22/16 05:43	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115127	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.247	1.3	mg/L	0.0010	1	28933-67		07/25/16 16:45	
Lead	0.0018	0.02	mg/L	0.0002	1	28933-67		07/25/16 16:45	

Sample: 155-A-4	Collected: 07/22/16 05:44	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115128	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									

Copper	0.484	1.3	mg/L	0.0010	1	28933-68		07/25/16 16:47	
Lead	0.0058	0.02	mg/L	0.0002	1	28933-68		07/25/16 16:47	

Sample: 163-A-1	Collected: 07/22/16 05:45	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115129	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.327	1.3	mg/L	0.0010	1	28933-69		07/25/16 16:50	
Lead	0.0034	0.02	mg/L	0.0002	1	28933-69		07/25/16 16:50	

Sample: 163-A-2	Collected: 07/22/16 05:46	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115130	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.351	1.3	mg/L	0.0010	1	28933-70		07/25/16 16:52	
Lead	0.0033	0.02	mg/L	0.0002	1	28933-70		07/25/16 16:52	

Sample: 163-A-3	Collected: 07/22/16 05:47	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115131	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.418	1.3	mg/L	0.0010	1	28933-71		07/25/16 16:54	
Lead	0.0134	0.02	mg/L	0.0002	1	28933-71		07/25/16 16:54	

Sample: 163-A-4	Collected: 07/22/16 05:48	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115132	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.281	1.3	mg/L	0.0010	1	28933-72		07/25/16 16:56	
Lead	0.0031	0.02	mg/L	0.0002	1	28933-72		07/25/16 16:56	

Sample: 164-A	Collected: 07/22/16 05:49	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115133	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.378	1.3	mg/L	0.0010	1	28933-77		07/25/16 17:09	
Lead	0.0054	0.02	mg/L	0.0002	1	28933-77		07/25/16 17:09	

Sample: 165-A	Collected: 07/22/16 05:50	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115134	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.253	1.3	mg/L	0.0010	1	28933-78		07/25/16 17:11	
Lead	0.0040	0.02	mg/L	0.0002	1	28933-78		07/25/16 17:11	

Sample: 166-A	Collected: 07/22/16 05:51	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115135	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.320	1.3	mg/L	0.0010	1	28933-79		07/25/16 17:13	
Lead	0.0044	0.02	mg/L	0.0002	1	28933-79		07/25/16 17:13	

Sample: 167-A	Collected: 07/22/16 05:52	Temp: 23 C	Matrix: Drinking Water
Lab ID: 115136	Received: 07/22/16 10:55	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.322	1.3	mg/L	0.0010	1	28933-80		07/25/16 17:15	
Lead	0.0027	0.02	mg/L	0.0002	1	28933-80		07/25/16 17:15	
Sample: 168-A		Collected: 07/22/16 05:53			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115137		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.330	1.3	mg/L	0.0010	1	28933-81		07/25/16 17:18	
Lead	0.0028	0.02	mg/L	0.0002	1	28933-81		07/25/16 17:18	
Sample: 171-A-1		Collected: 07/22/16 05:54			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115138		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.437	1.3	mg/L	0.0010	1	28933-82		07/25/16 17:20	
Lead	0.0255	0.02	mg/L	0.0002	1	28933-82		07/25/16 17:20	
Sample: 171-A-2		Collected: 07/22/16 05:55			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115139		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.438	1.3	mg/L	0.0010	1	28933-83		07/25/16 17:22	
Lead	0.0048	0.02	mg/L	0.0002	1	28933-83		07/25/16 17:22	
Sample: 171-A-3		Collected: 07/22/16 05:56			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115140		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.382	1.3	mg/L	0.0010	1	28933-84		07/25/16 17:24	
Lead	0.0050	0.02	mg/L	0.0002	1	28933-84		07/25/16 17:24	
Sample: 171-A-4		Collected: 07/22/16 05:57			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115141		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.424	1.3	mg/L	0.0010	1	28933-85		07/25/16 17:26	
Lead	0.0076	0.02	mg/L	0.0002	1	28933-85		07/25/16 17:26	
Sample: 171-A-5		Collected: 07/22/16 05:58			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115142		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.408	1.3	mg/L	0.0010	1	28933-86		07/25/16 17:28	
Lead	0.0103	0.02	mg/L	0.0002	1	28933-86		07/25/16 17:28	
Sample: 171-A-6		Collected: 07/22/16 05:59			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115143		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.370	1.3	mg/L	0.0010	1	28933-91		07/25/16 17:39	
Lead	0.0051	0.02	mg/L	0.0002	1	28933-91		07/25/16 17:39	
Sample: 171-A-7		Collected: 07/22/16 06:00			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115144		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes

Method: EPA 200.8									
Copper	0.358	1.3	mg/L	0.0010	1	28933-92			07/25/16 17:41
Lead	0.0056	0.02	mg/L	0.0002	1	28933-92			07/25/16 17:41
Sample: 172-A		Collected: 07/22/16 06:01			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115145		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.393	1.3	mg/L	0.0010	1	28933-93			07/25/16 17:43
Lead	0.0079	0.02	mg/L	0.0002	1	28933-93			07/25/16 17:43
Sample: 173-A-1		Collected: 07/22/16 06:02			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115146		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.379	1.3	mg/L	0.0010	1	28933-94			07/25/16 17:46
Lead	0.0080	0.02	mg/L	0.0002	1	28933-94			07/25/16 17:46
Sample: 173-A-2		Collected: 07/22/16 06:03			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115147		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.336	1.3	mg/L	0.0010	1	28933-95			07/25/16 17:48
Lead	0.0030	0.02	mg/L	0.0002	1	28933-95			07/25/16 17:48
Sample: 173-A-3		Collected: 07/22/16 06:04			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115148		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.322	1.3	mg/L	0.0010	1	28933-96			07/25/16 17:50
Lead	0.0050	0.02	mg/L	0.0002	1	28933-96			07/25/16 17:50
Sample: 173-A-4		Collected: 07/22/16 06:05			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115149		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.427	1.3	mg/L	0.0010	1	28933-97			07/25/16 17:52
Lead	0.0128	0.02	mg/L	0.0002	1	28933-97			07/25/16 17:52
Sample: 173-A-5		Collected: 07/22/16 06:06			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115150		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.381	1.3	mg/L	0.0010	1	28933-98			07/25/16 17:54
Lead	0.0068	0.02	mg/L	0.0002	1	28933-98			07/25/16 17:54
Sample: 173-A-6		Collected: 07/22/16 06:07			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115151		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.364	1.3	mg/L	0.0010	1	28933-99			07/25/16 17:57
Lead	0.0044	0.02	mg/L	0.0002	1	28933-99			07/25/16 17:57
Sample: 176-A		Collected: 07/22/16 06:10			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115152		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes

Method: EPA 200.8									
Copper	0.334	1.3	mg/L	0.0010	1	28933-100			07/25/16 17:59
Lead	0.0036	0.02	mg/L	0.0002	1	28933-100			07/25/16 17:59
Sample: 177-A		Collected: 07/22/16 06:11			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115153		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.335	1.3	mg/L	0.0010	1	28933-105			07/25/16 18:10
Lead	0.0035	0.02	mg/L	0.0002	1	28933-105			07/25/16 18:10
Sample: 178-A		Collected: 07/22/16 06:12			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115154		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.376	1.3	mg/L	0.0010	1	28933-106			07/25/16 18:12
Lead	0.0053	0.02	mg/L	0.0002	1	28933-106			07/25/16 18:12
Sample: 179-A		Collected: 07/22/16 06:13			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115155		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.278	1.3	mg/L	0.0010	1	28933-107			07/25/16 18:14
Lead	0.0048	0.02	mg/L	0.0002	1	28933-107			07/25/16 18:14
Sample: 180-A		Collected: 07/22/16 06:14			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115156		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.283	1.3	mg/L	0.0010	1	28933-108			07/25/16 18:16
Lead	0.0070	0.02	mg/L	0.0002	1	28933-108			07/25/16 18:16
Sample: 181-A-1		Collected: 07/22/16 06:17			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115157		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.346	1.3	mg/L	0.0010	1	28933-109			07/25/16 18:18
Lead	0.0045	0.02	mg/L	0.0002	1	28933-109			07/25/16 18:18
Sample: 181-A-2		Collected: 07/22/16 06:18			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115158		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.433	1.3	mg/L	0.0010	1	28933-110			07/25/16 18:20
Lead	0.0053	0.02	mg/L	0.0002	1	28933-110			07/25/16 18:20
Sample: 181-A-3		Collected: 07/22/16 06:19			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115159		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.363	1.3	mg/L	0.0010	1	28933-111			07/25/16 18:22
Lead	0.0034	0.02	mg/L	0.0002	1	28933-111			07/25/16 18:22
Sample: 181-A-4		Collected: 07/22/16 06:20			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115160		Received: 07/22/16 10:55			Evidence of Cooling:N				

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.550	1.3	mg/L	0.0010	1	28933-112		07/25/16 18:25	
Lead	0.0106	0.02	mg/L	0.0002	1	28933-112		07/25/16 18:25	
Sample: 182-A-1		Collected: 07/22/16 06:21			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115161		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.372	1.3	mg/L	0.0010	1	28933-113		07/25/16 18:27	
Lead	0.0045	0.02	mg/L	0.0002	1	28933-113		07/25/16 18:27	
Sample: 182-A-2		Collected: 07/22/16 06:22			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115162		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.276	1.3	mg/L	0.0010	1	28933-114		07/25/16 18:29	
Lead	0.0028	0.02	mg/L	0.0002	1	28933-114		07/25/16 18:29	
Sample: 182-A-3		Collected: 07/22/16 06:23			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115163		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.266	1.3	mg/L	0.0010	1	28933-119		07/25/16 18:40	
Lead	0.0041	0.02	mg/L	0.0002	1	28933-119		07/25/16 18:40	
Sample: 182-A-4		Collected: 07/22/16 06:24			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115164		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.326	1.3	mg/L	0.0010	1	28933-120		07/25/16 18:42	
Lead	0.0064	0.02	mg/L	0.0002	1	28933-120		07/25/16 18:42	
Sample: 187-C		Collected: 07/22/16 06:15			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115165		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.333	1.3	mg/L	0.0010	1	28933-121		07/25/16 18:44	
Lead	0.0011	0.02	mg/L	0.0002	1	28933-121		07/25/16 18:44	
Sample: 187-D		Collected: 07/22/16 06:16			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115166		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.153	1.3	mg/L	0.0010	1	28933-122		07/25/16 18:47	
Lead	ND	0.02	mg/L	0.0002	1	28933-122		07/25/16 18:47	
Sample: 191-A		Collected: 07/22/16 06:30			Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115167		Received: 07/22/16 10:55			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.388	1.3	mg/L	0.0010	1	28933-123		07/25/16 18:49	
Lead	0.0150	0.02	mg/L	0.0002	1	28933-123		07/25/16 18:49	
Sample: 192-A		Collected: 07/22/16 06:31			Temp: 23 C		Matrix: Drinking Water		

Lab ID: 115168		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.399	1.3	mg/L	0.0010	1	28933-124		07/25/16 18:51	
Lead	0.0076	0.02	mg/L	0.0002	1	28933-124		07/25/16 18:51	
Sample: 195-C		Collected: 07/22/16 05:41				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115169		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.225	1.3	mg/L	0.0010	1	28933-125		07/25/16 18:53	
Lead	0.0005	0.02	mg/L	0.0002	1	28933-125		07/25/16 18:53	
Sample: 195-D		Collected: 07/22/16 05:42				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115170		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0936	1.3	mg/L	0.0010	1	28933-126		07/25/16 18:55	
Lead	ND	0.02	mg/L	0.0002	1	28933-126		07/25/16 18:55	
Sample: 206-A-1		Collected: 07/22/16 06:36				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115171		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.455	1.3	mg/L	0.0010	1	28933-127		07/25/16 18:58	
Lead	0.0037	0.02	mg/L	0.0002	1	28933-127		07/25/16 18:58	
Sample: 206-A-2		Collected: 07/22/16 06:37				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115172		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.286	1.3	mg/L	0.0010	1	28933-128		07/25/16 19:00	
Lead	0.0026	0.02	mg/L	0.0002	1	28933-128		07/25/16 19:00	
Sample: 206-A-3		Collected: 07/22/16 06:38				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115173		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.264	1.3	mg/L	0.0010	1	28933-133		07/25/16 19:13	
Lead	0.0020	0.02	mg/L	0.0002	1	28933-133		07/25/16 19:13	
Sample: 206-A-4		Collected: 07/22/16 06:39				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115174		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.538	1.3	mg/L	0.0010	1	28933-134		07/25/16 19:15	
Lead	0.0035	0.02	mg/L	0.0002	1	28933-134		07/25/16 19:15	
Sample: 207-A-1		Collected: 07/22/16 06:40				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115175		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.334	1.3	mg/L	0.0010	1	28933-135		07/25/16 19:17	
Lead	0.0025	0.02	mg/L	0.0002	1	28933-135		07/25/16 19:17	

Sample: 207-A-2 Lab ID: 115176		Collected: 07/22/16 06:41 Received: 07/22/16 10:55				Temp: 23 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.304	1.3	mg/L	0.0010	1	28933-195		07/25/16 19:20	
Lead	0.0034	0.02	mg/L	0.0002	1	28933-195		07/25/16 19:20	
Sample: 207-A-3 Lab ID: 115177		Collected: 07/22/16 06:42 Received: 07/22/16 10:55				Temp: 23 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.302	1.3	mg/L	0.0020	5	28963-76	07/26/16 09:10	07/27/16 16:42	
Lead	0.0210	0.02	mg/L	0.0004	5	28963-76	07/26/16 09:10	07/27/16 16:42	
Sample: 207-A-4 Lab ID: 115178		Collected: 07/22/16 06:43 Received: 07/22/16 10:55				Temp: 23 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.226	1.3	mg/L	0.0010	1	28933-136		07/25/16 19:22	
Lead	0.0024	0.02	mg/L	0.0002	1	28933-136		07/25/16 19:22	
Sample: 214-A Lab ID: 115179		Collected: 07/22/16 06:44 Received: 07/22/16 10:55				Temp: 23 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.324	1.3	mg/L	0.0010	1	28933-137		07/25/16 19:24	
Lead	0.0070	0.02	mg/L	0.0002	1	28933-137		07/25/16 19:24	
Sample: 215-A Lab ID: 115180		Collected: 07/22/16 06:45 Received: 07/22/16 10:55				Temp: 23 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.333	1.3	mg/L	0.0010	1	28933-138		07/25/16 19:26	
Lead	0.0069	0.02	mg/L	0.0002	1	28933-138		07/25/16 19:26	
Sample: 217-A Lab ID: 115181		Collected: 07/22/16 06:46 Received: 07/22/16 10:55				Temp: 23 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.323	1.3	mg/L	0.0010	1	28933-139		07/25/16 19:29	
Lead	0.0026	0.02	mg/L	0.0002	1	28933-139		07/25/16 19:29	
Sample: 218-A Lab ID: 115182		Collected: 07/22/16 06:47 Received: 07/22/16 10:55				Temp: 23 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.374	1.3	mg/L	0.0010	1	28933-140		07/25/16 19:31	
Lead	0.0035	0.02	mg/L	0.0002	1	28933-140		07/25/16 19:31	
Sample: 220-A Lab ID: 115183		Collected: 07/22/16 07:18 Received: 07/22/16 10:55				Temp: 23 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.353	1.3	mg/L	0.0010	1	28933-141		07/25/16 19:33	
Lead	0.0021	0.02	mg/L	0.0002	1	28933-141		07/25/16 19:33	

Sample: 222-A-1		Collected: 07/22/16 07:20				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115184		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.406	1.3	mg/L	0.0010	1	28933-146		07/25/16 19:44	
Lead	0.0111	0.02	mg/L	0.0002	1	28933-146		07/25/16 19:44	
Sample: 222-A-2		Collected: 07/22/16 07:21				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115185		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.366	1.3	mg/L	0.0010	1	28933-147		07/25/16 19:47	
Lead	0.0063	0.02	mg/L	0.0002	1	28933-147		07/25/16 19:47	
Sample: 222-A-3		Collected: 07/22/16 07:22				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115186		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.347	1.3	mg/L	0.0010	1	28933-148		07/25/16 19:49	
Lead	0.0087	0.02	mg/L	0.0002	1	28933-148		07/25/16 19:49	
Sample: 222-A-4		Collected: 07/22/16 07:23				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115187		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.359	1.3	mg/L	0.0010	1	28933-149		07/25/16 19:51	
Lead	0.0084	0.02	mg/L	0.0002	1	28933-149		07/25/16 19:51	
Sample: 222-A-5		Collected: 07/22/16 07:24				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115188		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.355	1.3	mg/L	0.0010	1	28933-150		07/25/16 19:53	
Lead	0.0062	0.02	mg/L	0.0002	1	28933-150		07/25/16 19:53	
Sample: 222-A-6		Collected: 07/22/16 07:25				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115189		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.338	1.3	mg/L	0.0010	1	28933-151		07/25/16 19:56	
Lead	0.0086	0.02	mg/L	0.0002	1	28933-151		07/25/16 19:56	
Sample: 222-A-7		Collected: 07/22/16 07:26				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115190		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.382	1.3	mg/L	0.0010	1	28933-152		07/25/16 19:58	
Lead	0.0177	0.02	mg/L	0.0002	1	28933-152		07/25/16 19:58	
Sample: 223-A		Collected: 07/22/16 07:16				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115191		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.373	1.3	mg/L	0.0010	1	28933-153		07/25/16 20:00	
Lead	0.0078	0.02	mg/L	0.0002	1	28933-153		07/25/16 20:00	

Sample: 223-D		Collected: 07/22/16 07:17				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115192		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.0784	1.3	mg/L	0.0010	1	28933-154		07/25/16 20:02		
Lead	0.0176	0.02	mg/L	0.0002	1	28933-154		07/25/16 20:02		
Sample: 224-A-1		Collected: 07/22/16 07:10				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115193		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.352	1.3	mg/L	0.0010	1	28933-155		07/25/16 20:04		
Lead	0.0058	0.02	mg/L	0.0002	1	28933-155		07/25/16 20:04		
Sample: 224-A-2		Collected: 07/22/16 07:11				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115194		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.402	1.3	mg/L	0.0010	1	28933-160		07/25/16 20:15		
Lead	0.0017	0.02	mg/L	0.0002	1	28933-160		07/25/16 20:15		
Sample: 224-A-3		Collected: 07/22/16 07:12				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115195		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.295	1.3	mg/L	0.0010	1	28933-161		07/25/16 20:18		
Lead	0.0060	0.02	mg/L	0.0002	1	28933-161		07/25/16 20:18		
Sample: 224-A-4		Collected: 07/22/16 07:13				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115196		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.322	1.3	mg/L	0.0010	1	28933-162		07/25/16 20:20		
Lead	0.0071	0.02	mg/L	0.0002	1	28933-162		07/25/16 20:20		
Sample: 224-A-5		Collected: 07/22/16 07:14				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115197		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.412	1.3	mg/L	0.0010	1	28933-163		07/25/16 20:22		
Lead	0.0129	0.02	mg/L	0.0002	1	28933-163		07/25/16 20:22		
Sample: 224-A-6		Collected: 07/22/16 07:15				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115198		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.391	1.3	mg/L	0.0010	1	28933-164		07/25/16 20:24		
Lead	0.0094	0.02	mg/L	0.0002	1	28933-164		07/25/16 20:24		
Sample: 227-A		Collected: 07/22/16 06:50				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115199		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.316	1.3	mg/L	0.0010	1	28933-165		07/25/16 20:27		
Lead	0.0020	0.02	mg/L	0.0002	1	28933-165		07/25/16 20:27		

Sample: 228-A		Collected: 07/22/16 06:51				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115200		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.419	1.3	mg/L	0.0010	1	28933-166		07/25/16 20:29	
Lead	0.0032	0.02	mg/L	0.0002	1	28933-166		07/25/16 20:29	
Sample: 229-A		Collected: 07/22/16 06:52				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115201		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.233	1.3	mg/L	0.0010	1	28933-167		07/25/16 20:31	
Lead	0.0034	0.02	mg/L	0.0002	1	28933-167		07/25/16 20:31	
Sample: 230-A		Collected: 07/22/16 06:53				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115202		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.326	1.3	mg/L	0.0010	1	28933-168		07/25/16 20:33	
Lead	0.0038	0.02	mg/L	0.0002	1	28933-168		07/25/16 20:33	
Sample: 231-A		Collected: 07/22/16 06:54				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115203		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.331	1.3	mg/L	0.0010	1	28933-169		07/25/16 20:36	
Lead	0.0083	0.02	mg/L	0.0002	1	28933-169		07/25/16 20:36	
Sample: 232-A-1		Collected: 07/22/16 06:55				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115204		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.298	1.3	mg/L	0.0010	1	28933-174		07/25/16 20:47	
Lead	0.0025	0.02	mg/L	0.0002	1	28933-174		07/25/16 20:47	
Sample: 232-A-2		Collected: 07/22/16 06:56				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115205		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.220	1.3	mg/L	0.0010	1	28933-175		07/25/16 20:49	
Lead	0.0029	0.02	mg/L	0.0002	1	28933-175		07/25/16 20:49	
Sample: 232-A-3		Collected: 07/22/16 06:57				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115206		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.219	1.3	mg/L	0.0010	1	28933-176		07/25/16 20:51	
Lead	0.0034	0.02	mg/L	0.0002	1	28933-176		07/25/16 20:51	
Sample: 232-A-4		Collected: 07/22/16 06:58				Temp: 23 C		Matrix: Drinking Water	
Lab ID: 115207		Received: 07/22/16 10:55				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.278	1.3	mg/L	0.0010	1	28933-177		07/25/16 20:54	
Lead	0.0060	0.02	mg/L	0.0002	1	28933-177		07/25/16 20:54	

Sample: 233-A-1		Collected: 07/22/16 07:03				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115208		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.264	1.3	mg/L	0.0010	1	28933-178		07/25/16 20:56		
Lead	0.0032	0.02	mg/L	0.0002	1	28933-178		07/25/16 20:56		
Sample: 233-A-2		Collected: 07/22/16 07:04				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115209		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.182	1.3	mg/L	0.0010	1	28933-179		07/25/16 20:58		
Lead	0.0031	0.02	mg/L	0.0002	1	28933-179		07/25/16 20:58		
Sample: 233-A-3		Collected: 07/22/16 07:05				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115210		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.244	1.3	mg/L	0.0010	1	28933-180		07/25/16 21:01		
Lead	0.0090	0.02	mg/L	0.0002	1	28933-180		07/25/16 21:01		
Sample: 233-A-4		Collected: 07/22/16 07:06				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115211		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.312	1.3	mg/L	0.0010	1	28933-181		07/25/16 21:03		
Lead	0.0175	0.02	mg/L	0.0002	1	28933-181		07/25/16 21:03		
Sample: 238-C		Collected: 07/22/16 06:59				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115212		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.399	1.3	mg/L	0.0010	1	28933-182		07/25/16 21:05		
Lead	0.0008	0.02	mg/L	0.0002	1	28933-182		07/25/16 21:05		
Sample: 244-A-1		Collected: 07/22/16 07:00				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115213		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.363	1.3	mg/L	0.0010	1	28933-183		07/25/16 21:07		
Lead	0.0020	0.02	mg/L	0.0002	1	28933-183		07/25/16 21:07		
Sample: 244-A-2		Collected: 07/22/16 07:01				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115214		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.352	1.3	mg/L	0.0010	1	28933-188		07/25/16 21:21		
Lead	0.0031	0.02	mg/L	0.0002	1	28933-188		07/25/16 21:21		
Sample: 244-A-3		Collected: 07/22/16 07:02				Temp: 23 C		Matrix: Drinking Water		
Lab ID: 115215		Received: 07/22/16 10:55				Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes	
Method: EPA 200.8										
Copper	0.378	1.3	mg/L	0.0010	1	28933-189		07/25/16 21:23		

Lead 0.0039 0.02 mg/L 0.0002 1 28933-189 07/25/16 21:23

Sample: 246-C Collected: 07/22/16 07:03 Temp: 23 C Matrix: Drinking Water
Lab ID: 115216 Received: 07/22/16 10:55 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.447	1.3	mg/L	0.0010	1	28933-190		07/25/16 21:26	
--------	-------	-----	------	--------	---	-----------	--	----------------	--

Lead	0.0014	0.02	mg/L	0.0002	1	28933-190		07/25/16 21:26	
------	--------	------	------	--------	---	-----------	--	----------------	--

Abbreviations

MRL Method Reporting Limit

ND None Detected at or above the MRL

Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

Units of Measure:

mg/L Milligrams Per Liter

Chain of Custody Record-Water Samples
006 - Athey Creek Middle School: 2900 SE Borland Rd., Tualatin, OR 97062

Location/Site	Date Collected	Collector's Name	Time	Date Delivered
103-C	7/22/2016	Steve Matthias	5:12 AM	7/22/2016
104-A	7/22/2016	Steve Matthias	5:13 AM	7/22/2016
105-A	7/22/2016	Steve Matthias	5:14 AM	7/22/2016
107-A	7/22/2016	Steve Matthias	5:15 AM	7/22/2016
107-C		No sample-leaking		
109-A-1	7/22/2016	Steve Matthias	5:17 AM	7/22/2016
109-A-2	7/22/2016	Steve Matthias	5:18 AM	7/22/2016
109-A-3	7/22/2016	Steve Matthias	5:19 AM	7/22/2016
109-A-4	7/22/2016	Steve Matthias	5:20 AM	7/22/2016
109-A-5	7/22/2016	Steve Matthias	5:21 AM	7/22/2016
109-A-6	7/22/2016	Steve Matthias	5:22 AM	7/22/2016
109-A-7	7/22/2016	Steve Matthias	5:23 AM	7/22/2016
112-A	7/22/2016	Steve Matthias	5:54 AM	7/22/2016
113-A	7/22/2016	Steve Matthias	5:27 AM	7/22/2016
119-C	7/22/2016	Steve Matthias	5:25 AM	7/22/2016
119-D	7/22/2016	Steve Matthias	5:26 AM	7/22/2016
140-A	7/22/2016	Steve Matthias	5:28 AM	7/22/2016
141-A	7/22/2016	Steve Matthias	5:29 AM	7/22/2016
143-A	7/22/2016	Steve Matthias	5:30 AM	7/22/2016
149-A	7/22/2016	Steve Matthias	5:40 AM	7/22/2016
155-A-1	7/22/2016	Steve Matthias	5:41 AM	7/22/2016
155-A-2	7/22/2016	Steve Matthias	5:42 AM	7/22/2016
155-A-3	7/22/2016	Steve Matthias	5:43 AM	7/22/2016
155-A-4	7/22/2016	Steve Matthias	5:44 AM	7/22/2016
163-A-1	7/22/2016	Steve Matthias	5:45 AM	7/22/2016
163-A-2	7/22/2016	Steve Matthias	5:46 AM	7/22/2016
163-A-3	7/22/2016	Steve Matthias	5:47 AM	7/22/2016
163-A-4	7/22/2016	Steve Matthias	5:48 AM	7/22/2016
164-A	7/22/2016	Steve Matthias	5:49 AM	7/22/2016
165-A	7/22/2016	Steve Matthias	5:50 AM	7/22/2016
166-A	7/22/2016	Steve Matthias	5:51 AM	7/22/2016
167-A	7/22/2016	Steve Matthias	5:52 AM	7/22/2016
168-A	7/22/2016	Steve Matthias	5:53 AM	7/22/2016
171-A-1	7/22/2016	Steve Matthias	5:54 AM	7/22/2016
171-A-2	7/22/2016	Steve Matthias	5:55 AM	7/22/2016

WESTMIN SC
 7/22/2016
 Page 1 of 4

No 22.60
 Cooling

Stephen Matthias 7-22-16
 Collector's Signature Date

mea 7-22-16 1055 am
 Laboratory Signature Date

Chain of Custody Record-Water Samples
006 - Athey Creek Middle School: 2900 SE Borland Rd., Tualatin, OR 97062

171-A-3	7/22/2016	Steve Matthias	5:56 AM	7/22/2016
171-A-4	7/22/2016	Steve Matthias	5:57 AM	7/22/2016
171-A-5	7/22/2016	Steve Matthias	5:58 AM	7/22/2016
171-A-6	7/22/2016	Steve Matthias	5:59 AM	7/22/2016
171-A-7	7/22/2016	Steve Matthias	6:00 AM	7/22/2016
172-A	7/22/2016	Steve Matthias	6:01 AM	7/22/2016
173-A-1	7/22/2016	Steve Matthias	6:02 AM	7/22/2016
173-A-2	7/22/2016	Steve Matthias	6:03 AM	7/22/2016
173-A-3	7/22/2016	Steve Matthias	6:04 AM	7/22/2016
173-A-4	7/22/2016	Steve Matthias	6:05 AM	7/22/2016
173-A-5	7/22/2016	Steve Matthias	6:06 AM	7/22/2016
173-A-6	7/22/2016	Steve Matthias	6:07 AM	7/22/2016
173-A-7		No sample-leaking		
176-A	7/22/2016	Steve Matthias	6:10 AM	7/22/2016
177-A	7/22/2016	Steve Matthias	6:11 AM	7/22/2016
178-A	7/22/2016	Steve Matthias	6:12 AM	7/22/2016
179-A	7/22/2016	Steve Matthias	6:13 AM	7/22/2016
180-A	7/22/2016	Steve Matthias	6:14 AM	7/22/2016
181-A-1	7/22/2016	Steve Matthias	6:17 AM	7/22/2016
181-A-2	7/22/2016	Steve Matthias	6:18 AM	7/22/2016
181-A-3	7/22/2016	Steve Matthias	6:19 AM	7/22/2016
181-A-4	7/22/2016	Steve Matthias	6:20 AM	7/22/2016
182-A-1	7/22/2016	Steve Matthias	6:21 AM	7/22/2016
182-A-2	7/22/2016	Steve Matthias	6:22 AM	7/22/2016
182-A-3	7/22/2016	Steve Matthias	6:23 AM	7/22/2016
182-A-4	7/22/2016	Steve Matthias	6:24 AM	7/22/2016
187-C	7/22/2016	Steve Matthias	6:15 AM	7/22/2016
187-D	7/22/2016	Steve Matthias	6:16 AM	7/22/2016
191-A	7/22/2016	Steve Matthias	6:30 AM	7/22/2016
192-A	7/22/2016	Steve Matthias	6:31 AM	7/22/2016
195-C	7/22/2016	Steve Matthias	5:41 AM	7/22/2016
195-D	7/22/2016	Steve Matthias	5:42 AM	7/22/2016
206-A-1	7/22/2016	Steve Matthias	6:36 AM	7/22/2016
206-A-2	7/22/2016	Steve Matthias	6:37 AM	7/22/2016
206-A-3	7/22/2016	Steve Matthias	6:38 AM	7/22/2016
206-A-4	7/22/2016	Steve Matthias	6:39 AM	7/22/2016

0672220
Page 2 of 4

Steve Matthias 7-22-16
 Collector's Signature Date

mea 7-22-16 1055am
 Laboratory Signature Date

Chain of Custody Record-Water Samples
006 - Athey Creek Middle School: 2900 SE Borland Rd., Tualatin, OR 97062

207-A-1	7/22/2016	Steve Matthias	6:40 AM	7/22/2016
207-A-2	7/22/2016	Steve Matthias	6:41 AM	7/22/2016
207-A-3	7/22/2016	Steve Matthias	6:42 AM	7/22/2016
207-A-4	7/22/2016	Steve Matthias	6:43 AM	7/22/2016
214-A	7/22/2016	Steve Matthias	6:44 AM	7/22/2016
215-A	7/22/2016	Steve Matthias	6:45 AM	7/22/2016
216-A		No sample-leaking		
217-A	7/22/2016	Steve Matthias	6:46 AM	7/22/2016
218-A	7/22/2016	Steve Matthias	6:47 AM	7/22/2016
220-A	7/22/2016	Steve Matthias	7:18 AM	7/22/2016
222-A-1	7/22/2016	Steve Matthias	7:20 AM	7/22/2016
222-A-2	7/22/2016	Steve Matthias	7:21 AM	7/22/2016
222-A-3	7/22/2016	Steve Matthias	7:22 AM	7/22/2016
222-A-4	7/22/2016	Steve Matthias	7:23 AM	7/22/2016
222-A-5	7/22/2016	Steve Matthias	7:24 AM	7/22/2016
222-A-6	7/22/2016	Steve Matthias	7:25 AM	7/22/2016
222-A-7	7/22/2016	Steve Matthias	7:26 AM	7/22/2016
223-A	7/22/2016	Steve Matthias	7:16 AM	7/22/2016
223-D	7/22/2016	Steve Matthias	7:17 AM	7/22/2016
224-A-1	7/22/2016	Steve Matthias	7:10 AM	7/22/2016
224-A-2	7/22/2016	Steve Matthias	7:11 AM	7/22/2016
224-A-3	7/22/2016	Steve Matthias	7:12 AM	7/22/2016
224-A-4	7/22/2016	Steve Matthias	7:13 AM	7/22/2016
224-A-5	7/22/2016	Steve Matthias	7:14 AM	7/22/2016
224-A-6	7/22/2016	Steve Matthias	7:15 AM	7/22/2016
227-A	7/22/2016	Steve Matthias	6:50 AM	7/22/2016
228-A	7/22/2016	Steve Matthias	6:51 AM	7/22/2016
229-A	7/22/2016	Steve Matthias	6:52 AM	7/22/2016
230-A	7/22/2016	Steve Matthias	6:53 AM	7/22/2016
231-A	7/22/2016	Steve Matthias	6:54 AM	7/22/2016
232-A-1	7/22/2016	Steve Matthias	6:55 AM	7/22/2016
232-A-2	7/22/2016	Steve Matthias	6:56 AM	7/22/2016
232-A-3	7/22/2016	Steve Matthias	6:57 AM	7/22/2016
232-A-4	7/22/2016	Steve Matthias	6:58 AM	7/22/2016
233-A-1	7/22/2016	Steve Matthias	7:03 AM	7/22/2016
233-A-2	7/22/2016	Steve Matthias	7:04 AM	7/22/2016

072220
page 3 of 4

Steve Matthias 7-22-16
 Collector's Signature Date

Meow 7-22-16 1055 am
 Laboratory Signature Date

Chain of Custody Record-Water Samples
006 - Athey Creek Middle School: 2900 SE Borland Rd., Tualatin, OR 97062

233-A-3	7/22/2016	Steve Matthias	7:05 AM	7/22/2016
233-A-4	7/22/2016	Steve Matthias	7:06 AM	7/22/2016
238-C	7/22/2016	Steve Matthias	6:59 AM	7/22/2016
244-A-1	7/22/2016	Steve Matthias	7:00 AM	7/22/2016
244-A-2	7/22/2016	Steve Matthias	7:01 AM	7/22/2016
244-A-3	7/22/2016	Steve Matthias	7:02 AM	7/22/2016
246-C	7/22/2016	Steve Matthias	7:03 AM	7/22/2016

H 70 H 2622
 page 4 of 4
 0222200

 7-22-16
 Collector's Signature Date

mend 7-22-16 10:55 am
 Laboratory Signature Date