



## WEST LINN - WILSONVILLE SCHOOL DISTRICT

### Water Quality Information

August 4, 2016

Dear Athey Creek Families,

As you know, the West Linn-Wilsonville School District is testing the water in all schools this summer. As each school's lab results are made available to the District, they are being shared with families in that school.

The results from July testing at Athey Creek Middle School show that out of 111 test locations, two indicated elevated levels of lead that exceed the action level of 20 parts per billion. This includes a lab sink in a science classroom and a sink faucet in a restroom.

Immediate remediation steps taken include turning water off at these locations, replacing subject fixtures and retesting. These results will be sent out to you once all remediation steps are complete. The remediation and retesting will occur before children return to school this fall.

More information about District water quality testing is available at <http://www.wlww.k12.or.us/Page/10603>.

West Linn-Wilsonville School District  
Department of Operations  
Tim K. Woodley, Director

22210 SW Stafford Road Tualatin OR 97062  
Business: 503.673.7000 Fax: 503.673.7001

www.wlww.k12.or.us