

# WLWSD QUARTERLY SAFETY INSPECTIONS

## ISSUE LOG

DATE: Feb. 9

FACILITY: Bolton

Page: \_\_\_\_\_

Number	Location	Issue Code	Notes	W.O.
	113	C-4	Extension cord to surge protector	
	115	C-4	Extension cord under rug	
	119		Surge protector under rug	
	120		Surge protector under rug	
	122		Surge protector connected to extension cord and under carpet	
	123		Surge protector under rug	
	Staff room		Surge protector "daisy chained"	
	160		Cord under rug	
	159		Cord under rug	
	A-101		Cord under rug	
	A-102		Computer cart blocking doorway	
			Cord under rug	
	155		Cord under rug	
	154		Door to outside blocked	
			All doors must be clear for egress	
