

PIXIS Labs

Accurate. Reliable. On Time.

Pixis Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

Job Number: 6062821
Report Date: 07/18/2016
ORELAP #: OR100028
Project No: 002-Bolton Primary School

Cover Letter

Pat McGough
West Linn School District
2755 SW Borland
West Linn, OR 97068

Dear Pat McGough,

Enclosed please find Pixis Labs analytical report for samples received as order number 6062821 on 06/28/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed

Richard Reid

Project Manager

Sample Results

Sample: 107-A		Collected: 06/28/16 06:20		Temp: 27 C		Matrix: Drinking Water			
Lab ID: 111273		Received: 06/28/16 10:25		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.265	1.3	mg/L	0.0010	1	28797-134		07/12/16 16:02	
Lead	0.0017	0.02	mg/L	0.0002	1	28797-134		07/12/16 16:02	
Sample: A107-A		Collected: 06/28/16 06:23		Temp: 27 C		Matrix: Drinking Water			
Lab ID: 111274		Received: 06/28/16 10:25		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.132	1.3	mg/L	0.0010	1	28797-135		07/12/16 16:04	
Lead	0.0019	0.02	mg/L	0.0002	1	28797-135		07/12/16 16:04	
Sample: 110-A-1		Collected: 06/28/16 06:26		Temp: 27 C		Matrix: Drinking Water			
Lab ID: 111275		Received: 06/28/16 10:25		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.203	1.3	mg/L	0.0010	1	28797-136		07/12/16 16:06	
Lead	0.0013	0.02	mg/L	0.0002	1	28797-136		07/12/16 16:06	
Sample: 110-A-2		Collected: 06/28/16 06:30		Temp: 27 C		Matrix: Drinking Water			
Lab ID: 111276		Received: 06/28/16 10:25		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.280	1.3	mg/L	0.0010	1	28797-137		07/12/16 16:08	
Lead	0.0022	0.02	mg/L	0.0002	1	28797-137		07/12/16 16:08	
Sample: 110-B		Collected: 06/28/16 06:28		Temp: 27 C		Matrix: Drinking Water			
Lab ID: 111277		Received: 06/28/16 10:25		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.313	1.3	mg/L	0.0010	1	28797-138		07/12/16 16:10	
Lead	0.0008	0.02	mg/L	0.0002	1	28797-138		07/12/16 16:10	
Sample: 113-A		Collected: 06/28/16 06:33		Temp: 27 C		Matrix: Drinking Water			
Lab ID: 111278		Received: 06/28/16 10:25		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.215	1.3	mg/L	0.0010	1	28797-139		07/12/16 16:12	
Lead	0.0018	0.02	mg/L	0.0002	1	28797-139		07/12/16 16:12	
Sample: 113-B		Collected: 06/28/16 06:34		Temp: 27 C		Matrix: Drinking Water			
Lab ID: 111279		Received: 06/28/16 10:25		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.218	1.3	mg/L	0.0010	1	28797-140		07/12/16 16:14	

Lead ND 0.02 mg/L 0.0002 1 28797-140 07/12/16 16:14

Sample: 114-A Collected: 06/28/16 06:36 Temp: 27 C Matrix: Drinking Water
Lab ID: 111280 Received: 06/28/16 10:25 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.106	1.3	mg/L	0.0010	1	28797-141		07/12/16 16:16	
Lead	0.0008	0.02	mg/L	0.0002	1	28797-141		07/12/16 16:16	

Sample: 114-B Collected: 06/28/16 06:37 Temp: 27 C Matrix: Drinking Water
Lab ID: 111281 Received: 06/28/16 10:25 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0644	1.3	mg/L	0.0010	1	28797-142		07/12/16 16:19	
Lead	0.0004	0.02	mg/L	0.0002	1	28797-142		07/12/16 16:19	

Sample: 115-A Collected: 06/28/16 06:39 Temp: 27 C Matrix: Drinking Water
Lab ID: 111282 Received: 06/28/16 10:25 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.114	1.3	mg/L	0.0010	1	28797-143		07/12/16 16:21	
Lead	0.0015	0.02	mg/L	0.0002	1	28797-143		07/12/16 16:21	

Sample: 115-B Collected: 06/28/16 06:40 Temp: 27 C Matrix: Drinking Water
Lab ID: 111283 Received: 06/28/16 10:25 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0585	1.3	mg/L	0.0010	1	28838-7		07/18/16 11:28	
Lead	0.0005	0.02	mg/L	0.0002	1	28838-7		07/18/16 11:28	

Sample: 116-A Collected: 06/28/16 06:41 Temp: 27 C Matrix: Drinking Water
Lab ID: 111284 Received: 06/28/16 10:25 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.229	1.3	mg/L	0.0010	1	28838-8		07/18/16 11:30	
Lead	0.0015	0.02	mg/L	0.0002	1	28838-8		07/18/16 11:30	

Sample: 116-B Collected: 06/28/16 06:42 Temp: 27 C Matrix: Drinking Water
Lab ID: 111285 Received: 06/28/16 10:25 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.120	1.3	mg/L	0.0010	1	28838-9		07/18/16 11:32	
Lead	0.0011	0.02	mg/L	0.0002	1	28838-9		07/18/16 11:32	

Sample: 119-A Collected: 06/28/16 06:43 Temp: 27 C Matrix: Drinking Water
Lab ID: 111286 Received: 06/28/16 10:25 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.132	1.3	mg/L	0.0010	1	28838-10		07/18/16 11:33	
Lead	0.0015	0.02	mg/L	0.0002	1	28838-10		07/18/16 11:33	

Sample: 119-B Collected: 06/28/16 06:44 Temp: 27 C Matrix: Drinking Water
Lab ID: 111287 Received: 06/28/16 10:25 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									

Copper	0.0676	1.3	mg/L	0.0010	1	28838-11		07/18/16 11:35	
Lead	0.0006	0.02	mg/L	0.0002	1	28838-11		07/18/16 11:35	

Sample: 120-A	Collected: 06/28/16 06:45	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111288	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.148	1.3	mg/L	0.0010	1	28838-12		07/18/16 11:37	
Lead	0.0012	0.02	mg/L	0.0002	1	28838-12		07/18/16 11:37	

Sample: 120-B	Collected: 06/28/16 06:46	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111289	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0579	1.3	mg/L	0.0010	1	28769-104		07/11/16 17:42	
Lead	0.0005	0.02	mg/L	0.0002	1	28769-104		07/11/16 17:42	

Sample: 122-A	Collected: 06/28/16 06:53	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111290	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.124	1.3	mg/L	0.0010	1	28769-105		07/11/16 17:44	
Lead	0.0015	0.02	mg/L	0.0002	1	28769-105		07/11/16 17:44	

Sample: 122-B	Collected: 06/28/16 06:54	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111291	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0865	1.3	mg/L	0.0010	1	28769-106		07/11/16 17:46	
Lead	0.0008	0.02	mg/L	0.0002	1	28769-106		07/11/16 17:46	

Sample: A106-A	Collected: 06/28/16 06:57	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111292	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.122	1.3	mg/L	0.0010	1	28769-107		07/11/16 17:48	
Lead	0.0020	0.02	mg/L	0.0002	1	28769-107		07/11/16 17:48	

Sample: A106-B	Collected: 06/28/16 06:58	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111293	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0912	1.3	mg/L	0.0010	1	28769-108		07/11/16 17:50	
Lead	0.0013	0.02	mg/L	0.0002	1	28769-108		07/11/16 17:50	

Sample: 124-A-1	Collected: 06/28/16 06:59	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111294	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.168	1.3	mg/L	0.0010	1	28769-116		07/11/16 18:06	
Lead	0.0007	0.02	mg/L	0.0002	1	28769-116		07/11/16 18:06	

Sample: 124-A-2	Collected: 06/28/16 07:00	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111295	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									

Copper	0.203	1.3	mg/L	0.0010	1	28769-109	07/11/16 17:52
Lead	0.0012	0.02	mg/L	0.0002	1	28769-109	07/11/16 17:52

Sample: 127-A-1	Collected: 06/28/16 07:02	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111296	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.239	1.3	mg/L	0.0010	1	28769-110	07/11/16 17:54
Lead	0.0007	0.02	mg/L	0.0002	1	28769-110	07/11/16 17:54

Sample: 127-A-2	Collected: 06/28/16 07:03	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111297	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.296	1.3	mg/L	0.0010	1	28769-111	07/11/16 17:56
Lead	0.0008	0.02	mg/L	0.0002	1	28769-111	07/11/16 17:56

Sample: Corridor by 125-C-1	Collected: 06/28/16 07:05	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111298	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.163	1.3	mg/L	0.0010	1	28769-117	07/11/16 18:08
Lead	0.0026	0.02	mg/L	0.0002	1	28769-117	07/11/16 18:08

Sample: Corridor by 125-C-2	Collected: 06/28/16 07:06	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111299	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0944	1.3	mg/L	0.0010	1	28769-118	07/11/16 18:10
Lead	0.0010	0.02	mg/L	0.0002	1	28769-118	07/11/16 18:10

Sample: Corridor by 125-D	Collected: 06/28/16 07:11	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111300	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.182	1.3	mg/L	0.0010	1	28769-119	07/11/16 18:12
Lead	ND	0.02	mg/L	0.0002	1	28769-119	07/11/16 18:12

Sample: A103-A	Collected: 06/28/16 07:12	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111302	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.276	1.3	mg/L	0.0010	1	28769-120	07/11/16 18:14
Lead	0.0017	0.02	mg/L	0.0002	1	28769-120	07/11/16 18:14

Sample: A104-A	Collected: 06/28/16 07:13	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111303	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.319	1.3	mg/L	0.0010	1	28769-121	07/11/16 18:16
Lead	0.0008	0.02	mg/L	0.0002	1	28769-121	07/11/16 18:16

Sample: Gym 135-C	Collected: 06/28/16 07:16	Temp: 27 C	Matrix: Drinking Water
Lab ID: 111304	Received: 06/28/16 10:25	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.303	1.3	mg/L	0.0010	1	28769-122		07/11/16 18:18	
Lead	0.0005	0.02	mg/L	0.0002	1	28769-122		07/11/16 18:18	
Sample: A110-A-1		Collected: 06/28/16 07:18			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111305		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.195	1.3	mg/L	0.0010	1	28769-123		07/11/16 18:20	
Lead	0.0007	0.02	mg/L	0.0002	1	28769-123		07/11/16 18:20	
Sample: A110-A-2		Collected: 06/28/16 07:19			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111307		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.226	1.3	mg/L	0.0010	1	28769-124		07/11/16 18:21	
Lead	0.0030	0.02	mg/L	0.0002	1	28769-124		07/11/16 18:21	
Sample: Hall 144-C-1		Collected: 06/28/16 07:23			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111308		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0890	1.3	mg/L	0.0010	1	28769-125		07/11/16 18:23	
Lead	0.0007	0.02	mg/L	0.0002	1	28769-125		07/11/16 18:23	
Sample: Hall 144-C-2		Collected: 06/28/16 07:24			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111309		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.115	1.3	mg/L	0.0010	1	28769-130		07/11/16 18:33	
Lead	0.0068	0.02	mg/L	0.0002	1	28769-130		07/11/16 18:33	
Sample: A147-A-1		Collected: 06/28/16 07:24			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111310		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.222	1.3	mg/L	0.0010	1	28769-131		07/11/16 18:36	
Lead	0.0005	0.02	mg/L	0.0002	1	28769-131		07/11/16 18:36	
Sample: A147-A-2		Collected: 06/28/16 07:25			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111311		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.233	1.3	mg/L	0.0010	1	28769-132		07/11/16 18:38	
Lead	0.0012	0.02	mg/L	0.0002	1	28769-132		07/11/16 18:38	
Sample: A148-A-1		Collected: 06/28/16 07:27			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111313		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.180	1.3	mg/L	0.0010	1	28769-133		07/11/16 18:40	
Lead	0.0009	0.02	mg/L	0.0002	1	28769-133		07/11/16 18:40	
Sample: A148-A-2		Collected: 06/28/16 07:28			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111314		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes

Method: EPA 200.8									
Copper	0.170	1.3	mg/L	0.0010	1	28769-134		07/11/16 18:42	
Lead	0.0005	0.02	mg/L	0.0002	1	28769-134		07/11/16 18:42	
Sample: 150-A		Collected: 06/28/16 07:29			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111315		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.131	1.3	mg/L	0.0010	1	28769-135		07/11/16 18:43	
Lead	0.0047	0.02	mg/L	0.0002	1	28769-135		07/11/16 18:43	
Sample: 153-A		Collected: 06/28/16 07:31			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111316		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.320	1.3	mg/L	0.0010	1	28769-61		07/11/16 16:18	
Lead	0.0012	0.02	mg/L	0.0002	1	28769-61		07/11/16 16:18	
Sample: 153-B		Collected: 06/28/16 07:32			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111317		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.323	1.3	mg/L	0.0010	1	28769-62		07/11/16 16:20	
Lead	ND	0.02	mg/L	0.0002	1	28769-62		07/11/16 16:20	
Sample: 154-A		Collected: 06/28/16 07:33			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111318		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.197	1.3	mg/L	0.0010	1	28769-63		07/11/16 16:22	
Lead	0.0008	0.02	mg/L	0.0002	1	28769-63		07/11/16 16:22	
Sample: 154-B		Collected: 06/28/16 07:34			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111319		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.192	1.3	mg/L	0.0010	1	28769-64		07/11/16 16:24	
Lead	0.0015	0.02	mg/L	0.0002	1	28769-64		07/11/16 16:24	
Sample: 155-A		Collected: 06/28/16 07:36			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111320		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.208	1.3	mg/L	0.0010	1	28769-65		07/11/16 16:26	
Lead	0.0020	0.02	mg/L	0.0002	1	28769-65		07/11/16 16:26	
Sample: 155-B		Collected: 06/28/16 07:37			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111321		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.325	1.3	mg/L	0.0010	1	28769-66		07/11/16 16:28	
Lead	0.0008	0.02	mg/L	0.0002	1	28769-66		07/11/16 16:28	
Sample: 156-A		Collected: 06/28/16 07:38			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111322		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes

Method: EPA 200.8									
Copper	0.255	1.3	mg/L	0.0010	1	28769-67		07/11/16 16:30	
Lead	0.0012	0.02	mg/L	0.0002	1	28769-67		07/11/16 16:30	
Sample: 156-B		Collected: 06/28/16 07:39			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111323		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.392	1.3	mg/L	0.0010	1	28769-68		07/11/16 16:32	
Lead	0.0034	0.02	mg/L	0.0002	1	28769-68		07/11/16 16:32	
Sample: 157-A		Collected: 06/28/16 07:40			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111324		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.213	1.3	mg/L	0.0010	1	28769-69		07/11/16 16:33	
Lead	0.0013	0.02	mg/L	0.0002	1	28769-69		07/11/16 16:33	
Sample: 157-B		Collected: 06/28/16 07:41			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111325		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.356	1.3	mg/L	0.0010	1	28769-74		07/11/16 16:43	
Lead	0.0020	0.02	mg/L	0.0002	1	28769-74		07/11/16 16:43	
Sample: A100-A		Collected: 06/28/16 07:42			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111326		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.147	1.3	mg/L	0.0010	1	28769-75		07/11/16 16:45	
Lead	0.0014	0.02	mg/L	0.0002	1	28769-75		07/11/16 16:45	
Sample: A100-B		Collected: 06/28/16 07:43			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111327		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.232	1.3	mg/L	0.0010	1	28769-76		07/11/16 16:47	
Lead	0.0014	0.02	mg/L	0.0002	1	28769-76		07/11/16 16:47	
Sample: A101-A		Collected: 06/28/16 07:44			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111328		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.172	1.3	mg/L	0.0010	1	28769-77		07/11/16 16:49	
Lead	0.0010	0.02	mg/L	0.0002	1	28769-77		07/11/16 16:49	
Sample: A101-B		Collected: 06/28/16 07:45			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111329		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0962	1.3	mg/L	0.0010	1	28769-78		07/11/16 16:51	
Lead	0.0008	0.02	mg/L	0.0002	1	28769-78		07/11/16 16:51	
Sample: 159-A		Collected: 06/28/16 07:47			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111330		Received: 06/28/16 10:25			Evidence of Cooling:N				

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.131	1.3	mg/L	0.0010	1	28769-79		07/11/16 16:52	
Lead	0.0011	0.02	mg/L	0.0002	1	28769-79		07/11/16 16:52	
Sample: 159-B		Collected: 06/28/16 07:48			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111331		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.182	1.3	mg/L	0.0010	1	28769-80		07/11/16 16:54	
Lead	0.0008	0.02	mg/L	0.0002	1	28769-80		07/11/16 16:54	
Sample: 160-A		Collected: 06/28/16 07:49			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111332		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.219	1.3	mg/L	0.0010	1	28769-81		07/11/16 16:56	
Lead	0.0009	0.02	mg/L	0.0002	1	28769-81		07/11/16 16:56	
Sample: 160-B		Collected: 06/28/16 07:50			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111333		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.392	1.3	mg/L	0.0010	1	28769-82		07/11/16 16:58	
Lead	0.0005	0.02	mg/L	0.0002	1	28769-82		07/11/16 16:58	
Sample: A003-A-1		Collected: 06/28/16 07:57			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111334		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.185	1.3	mg/L	0.0010	1	28769-83		07/11/16 17:00	
Lead	0.0012	0.02	mg/L	0.0002	1	28769-83		07/11/16 17:00	
Sample: A003-A-2		Collected: 06/28/16 07:58			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111335		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.211	1.3	mg/L	0.0010	1	28769-88		07/11/16 17:10	
Lead	0.0011	0.02	mg/L	0.0002	1	28769-88		07/11/16 17:10	
Sample: A004-A		Collected: 06/28/16 08:00			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111336		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.160	1.3	mg/L	0.0010	1	28769-89		07/11/16 17:12	
Lead	0.0008	0.02	mg/L	0.0002	1	28769-89		07/11/16 17:12	
Sample: A006-A-1		Collected: 06/28/16 08:01			Temp: 27 C		Matrix: Drinking Water		
Lab ID: 111337		Received: 06/28/16 10:25			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.262	1.3	mg/L	0.0010	1	28769-90		07/11/16 17:14	
Lead	0.0121	0.02	mg/L	0.0002	1	28769-90		07/11/16 17:14	
Sample: A006-A-2		Collected: 06/28/16 08:02			Temp: 27 C		Matrix: Drinking Water		

Lab ID: 111338		Received: 06/28/16 10:25				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.146	1.3	mg/L	0.0010	1	28769-91		07/11/16 17:15	
Lead	0.0157	0.02	mg/L	0.0002	1	28769-91		07/11/16 17:15	
Sample: A006-A-3		Collected: 06/28/16 08:03				Temp: 27 C		Matrix: Drinking Water	
Lab ID: 111339		Received: 06/28/16 10:25				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.298	1.3	mg/L	0.0010	1	28769-92		07/11/16 17:17	
Lead	0.0048	0.02	mg/L	0.0002	1	28769-92		07/11/16 17:17	
Sample: A006-A-4		Collected: 06/28/16 08:04				Temp: 27 C		Matrix: Drinking Water	
Lab ID: 111340		Received: 06/28/16 10:25				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0909	1.3	mg/L	0.0010	1	28769-93		07/11/16 17:19	
Lead	0.0019	0.02	mg/L	0.0002	1	28769-93		07/11/16 17:19	
Sample: 018-A-1		Collected: 06/28/16 08:07				Temp: 27 C		Matrix: Drinking Water	
Lab ID: 111341		Received: 06/28/16 10:25				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.220	1.3	mg/L	0.0010	1	28769-94		07/11/16 17:21	
Lead	0.0003	0.02	mg/L	0.0002	1	28769-94		07/11/16 17:21	
Sample: 018-A-2		Collected: 06/28/16 08:13				Temp: 27 C		Matrix: Drinking Water	
Lab ID: 111342		Received: 06/28/16 10:25				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.165	1.3	mg/L	0.0010	1	28769-95		07/11/16 17:23	
Lead	0.0009	0.02	mg/L	0.0002	1	28769-95		07/11/16 17:23	
Sample: 004-A		Collected: 06/28/16 08:08				Temp: 27 C		Matrix: Drinking Water	
Lab ID: 111343		Received: 06/28/16 10:25				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.228	1.3	mg/L	0.0010	1	28769-96		07/11/16 17:25	
Lead	0.0016	0.02	mg/L	0.0002	1	28769-96		07/11/16 17:25	
Sample: 005-A		Collected: 06/28/16 08:09				Temp: 27 C		Matrix: Drinking Water	
Lab ID: 111344		Received: 06/28/16 10:25				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.198	1.3	mg/L	0.0010	1	28769-97		07/11/16 17:27	
Lead	0.0017	0.02	mg/L	0.0002	1	28769-97		07/11/16 17:27	
Sample: 018-B		Collected: 06/28/16 08:14				Temp: 27 C		Matrix: Drinking Water	
Lab ID: 111345		Received: 06/28/16 10:25				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.320	1.3	mg/L	0.0010	1	28769-102		07/11/16 17:38	
Lead	0.0030	0.02	mg/L	0.0002	1	28769-102		07/11/16 17:38	

Sample: 013-C Lab ID: 111346	Collected: 06/28/16 08:16 Received: 06/28/16 10:25	Temp: 27 C Evidence of Cooling:N	Matrix: Drinking Water
---------------------------------	---	-------------------------------------	------------------------

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.711	1.3	mg/L	0.0010	1	28769-103		07/11/16 17:40	
Lead	ND	0.02	mg/L	0.0002	1	28769-103		07/11/16 17:40	

Abbreviations

MRL Method Reporting Limit
 ND None Detected at or above the MRL
 Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

Units of Measure:

mg/L Milligrams Per Liter

Westlinn Sc
6062821

Chain of Custody Record-Water Samples
002-Bolton Primary School: 5933 SW Holmes St., West Linn, OR 97068

Location/Site	Date Collected	Collector's Name	Time	Date Delivered
107-A	6/28/2016	Jeff Chambers	6:20 AM	6/28/16
A107-A	6/28/2016	Jeff Chambers	6:23 AM	
110-A-1	6/28/2016	Jeff Chambers	6:26 AM	
110-A-2	6/28/2016	Jeff Chambers	6:30 AM	
110-B	6/28/2016	Jeff Chambers	6:28 AM	
113-A	6/28/2016	Jeff Chambers	6:33 AM	
113-B	6/28/2016	Jeff Chambers	6:34 AM	
114-A	6/28/2016	Jeff Chambers	6:36 AM	
114-B	6/28/2016	Jeff Chambers	6:37 AM	
115-A	6/28/2016	Jeff Chambers	6:39 AM	
115-B	6/28/2016	Jeff Chambers	6:40 AM	
116-A	6/28/2016	Jeff Chambers	6:41 AM	
116-B	6/28/2016	Jeff Chambers	6:42 AM	
119-A	6/28/2016	Jeff Chambers	6:43 AM	
119-B	6/28/2016	Jeff Chambers	6:44 AM	
120-A	6/28/2016	Jeff Chambers	6:45 AM	
120-B	6/28/2016	Jeff Chambers	6:46 AM	
122-A	6/28/2016	Jeff Chambers	6:53 AM	
122-B	6/28/2016	Jeff Chambers	6:54 AM	
A106-A	6/28/2016	Jeff Chambers	6:57 AM	
A106-B	6/28/2016	Jeff Chambers	6:58 AM	
124 A-1	6/28/2016	Jeff Chambers	6:59 AM	
124 A-2	6/28/2016	Jeff Chambers	7:00 AM	
127 A-1	6/28/2016	Jeff Chambers	7:02 AM	
127 A-2	6/28/2016	Jeff Chambers	7:03 AM	
Corridor by 125-C-1	6/28/2016	Jeff Chambers	7:05 AM	
Corridor by 125-C-2	6/28/2016	Jeff Chambers	7:06 AM	
Corridor by 125-D	6/28/2016	Jeff Chambers	7:11 AM	
A103-A	6/28/2016	Jeff Chambers	7:12 AM	
A104-A	6/28/2016	Jeff Chambers	7:13 AM	
Gym 135-C	6/28/2016	Jeff Chambers	7:16 AM	
A110 A-1	6/28/2016	Jeff Chambers	7:18 AM	
A110 A-2	6/28/2016	Jeff Chambers	7:19 AM	
Hall 144 C-1	6/28/2016	Jeff Chambers	7:23 AM	
Hall 144 C-2	6/28/2016	Jeff Chambers	7:24 AM	

27.2°C
No Cooling

Phony nill
Collector's Signature

6-28-16
Date

M. Ted
Laboratory Signature

Page 1 of 2
6/28/16, 1025
Date

Chain of Custody Record-Water Samples
002-Bolton Primary School: 5933 SW Holmes St., West Linn, OR 97068 *6062821*

147 A-1	6/28/2016	Jeff Chambers	7:24 AM	<i>6/28/16</i>
147 A-2	6/28/2016	Jeff Chambers	7:25 AM	
148 A-1	6/28/2016	Jeff Chambers	7:27 AM	
148 A-2	6/28/2016	Jeff Chambers	7:28 AM	
150-A	6/28/2016	Jeff Chambers	7:29 AM	
153-A	6/28/2016	Jeff Chambers	7:31 AM	
153-B	6/28/2016	Jeff Chambers	7:32 AM	
154-A	6/28/2016	Jeff Chambers	7:33 AM	
154-B	6/28/2016	Jeff Chambers	7:34 AM	
155-A	6/28/2016	Jeff Chambers	7:36 AM	
155-B	6/28/2016	Jeff Chambers	7:37 AM	
156-A	6/28/2016	Jeff Chambers	7:38 AM	
156-B	6/28/2016	Jeff Chambers	7:39 AM	
157-A	6/28/2016	Jeff Chambers	7:40 AM	
157-B	6/28/2016	Jeff Chambers	7:41 AM	
A100-A	6/28/2016	Jeff Chambers	7:42 AM	
A100-B	6/28/2016	Jeff Chambers	7:43 AM	
A101-A	6/28/2016	Jeff Chambers	7:44 AM	
A101-B	6/28/2016	Jeff Chambers	7:45 AM	
159-A	6/28/2016	Jeff Chambers	7:47 AM	
159-B	6/28/2016	Jeff Chambers	7:48 AM	
160-A	6/28/2016	Jeff Chambers	7:49 AM	
160-B	6/28/2016	Jeff Chambers	7:50 AM	
A003 A-1	6/28/2016	Jeff Chambers	7:57 AM	
A003 A-2	6/28/2016	Jeff Chambers	7:58 AM	
A004-A	6/28/2016	Jeff Chambers	8:00 AM	
A006 A-1	6/28/2016	Jeff Chambers	8:01 AM	
A006 A-2	6/28/2016	Jeff Chambers	8:02 AM	
A006 A-3	6/28/2016	Jeff Chambers	8:03 AM	
A006 A-4	6/28/2016	Jeff Chambers	8:04 AM	
018-A-1	6/28/2016	Jeff Chambers	8:07 AM	
018-A-2	6/28/2016	Jeff Chambers	8:13 AM	
004-A	6/28/2016	Jeff Chambers	8:08 AM	
005-A	6/28/2016	Jeff Chambers	8:09 AM	
018-B	6/28/2016	Jeff Chambers	8:14 AM	
018-C	6/28/2016	Jeff Chambers	8:16 AM	

Thomy
 Collector's Signature

6-28-16
 Date

M W / od
 Laboratory Signature

Page 2 of 2
6/28/16, 1025
 Date