

PIXIS Labs

Accurate. Reliable. On Time.

Pixis Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

Job Number: 6071212
Report Date: 07/20/2016
ORELAP #: OR100028
Project No: 010-C.R.E.S.T.

Cover Letter

Pat McGough
West Linn School District
2755 SW Borland
West Linn, OR 97068

Dear Pat McGough,

Enclosed please find Pixis Labs analytical report for samples received as order number 6071212 on 07/12/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed

Richard Reid

Project Manager

Sample Results

Sample: Mens RR-A		Collected: 07/12/16 07:52		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 114015		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.102	1.3	mg/L	0.0010	1	28845-137		07/15/16 17:00	
Lead	0.0004	0.02	mg/L	0.0002	1	28845-137		07/15/16 17:00	
Sample: Womens RR-A		Collected: 07/12/16 07:53		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 114016		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0958	1.3	mg/L	0.0010	1	28845-138		07/15/16 17:02	
Lead	0.0006	0.02	mg/L	0.0002	1	28845-138		07/15/16 17:02	
Sample: Seminar-A		Collected: 07/12/16 07:55		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 114017		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0623	1.3	mg/L	0.0010	1	28845-139		07/15/16 17:04	
Lead	0.0004	0.02	mg/L	0.0002	1	28845-139		07/15/16 17:04	
Sample: Seminar-C		Collected: 07/12/16 07:56		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 114018		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.150	1.3	mg/L	0.0010	1	28845-140		07/15/16 17:06	
Lead	0.0003	0.02	mg/L	0.0002	1	28845-140		07/15/16 17:06	
Sample: Garage RR-A		Collected: 07/12/16 08:00		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 114019		Received: 07/12/16 10:22		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.127	1.3	mg/L	0.0010	1	28845-141		07/15/16 17:07	
Lead	0.0006	0.02	mg/L	0.0002	1	28845-141		07/15/16 17:07	

Abbreviations

MRL Method Reporting Limit
 ND None Detected at or above the MRL
 Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

Units of Measure:

mg/L Milligrams Per Liter

Chain of Custody Record-Water Samples
010-C.R.E.S.T.: 11265 SW Wilsonville Rd., Wilsonville, OR 97070

Location/Site	Date Collected	Collector's Name	Time	Date Delivered
Men's RR-A	7/12/2016	Steve Matthias	7:52 AM	7/12/2016
Women's RR-A	7/12/2016	Steve Matthias	7:53 AM	7/12/2016
Seminar-A	7/12/2016	Steve Matthias	7:55 AM	7/12/2016
Seminar-C	7/12/2016	Steve Matthias	7:56 AM	7/12/2016
Garage RR-A	7/12/2016	Steve Matthias	8:00 AM	7/12/2016

WESTMIN SC
0071212
page 1 of 1

Steve Matthias 7/12/16
Collector's Signature Date

M. Wood 7/12/16 1022
Laboratory Signature Date
22°C, no cooling