Pixis Labs
12423 NE Whitaker Way
Portland, OR 97230
503-254-1794

Job Number:	6080437
Report Date:	08/16/2016
ORELAP #:	OR100028
Project No:	001-West Linn High School

Cover Letter

Pat McGough
West Linn School District
2755 SW Borland
West Linn, OR 97068

Dear Pat McGough,

Enclosed please find Pixis Labs analytical report for samples received as order number 6080437 on 08/04/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed
Richard Reid
Project Manager

Pixis Labs
12423 NE Whitaker Way
Portland, OR 97230
503-254-1794

Job Number: 6080437
Report Date: 08/16/2016
ORELAP #: OR100028
Project No: 001-West Linn High School

Sample Results

Sample: A107-A | Collected: 08/04/16 06:05 | Temp: 26 C | Matrix: Drinking Water
Lab ID: 117164 | Received: 08/04/16 14:50 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.344	1.3	mg/L	0.0010	1	29140-27		08/10/16 20:35	
Lead	0.0008	0.02	mg/L	0.0002	1	29140-27		08/10/16 20:35	

Sample: A107-B | Collected: 08/04/16 06:06 | Temp: 26 C | Matrix: Drinking Water
Lab ID: 117165 | Received: 08/04/16 14:50 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.412	1.3	mg/L	0.0010	1	29140-28		08/10/16 20:37	
Lead	0.0008	0.02	mg/L	0.0002	1	29140-28		08/10/16 20:37	

Sample: B107-A | Collected: 08/04/16 06:07 | Temp: 26 C | Matrix: Drinking Water
Lab ID: 117166 | Received: 08/04/16 14:50 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.273	1.3	mg/L	0.0010	1	29140-29		08/10/16 20:39	
Lead	0.0018	0.02	mg/L	0.0002	1	29140-29		08/10/16 20:39	

Sample: B107-B | Collected: 08/04/16 06:08 | Temp: 26 C | Matrix: Drinking Water
Lab ID: 117167 | Received: 08/04/16 14:50 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.356	1.3	mg/L	0.0010	1	29140-30		08/10/16 20:41	
Lead	0.0021	0.02	mg/L	0.0002	1	29140-30		08/10/16 20:41	

Sample: C101-A-1 | Collected: 08/04/16 06:09 | Temp: 26 C | Matrix: Drinking Water
Lab ID: 117168 | Received: 08/04/16 14:50 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.266	1.3	mg/L	0.0010	1	29140-31		08/10/16 20:44	
Lead	0.0010	0.02	mg/L	0.0002	1	29140-31		08/10/16 20:44	

Sample: C101-A-2 | Collected: 08/04/16 06:10 | Temp: 26 C | Matrix: Drinking Water
Lab ID: 117169 | Received: 08/04/16 14:50 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.235	1.3	mg/L	0.0010	1	29140-32		08/10/16 20:46	
Lead	0.0008	0.02	mg/L	0.0002	1	29140-32		08/10/16 20:46	

Sample: C101-A-3 | Collected: 08/04/16 06:11 | Temp: 26 C | Matrix: Drinking Water
Lab ID: 117170 | Received: 08/04/16 14:50 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.248	1.3	mg/L	0.0010	1	29140-33		08/10/16 20:48	

Lead	0.0007	0.02	mg/L	0.0002	1	29140-33		08/10/16 20:48	

Sample: C101-A-4	Collected: 08/04/16 06:12	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117171	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.378	1.3	mg/L	0.0010	1	29140-38		08/10/16 21:00	
Lead	0.0003	0.02	mg/L	0.0002	1	29140-38		08/10/16 21:00	

Sample: C101B-A	Collected: 08/04/16 06:13	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117172	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.300	1.3	mg/L	0.0010	1	29140-39		08/10/16 21:02	
Lead	0.0035	0.02	mg/L	0.0002	1	29140-39		08/10/16 21:02	

Sample: C102-A-1	Collected: 08/04/16 06:20	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117173	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.234	1.3	mg/L	0.0010	1	29140-40		08/10/16 21:04	
Lead	0.0081	0.02	mg/L	0.0002	1	29140-40		08/10/16 21:04	

Sample: C102-A-2	Collected: 08/04/16 06:21	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117174	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.373	1.3	mg/L	0.0010	1	29140-41		08/10/16 21:07	
Lead	0.0011	0.02	mg/L	0.0002	1	29140-41		08/10/16 21:07	

Sample: C102-A-3	Collected: 08/04/16 06:22	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117175	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.390	1.3	mg/L	0.0010	1	29140-42		08/10/16 21:09	
Lead	0.0008	0.02	mg/L	0.0002	1	29140-42		08/10/16 21:09	

Sample: C102-A-4	Collected: 08/04/16 06:23	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117176	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.590	1.3	mg/L	0.0010	1	29140-43		08/10/16 21:11	
Lead	0.0141	0.02	mg/L	0.0002	1	29140-43		08/10/16 21:11	

Sample: C102-A-5	Collected: 08/04/16 06:24	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117177	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.272	1.3	mg/L	0.0010	1	29140-44		08/10/16 21:13	
Lead	0.0006	0.02	mg/L	0.0002	1	29140-44		08/10/16 21:13	

Sample: C102-A-6	Collected: 08/04/16 06:25	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117178	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									

Copper	0.221	1.3	mg/L	0.0010	1	29140-45		08/10/16 21:16	
Lead	0.0006	0.02	mg/L	0.0002	1	29140-45		08/10/16 21:16	

Sample: C102-A-7		Collected: 08/04/16 06:27				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117179		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.255	1.3	mg/L	0.0010	1	29140-46		08/10/16 21:18	
Lead	0.0011	0.02	mg/L	0.0002	1	29140-46		08/10/16 21:18	

Sample: C102A-A		Collected: 08/04/16 06:26				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117180		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.256	1.3	mg/L	0.0010	1	29140-47		08/10/16 21:20	
Lead	0.0029	0.02	mg/L	0.0002	1	29140-47		08/10/16 21:20	

Sample: C103-A-1		Collected: 08/04/16 06:27				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117181		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.434	1.3	mg/L	0.0010	1	29140-53		08/10/16 21:34	
Lead	0.0008	0.02	mg/L	0.0002	1	29140-53		08/10/16 21:34	

Sample: C103-A-2		Collected: 08/04/16 06:28				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117182		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.293	1.3	mg/L	0.0010	1	29140-54		08/10/16 21:36	
Lead	0.0007	0.02	mg/L	0.0002	1	29140-54		08/10/16 21:36	

Sample: C103-A-3		Collected: 08/04/16 06:29				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117183		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.241	1.3	mg/L	0.0010	1	29140-55		08/10/16 21:39	
Lead	0.0042	0.02	mg/L	0.0002	1	29140-55		08/10/16 21:39	

Sample: C103-A-4		Collected: 08/04/16 06:30				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117184		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.213	1.3	mg/L	0.0010	1	29140-56		08/10/16 21:41	
Lead	0.0040	0.02	mg/L	0.0002	1	29140-56		08/10/16 21:41	

Sample: C103-A-5		Collected: 08/04/16 06:31				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117185		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.304	1.3	mg/L	0.0010	1	29140-57		08/10/16 21:43	
Lead	0.0006	0.02	mg/L	0.0002	1	29140-57		08/10/16 21:43	

Sample: C103-A-6		Collected: 08/04/16 06:32				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117186		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									

Copper	0.215	1.3	mg/L	0.0010	1	29140-58		08/10/16 21:46	
Lead	0.0009	0.02	mg/L	0.0002	1	29140-58		08/10/16 21:46	

Sample: C103-A-7	Collected: 08/04/16 06:33	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117187	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.189	1.3	mg/L	0.0010	1	29140-59		08/10/16 21:48	
Lead	0.0014	0.02	mg/L	0.0002	1	29140-59		08/10/16 21:48	

Sample: C104-A-1	Collected: 08/04/16 06:34	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117188	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.260	1.3	mg/L	0.0010	1	29140-60		08/10/16 21:50	
Lead	0.0016	0.02	mg/L	0.0002	1	29140-60		08/10/16 21:50	

Sample: C104-A-2	Collected: 08/04/16 06:35	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117189	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.415	1.3	mg/L	0.0010	1	29140-61		08/10/16 21:53	
Lead	0.0014	0.02	mg/L	0.0002	1	29140-61		08/10/16 21:53	

Sample: C104-A-3	Collected: 08/04/16 06:36	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117190	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.376	1.3	mg/L	0.0010	1	29140-62		08/10/16 21:55	
Lead	0.0008	0.02	mg/L	0.0002	1	29140-62		08/10/16 21:55	

Sample: C104-A-4	Collected: 08/04/16 06:37	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117191	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.421	1.3	mg/L	0.0010	1	29140-67		08/10/16 22:07	
Lead	0.0210	0.02	mg/L	0.0002	1	29140-67		08/10/16 22:07	

Sample: C104-A-5	Collected: 08/04/16 06:38	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117192	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.263	1.3	mg/L	0.0010	1	29139-51		08/10/16 14:09	
Lead	0.0014	0.02	mg/L	0.0002	1	29139-51		08/10/16 14:09	

Sample: C104-A-6	Collected: 08/04/16 06:39	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117193	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.385	1.3	mg/L	0.0010	1	29139-52		08/10/16 14:11	
Lead	0.0009	0.02	mg/L	0.0002	1	29139-52		08/10/16 14:11	

Sample: C104-A-7	Collected: 08/04/16 06:40	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117194	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									

Copper	0.243	1.3	mg/L	0.0010	1	29139-53		08/10/16 14:14	
Lead	0.0009	0.02	mg/L	0.0002	1	29139-53		08/10/16 14:14	

Sample: C105B-A	Collected: 08/04/16 07:27	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117195	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.0819	1.3	mg/L	0.0010	1	29139-54		08/10/16 14:16	
Lead	0.0013	0.02	mg/L	0.0002	1	29139-54		08/10/16 14:16	

Sample: C106-A-1	Collected: 08/04/16 07:28	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117196	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.255	1.3	mg/L	0.0010	1	29139-55		08/10/16 14:18	
Lead	0.0009	0.02	mg/L	0.0002	1	29139-55		08/10/16 14:18	

Sample: C106-A-2	Collected: 08/04/16 07:29	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117197	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.229	1.3	mg/L	0.0010	1	29139-56		08/10/16 14:20	
Lead	0.0007	0.02	mg/L	0.0002	1	29139-56		08/10/16 14:20	

Sample: C106-A-3	Collected: 08/04/16 07:30	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117198	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.231	1.3	mg/L	0.0010	1	29139-57		08/10/16 14:22	
Lead	0.0006	0.02	mg/L	0.0002	1	29139-57		08/10/16 14:22	

Sample: C106-A-4	Collected: 08/04/16 07:31	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117199	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.276	1.3	mg/L	0.0010	1	29139-58		08/10/16 14:24	
Lead	0.0006	0.02	mg/L	0.0002	1	29139-58		08/10/16 14:24	

Sample: C106-A-5	Collected: 08/04/16 07:32	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117200	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.311	1.3	mg/L	0.0010	1	29139-59		08/10/16 14:27	
Lead	0.0005	0.02	mg/L	0.0002	1	29139-59		08/10/16 14:27	

Sample: C106-A-6	Collected: 08/04/16 07:33	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117201	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.274	1.3	mg/L	0.0010	1	29139-60		08/10/16 14:29	
Lead	0.0004	0.02	mg/L	0.0002	1	29139-60		08/10/16 14:29	

Sample: C106-A-7	Collected: 08/04/16 07:34	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117202	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**

Method: EPA 200.8									
Copper	0.218	1.3	mg/L	0.0010	1	29139-65		08/10/16 14:40	
Lead	0.0187	0.02	mg/L	0.0002	1	29139-65		08/10/16 14:40	

Sample: C110-C-1		Collected: 08/04/16 07:35				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117203		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.708	1.3	mg/L	0.0010	1	29139-66		08/10/16 14:42	
Lead	ND	0.02	mg/L	0.0002	1	29139-66		08/10/16 14:42	

Sample: C110-C-2		Collected: 08/04/16 07:36				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117204		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.487	1.3	mg/L	0.0010	1	29139-67		08/10/16 14:44	
Lead	ND	0.02	mg/L	0.0002	1	29139-67		08/10/16 14:44	

Sample: C113-C-1		Collected: 08/04/16 07:37				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117205		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.548	1.3	mg/L	0.0010	1	29139-68		08/10/16 14:46	
Lead	ND	0.02	mg/L	0.0002	1	29139-68		08/10/16 14:46	

Sample: C113-C-2		Collected: 08/04/16 07:38				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117206		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.414	1.3	mg/L	0.0010	1	29139-69		08/10/16 14:48	
Lead	ND	0.02	mg/L	0.0002	1	29139-69		08/10/16 14:48	

Sample: D101A-A		Collected: 08/04/16 07:39				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117207		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.293	1.3	mg/L	0.0010	1	29139-70		08/10/16 14:51	
Lead	0.0025	0.02	mg/L	0.0002	1	29139-70		08/10/16 14:51	

Sample: D101B-A		Collected: 08/04/16 07:40				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117208		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.267	1.3	mg/L	0.0010	1	29139-71		08/10/16 14:53	
Lead	0.0020	0.02	mg/L	0.0002	1	29139-71		08/10/16 14:53	

Sample: D103B-A		Collected: 08/04/16 07:41				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117209		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.210	1.3	mg/L	0.0010	1	29139-72		08/10/16 14:55	
Lead	0.0046	0.02	mg/L	0.0002	1	29139-72		08/10/16 14:55	

Sample: E107-A		Collected: 08/04/16 07:42				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117210		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**

Method: EPA 200.8									
Copper	0.293	1.3	mg/L	0.0010	1	29139-73		08/10/16 14:57	
Lead	0.0021	0.02	mg/L	0.0002	1	29139-73		08/10/16 14:57	

Sample: E107-B	Collected: 08/04/16 07:43	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117211	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.238	1.3	mg/L	0.0010	1	29139-74		08/10/16 14:59	
Lead	0.0015	0.02	mg/L	0.0002	1	29139-74		08/10/16 14:59	

Sample: F103-A	Collected: 08/04/16 07:44	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117212	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.303	1.3	mg/L	0.0010	1	29139-80		08/10/16 15:13	
Lead	0.0021	0.02	mg/L	0.0002	1	29139-80		08/10/16 15:13	

Sample: A207-A	Collected: 08/04/16 07:50	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117213	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.246	1.3	mg/L	0.0010	1	29139-81		08/10/16 15:15	
Lead	0.0009	0.02	mg/L	0.0002	1	29139-81		08/10/16 15:15	

Sample: A207-B	Collected: 08/04/16 07:51	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117214	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.385	1.3	mg/L	0.0010	1	29139-82		08/10/16 15:17	
Lead	0.0037	0.02	mg/L	0.0002	1	29139-82		08/10/16 15:17	

Sample: B207-A	Collected: 08/04/16 07:52	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117215	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.188	1.3	mg/L	0.0010	1	29139-83		08/10/16 15:19	
Lead	0.0011	0.02	mg/L	0.0002	1	29139-83		08/10/16 15:19	

Sample: B207-B	Collected: 08/04/16 07:53	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117216	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.274	1.3	mg/L	0.0010	1	29139-84		08/10/16 15:21	
Lead	0.0204	0.02	mg/L	0.0002	1	29139-84		08/10/16 15:21	

Sample: C201-A-1	Collected: 08/04/16 08:12	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117217	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.203	1.3	mg/L	0.0010	1	29139-85		08/10/16 15:23	
Lead	0.0014	0.02	mg/L	0.0002	1	29139-85		08/10/16 15:23	

Sample: C201-A-2	Collected: 08/04/16 08:13	Temp: 26 C	Matrix: Drinking Water
Lab ID: 117218	Received: 08/04/16 14:50	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.190	1.3	mg/L	0.0010	1	29139-86		08/10/16 15:26	
Lead	0.0014	0.02	mg/L	0.0002	1	29139-86		08/10/16 15:26	

Sample: C201-A-3 Collected: 08/04/16 08:14 Temp: 26 C Matrix: Drinking Water
Lab ID: 117219 Received: 08/04/16 14:50 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.226	1.3	mg/L	0.0010	1	29139-87		08/10/16 15:28	
Lead	0.0013	0.02	mg/L	0.0002	1	29139-87		08/10/16 15:28	

Sample: C201-A-4 Collected: 08/04/16 08:15 Temp: 26 C Matrix: Drinking Water
Lab ID: 117220 Received: 08/04/16 14:50 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.225	1.3	mg/L	0.0010	1	29139-88		08/10/16 15:30	
Lead	0.0013	0.02	mg/L	0.0002	1	29139-88		08/10/16 15:30	

Sample: C202-A-1 Collected: 08/04/16 08:16 Temp: 26 C Matrix: Drinking Water
Lab ID: 117221 Received: 08/04/16 14:50 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.315	1.3	mg/L	0.0010	1	29139-89		08/10/16 15:32	
Lead	0.0006	0.02	mg/L	0.0002	1	29139-89		08/10/16 15:32	

Sample: C202-A-2 Collected: 08/04/16 08:17 Temp: 26 C Matrix: Drinking Water
Lab ID: 117222 Received: 08/04/16 14:50 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.208	1.3	mg/L	0.0010	1	29139-94		08/10/16 15:43	
Lead	0.0008	0.02	mg/L	0.0002	1	29139-94		08/10/16 15:43	

Sample: C202-A-3 Collected: 08/04/16 08:18 Temp: 26 C Matrix: Drinking Water
Lab ID: 117223 Received: 08/04/16 14:50 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.225	1.3	mg/L	0.0010	1	29139-95		08/10/16 15:45	
Lead	0.0008	0.02	mg/L	0.0002	1	29139-95		08/10/16 15:45	

Sample: C202-A-4 Collected: 08/04/16 08:19 Temp: 26 C Matrix: Drinking Water
Lab ID: 117224 Received: 08/04/16 14:50 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.181	1.3	mg/L	0.0010	1	29139-96		08/10/16 15:47	
Lead	0.0069	0.02	mg/L	0.0002	1	29139-96		08/10/16 15:47	

Sample: C202-A-5 Collected: 08/04/16 08:20 Temp: 26 C Matrix: Drinking Water
Lab ID: 117225 Received: 08/04/16 14:50 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.196	1.3	mg/L	0.0010	1	29139-97		08/10/16 15:50	
Lead	0.0008	0.02	mg/L	0.0002	1	29139-97		08/10/16 15:50	

Sample: C202-A-6 Collected: 08/04/16 08:21 Temp: 26 C Matrix: Drinking Water

Lab ID: 117226		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.230	1.3	mg/L	0.0010	1	29139-98		08/10/16 15:52	
Lead	0.0010	0.02	mg/L	0.0002	1	29139-98		08/10/16 15:52	

Sample: C202-A-7		Collected: 08/04/16 08:22				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117227		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.187	1.3	mg/L	0.0010	1	29139-99		08/10/16 15:54	
Lead	0.0012	0.02	mg/L	0.0002	1	29139-99		08/10/16 15:54	

Sample: C202A-A		Collected: 08/04/16 08:23				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117228		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.183	1.3	mg/L	0.0010	1	29139-100		08/10/16 15:56	
Lead	0.0040	0.02	mg/L	0.0002	1	29139-100		08/10/16 15:56	

Sample: C203-A-1		Collected: 08/04/16 08:24				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117229		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.337	1.3	mg/L	0.0010	1	29139-101		08/10/16 15:58	
Lead	0.0010	0.02	mg/L	0.0002	1	29139-101		08/10/16 15:58	

Sample: C203-A-2		Collected: 08/04/16 08:25				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117230		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.312	1.3	mg/L	0.0010	1	29139-102		08/10/16 16:01	
Lead	0.0007	0.02	mg/L	0.0002	1	29139-102		08/10/16 16:01	

Sample: C203-A-3		Collected: 08/04/16 08:26				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117231		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.261	1.3	mg/L	0.0010	1	29139-103		08/10/16 16:03	
Lead	0.0008	0.02	mg/L	0.0002	1	29139-103		08/10/16 16:03	

Sample: C203-A-4		Collected: 08/04/16 08:27				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117232		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.195	1.3	mg/L	0.0010	1	29139-108		08/10/16 16:14	
Lead	0.0029	0.02	mg/L	0.0002	1	29139-108		08/10/16 16:14	

Sample: C203-A-5		Collected: 08/04/16 08:28				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117233		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.231	1.3	mg/L	0.0010	1	29139-109		08/10/16 16:16	
Lead	0.0008	0.02	mg/L	0.0002	1	29139-109		08/10/16 16:16	

Sample: C203-A-6 | Collected: 08/04/16 08:29 | Temp: 26 C | Matrix: Drinking Water
Lab ID: 117234 | Received: 08/04/16 14:50 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.232	1.3	mg/L	0.0010	1	29139-110		08/10/16 16:18	
Lead	0.0005	0.02	mg/L	0.0002	1	29139-110		08/10/16 16:18	

Sample: C203-A-7 | Collected: 08/04/16 08:30 | Temp: 26 C | Matrix: Drinking Water
Lab ID: 117235 | Received: 08/04/16 14:50 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.243	1.3	mg/L	0.0010	1	29139-111		08/10/16 16:20	
Lead	0.0005	0.02	mg/L	0.0002	1	29139-111		08/10/16 16:20	

Sample: C205-A-1 | Collected: 08/04/16 08:42 | Temp: 26 C | Matrix: Drinking Water
Lab ID: 117236 | Received: 08/04/16 14:50 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.283	1.3	mg/L	0.0010	1	29139-112		08/10/16 16:23	
Lead	0.0003	0.02	mg/L	0.0002	1	29139-112		08/10/16 16:23	

Sample: C205-A-2 | Collected: 08/04/16 08:43 | Temp: 26 C | Matrix: Drinking Water
Lab ID: 117237 | Received: 08/04/16 14:50 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.329	1.3	mg/L	0.0010	1	29139-113		08/10/16 16:25	
Lead	0.0022	0.02	mg/L	0.0002	1	29139-113		08/10/16 16:25	

Sample: C205-A-3 | Collected: 08/04/16 08:44 | Temp: 26 C | Matrix: Drinking Water
Lab ID: 117238 | Received: 08/04/16 14:50 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.299	1.3	mg/L	0.0010	1	29139-114		08/10/16 16:27	
Lead	0.0009	0.02	mg/L	0.0002	1	29139-114		08/10/16 16:27	

Sample: C205-A-4 | Collected: 08/04/16 08:45 | Temp: 26 C | Matrix: Drinking Water
Lab ID: 117239 | Received: 08/04/16 14:50 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.312	1.3	mg/L	0.0010	1	29139-115		08/10/16 16:29	
Lead	0.0231	0.02	mg/L	0.0002	1	29139-115		08/10/16 16:29	

Sample: C205-A-5 | Collected: 08/04/16 08:46 | Temp: 26 C | Matrix: Drinking Water
Lab ID: 117240 | Received: 08/04/16 14:50 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.227	1.3	mg/L	0.0010	1	29139-116		08/10/16 16:31	
Lead	0.0009	0.02	mg/L	0.0002	1	29139-116		08/10/16 16:31	

Sample: C205-A-6 | Collected: 08/04/16 08:47 | Temp: 26 C | Matrix: Drinking Water
Lab ID: 117241 | Received: 08/04/16 14:50 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.240	1.3	mg/L	0.0010	1	29139-117		08/10/16 16:34	
Lead	0.0007	0.02	mg/L	0.0002	1	29139-117		08/10/16 16:34	

Sample: C205-A-7		Collected: 08/04/16 08:48				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117242		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.280	1.3	mg/L	0.0010	1	29139-122		08/10/16 16:45	
Lead	0.0011	0.02	mg/L	0.0002	1	29139-122		08/10/16 16:45	

Sample: C204-A-1		Collected: 08/04/16 08:35				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117243		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.180	1.3	mg/L	0.0010	1	29139-123		08/10/16 16:47	
Lead	0.0008	0.02	mg/L	0.0002	1	29139-123		08/10/16 16:47	

Sample: C204-A-2		Collected: 08/04/16 08:36				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117244		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.186	1.3	mg/L	0.0010	1	29139-124		08/10/16 16:49	
Lead	0.0008	0.02	mg/L	0.0002	1	29139-124		08/10/16 16:49	

Sample: C204-A-3		Collected: 08/04/16 08:37				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117245		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.185	1.3	mg/L	0.0010	1	29139-125		08/10/16 16:51	
Lead	0.0006	0.02	mg/L	0.0002	1	29139-125		08/10/16 16:51	

Sample: C204-A-4		Collected: 08/04/16 08:38				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117246		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.204	1.3	mg/L	0.0010	1	29139-126		08/10/16 16:54	
Lead	0.0032	0.02	mg/L	0.0002	1	29139-126		08/10/16 16:54	

Sample: C204-A-5		Collected: 08/04/16 08:39				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117247		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.262	1.3	mg/L	0.0010	1	29139-127		08/10/16 16:56	
Lead	0.0009	0.02	mg/L	0.0002	1	29139-127		08/10/16 16:56	

Sample: C204-A-6		Collected: 08/04/16 08:40				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117248		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.372	1.3	mg/L	0.0010	1	29139-128		08/10/16 16:58	
Lead	0.0014	0.02	mg/L	0.0002	1	29139-128		08/10/16 16:58	

Sample: C204-A-7		Collected: 08/04/16 08:41				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117249		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.169	1.3	mg/L	0.0010	1	29139-129		08/10/16 17:00	
Lead	0.0005	0.02	mg/L	0.0002	1	29139-129		08/10/16 17:00	

Sample: C209-C-1		Collected: 08/04/16 08:53				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117250		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.801	1.3	mg/L	0.0010	1	29139-130		08/10/16 17:03	
Lead	0.0005	0.02	mg/L	0.0002	1	29139-130		08/10/16 17:03	

Sample: C209-C-2		Collected: 08/04/16 08:54				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117251		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.433	1.3	mg/L	0.0010	1	29139-131		08/10/16 17:05	
Lead	0.0004	0.02	mg/L	0.0002	1	29139-131		08/10/16 17:05	

Sample: C212-C-1		Collected: 08/04/16 09:03				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117252		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.328	1.3	mg/L	0.0010	1	29144-54		08/11/16 22:04	
Lead	0.0003	0.02	mg/L	0.0002	1	29144-54		08/11/16 22:04	

Sample: C212-C-2		Collected: 08/04/16 09:03				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117253		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.334	1.3	mg/L	0.0010	1	29139-137		08/10/16 17:18	
Lead	0.0002	0.02	mg/L	0.0002	1	29139-137		08/10/16 17:18	

Sample: D206-B		Collected: 08/04/16 07:57				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117254		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.122	1.3	mg/L	0.0010	1	29139-138		08/10/16 17:22	
Lead	0.0018	0.02	mg/L	0.0002	1	29139-138		08/10/16 17:22	

Sample: E207-A		Collected: 08/04/16 07:54				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117255		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.274	1.3	mg/L	0.0010	1	29139-139		08/10/16 17:24	
Lead	0.0014	0.02	mg/L	0.0002	1	29139-139		08/10/16 17:24	

Sample: E207-B		Collected: 08/04/16 07:55				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117256		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.316	1.3	mg/L	0.0010	1	29139-140		08/10/16 17:27	
Lead	0.0012	0.02	mg/L	0.0002	1	29139-140		08/10/16 17:27	

Sample: G204-C-1		Collected: 08/04/16 06:56				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117257		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	3.67	1.3	mg/L	0.0500	50	29144-55		08/11/16 22:06	
Lead	0.0008	0.02	mg/L	0.0002	1	29139-141		08/10/16 17:29	

Sample: G204-C-2		Collected: 08/04/16 06:57				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117258		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.733	1.3	mg/L	0.0010	1	29139-142		08/10/16 17:31	
Lead	0.0008	0.02	mg/L	0.0002	1	29139-142		08/10/16 17:31	

Sample: G207-A		Collected: 08/04/16 06:58				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117259		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.320	1.3	mg/L	0.0010	1	29139-143		08/10/16 17:33	
Lead	0.0003	0.02	mg/L	0.0002	1	29139-143		08/10/16 17:33	

Sample: G208A-A-1		Collected: 08/04/16 06:59				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117260		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.449	1.3	mg/L	0.0010	1	29139-144		08/10/16 17:35	
Lead	0.0048	0.02	mg/L	0.0002	1	29139-144		08/10/16 17:35	

Sample: G208A-A-2		Collected: 08/04/16 07:00				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117261		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.362	1.3	mg/L	0.0010	1	29139-145		08/10/16 17:38	
Lead	0.0035	0.02	mg/L	0.0002	1	29139-145		08/10/16 17:38	

Sample: G208B-A		Collected: 08/04/16 07:01				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117262		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.325	1.3	mg/L	0.0010	1	29139-150		08/10/16 17:49	
Lead	0.0014	0.02	mg/L	0.0002	1	29139-150		08/10/16 17:49	

Sample: G122-A		Collected: 08/04/16 07:15				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117263		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.289	1.3	mg/L	0.0010	1	29139-151		08/10/16 17:51	
Lead	0.0019	0.02	mg/L	0.0002	1	29139-151		08/10/16 17:51	

Sample: G123-A		Collected: 08/04/16 07:16				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117264		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.229	1.3	mg/L	0.0010	1	29139-152		08/10/16 17:53	
Lead	0.0018	0.02	mg/L	0.0002	1	29139-152		08/10/16 17:53	

Sample: G127-A		Collected: 08/04/16 07:17				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117265		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.298	1.3	mg/L	0.0010	1	29139-153		08/10/16 17:56	
Lead	0.0008	0.02	mg/L	0.0002	1	29139-153		08/10/16 17:56	

Sample: G129-A		Collected: 08/04/16 07:18				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117266		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.374	1.3	mg/L	0.0010	1	29139-154		08/10/16 17:58	
Lead	0.0013	0.02	mg/L	0.0002	1	29139-154		08/10/16 17:58	

Sample: G129A-A		Collected: 08/04/16 07:19				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117267		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.516	1.3	mg/L	0.0010	1	29139-155		08/10/16 18:00	
Lead	0.0025	0.02	mg/L	0.0002	1	29139-155		08/10/16 18:00	

Sample: G136-C-1		Collected: 08/04/16 06:53				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117268		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.455	1.3	mg/L	0.0010	1	29139-156		08/10/16 18:02	
Lead	0.0003	0.02	mg/L	0.0002	1	29139-156		08/10/16 18:02	

Sample: G136-C-2		Collected: 08/04/16 06:54				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117269		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.437	1.3	mg/L	0.0010	1	29139-157		08/10/16 18:05	
Lead	0.0003	0.02	mg/L	0.0002	1	29139-157		08/10/16 18:05	

Sample: G136-D		Collected: 08/04/16 06:55				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117270		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.0519	1.3	mg/L	0.0010	1	29139-158		08/10/16 18:07	
Lead	ND	0.02	mg/L	0.0002	1	29139-158		08/10/16 18:07	

Sample: G141-A		Collected: 08/04/16 07:09				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117271		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.296	1.3	mg/L	0.0010	1	29139-159		08/10/16 18:09	
Lead	0.0013	0.02	mg/L	0.0002	1	29139-159		08/10/16 18:09	

Sample: G141C-A		Collected: 08/04/16 07:10				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117272		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.256	1.3	mg/L	0.0010	1	29139-164		08/10/16 18:20	
Lead	0.0016	0.02	mg/L	0.0002	1	29139-164		08/10/16 18:20	

Sample: G142B-A		Collected: 08/04/16 07:11				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117273		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.375	1.3	mg/L	0.0010	1	29139-165		08/10/16 18:22	

Lead	0.0014	0.02	mg/L	0.0002	1	29139-165		08/10/16 18:22	

Sample: G142C-A — Collected: 08/04/16 07:12 — Temp: 26 C — Matrix: Drinking Water
Lab ID: 117274 — Received: 08/04/16 14:50 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.382	1.3	mg/L	0.0010	1	29139-166		08/10/16 18:25	
Lead	0.0029	0.02	mg/L	0.0002	1	29139-166		08/10/16 18:25	

Sample: G143-A — Collected: 08/04/16 07:13 — Temp: 26 C — Matrix: Drinking Water
Lab ID: 117275 — Received: 08/04/16 14:50 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.147	1.3	mg/L	0.0010	1	29139-167		08/10/16 18:27	
Lead	0.0007	0.02	mg/L	0.0002	1	29139-167		08/10/16 18:27	

Sample: G146A-A — Collected: 08/04/16 07:14 — Temp: 26 C — Matrix: Drinking Water
Lab ID: 117276 — Received: 08/04/16 14:50 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.412	1.3	mg/L	0.0010	1	29139-168		08/10/16 18:29	
Lead	0.0336	0.02	mg/L	0.0002	1	29139-168		08/10/16 18:29	

Sample: H110-A — Collected: 08/04/16 09:27 — Temp: 26 C — Matrix: Drinking Water
Lab ID: 117277 — Received: 08/04/16 14:50 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.280	1.3	mg/L	0.0010	1	29163-24		08/15/16 16:27	
Lead	0.0072	0.02	mg/L	0.0002	1	29163-24		08/15/16 16:27	

Sample: H111-A-1 — Collected: 08/04/16 09:28 — Temp: 26 C — Matrix: Drinking Water
Lab ID: 117278 — Received: 08/04/16 14:50 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.162	1.3	mg/L	0.0010	1	29139-169		08/10/16 18:31	
Lead	0.0057	0.02	mg/L	0.0002	1	29139-169		08/10/16 18:31	

Sample: H111-A-2 — Collected: 08/04/16 09:29 — Temp: 26 C — Matrix: Drinking Water
Lab ID: 117279 — Received: 08/04/16 14:50 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.245	1.3	mg/L	0.0010	1	29139-170		08/10/16 18:34	
Lead	0.0035	0.02	mg/L	0.0002	1	29139-170		08/10/16 18:34	

Sample: H116-A — Collected: 08/04/16 09:32 — Temp: 26 C — Matrix: Drinking Water
Lab ID: 117280 — Received: 08/04/16 14:50 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.260	1.3	mg/L	0.0010	1	29139-171		08/10/16 18:36	
Lead	0.0011	0.02	mg/L	0.0002	1	29139-171		08/10/16 18:36	

Sample: H117-A-1 — Collected: 08/04/16 09:23 — Temp: 26 C — Matrix: Drinking Water
Lab ID: 117281 — Received: 08/04/16 14:50 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									

Copper	0.554	1.3	mg/L	0.0010	1	29139-172		08/10/16 18:38
Lead	0.0005	0.02	mg/L	0.0002	1	29139-172		08/10/16 18:38

Sample: H117-A-2 Collected: 08/04/16 09:24 Temp: 26 C Matrix: Drinking Water
Lab ID: 117282 Received: 08/04/16 14:50 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.533	1.3	mg/L	0.0010	1	29139-177		08/10/16 18:50	
Lead	0.0015	0.02	mg/L	0.0002	1	29139-177		08/10/16 18:50	

Sample: H117-A-3 Collected: 08/04/16 09:25 Temp: 26 C Matrix: Drinking Water
Lab ID: 117283 Received: 08/04/16 14:50 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.537	1.3	mg/L	0.0010	1	29139-178		08/10/16 18:52	
Lead	0.0011	0.02	mg/L	0.0002	1	29139-178		08/10/16 18:52	

Sample: H117-A-4 Collected: 08/04/16 09:26 Temp: 26 C Matrix: Drinking Water
Lab ID: 117284 Received: 08/04/16 14:50 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.292	1.3	mg/L	0.0010	1	29139-179		08/10/16 18:54	
Lead	0.0006	0.02	mg/L	0.0002	1	29139-179		08/10/16 18:54	

Sample: H118-A-1 Collected: 08/04/16 09:19 Temp: 26 C Matrix: Drinking Water
Lab ID: 117285 Received: 08/04/16 14:50 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.244	1.3	mg/L	0.0010	1	29139-180		08/10/16 18:56	
Lead	0.0008	0.02	mg/L	0.0002	1	29139-180		08/10/16 18:56	

Sample: H118-A-2 Collected: 08/04/16 09:20 Temp: 26 C Matrix: Drinking Water
Lab ID: 117286 Received: 08/04/16 14:50 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.275	1.3	mg/L	0.0010	1	29139-181		08/10/16 18:58	
Lead	0.0013	0.02	mg/L	0.0002	1	29139-181		08/10/16 18:58	

Sample: H118-A-3 Collected: 08/04/16 09:21 Temp: 26 C Matrix: Drinking Water
Lab ID: 117287 Received: 08/04/16 14:50 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.256	1.3	mg/L	0.0010	1	29139-182		08/10/16 19:01	
Lead	0.0008	0.02	mg/L	0.0002	1	29139-182		08/10/16 19:01	

Sample: H118-A-4 Collected: 08/04/16 09:22 Temp: 26 C Matrix: Drinking Water
Lab ID: 117288 Received: 08/04/16 14:50 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.247	1.3	mg/L	0.0010	1	29139-183		08/10/16 19:03	
Lead	0.0013	0.02	mg/L	0.0002	1	29139-183		08/10/16 19:03	

Sample: H120-A-1 Collected: 08/04/16 09:33 Temp: 26 C Matrix: Drinking Water
Lab ID: 117289 Received: 08/04/16 14:50 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes

Method: EPA 200.8									
Copper	0.529	1.3	mg/L	0.0010	1	29139-184		08/10/16 19:05	
Lead	0.0003	0.02	mg/L	0.0002	1	29139-184		08/10/16 19:05	

Sample: H120-A-2		Collected: 08/04/16 09:34				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117290		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.384	1.3	mg/L	0.0010	1	29139-185		08/10/16 19:08	
Lead	0.0022	0.02	mg/L	0.0002	1	29139-185		08/10/16 19:08	

Sample: H120-A-3		Collected: 08/04/16 09:35				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117291		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.326	1.3	mg/L	0.0010	1	29139-186		08/10/16 19:10	
Lead	0.0008	0.02	mg/L	0.0002	1	29139-186		08/10/16 19:10	

Sample: H120-A-4		Collected: 08/04/16 09:36				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117292		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.177	1.3	mg/L	0.0010	1	29139-192		08/10/16 19:24	
Lead	0.0019	0.02	mg/L	0.0002	1	29139-192		08/10/16 19:24	

Sample: H121-A-1		Collected: 08/04/16 09:37				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117293		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.286	1.3	mg/L	0.0010	1	29139-193		08/10/16 19:26	
Lead	0.0011	0.02	mg/L	0.0002	1	29139-193		08/10/16 19:26	

Sample: H121-A-2		Collected: 08/04/16 09:38				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117294		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.308	1.3	mg/L	0.0010	1	29139-194		08/10/16 19:28	
Lead	0.0026	0.02	mg/L	0.0002	1	29139-194		08/10/16 19:28	

Sample: H121-A-3		Collected: 08/04/16 09:39				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117295		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.322	1.3	mg/L	0.0010	1	29139-195		08/10/16 19:31	
Lead	0.0035	0.02	mg/L	0.0002	1	29139-195		08/10/16 19:31	

Sample: H121-A-4		Collected: 08/04/16 09:40				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117296		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.311	1.3	mg/L	0.0010	1	29139-196		08/10/16 19:33	
Lead	0.0017	0.02	mg/L	0.0002	1	29139-196		08/10/16 19:33	

Sample: H132-C		Collected: 08/04/16 09:15				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117297		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**

Method: EPA 200.8									
Copper	0.568	1.3	mg/L	0.0010	1	29139-197		08/10/16 19:35	
Lead	0.0011	0.02	mg/L	0.0002	1	29139-197		08/10/16 19:35	

Sample: H132-D		Collected: 08/04/16 09:16				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 117298		Received: 08/04/16 14:50				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.358	1.3	mg/L	0.0010	1	29139-198		08/10/16 19:38	
Lead	0.0018	0.02	mg/L	0.0002	1	29139-198		08/10/16 19:38	

Abbreviations

MRL	Method Reporting Limit
ND	None Detected at or above the MRL
Limit	Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

Units of Measure:

mg/L	Milligrams Per Liter

Chain of Custody Record-Water Samples

001-West Linn High School: 5464 West "A" St., West Linn, OR 97068

Location/Site	Date Collected	Collector's Name	Time	Date Delivered
A107-A	8/4/2016	Steve Matthias	6:05 AM	8/4/2016
A107-B	8/4/2016	Steve Matthias	6:06 AM	8/4/2016
B107-A	8/4/2016	Steve Matthias	6:07 AM	8/4/2016
B107-B	8/4/2016	Steve Matthias	6:08 AM	8/4/2016
C101-A-1	8/4/2016	Steve Matthias	6:09 AM	8/4/2016
C101-A-2	8/4/2016	Steve Matthias	6:10 AM	8/4/2016
C101-A-3	8/4/2016	Steve Matthias	6:11 AM	8/4/2016
C101-A-4	8/4/2016	Steve Matthias	6:12 AM	8/4/2016
C101B-A	8/4/2016	Steve Matthias	6:13 AM	8/4/2016
C102-A-1	8/4/2016	Steve Matthias	6:20 AM	8/4/2016
C102-A-2	8/4/2016	Steve Matthias	6:21 AM	8/4/2016
C102-A-3	8/4/2016	Steve Matthias	6:22 AM	8/4/2016
C102-A-4	8/4/2016	Steve Matthias	6:23 AM	8/4/2016
C102-A-5	8/4/2016	Steve Matthias	6:24 AM	8/4/2016
C102-A-6	8/4/2016	Steve Matthias	6:25 AM	8/4/2016
C102-A-7	8/4/2016	Steve Matthias	6:27 AM	8/4/2016
C102A-A	8/4/2016	Steve Matthias	6:26 AM	8/4/2016
C103-A-1	8/4/2016	Steve Matthias	6:27 AM	8/4/2016
C103-A-2	8/4/2016	Steve Matthias	6:28 AM	8/4/2016
C103-A-3	8/4/2016	Steve Matthias	6:29 AM	8/4/2016
C103-A-4	8/4/2016	Steve Matthias	6:30 AM	8/4/2016
C103-A-5	8/4/2016	Steve Matthias	6:31 AM	8/4/2016
C103-A-6	8/4/2016	Steve Matthias	6:32 AM	8/4/2016
C103-A-7	8/4/2016	Steve Matthias	6:33 AM	8/4/2016
C104-A-1	8/4/2016	Steve Matthias	6:34 AM	8/4/2016
C104-A-2	8/4/2016	Steve Matthias	6:35 AM	8/4/2016
C104-A-3	8/4/2016	Steve Matthias	6:36 AM	8/4/2016
C104-A-4	8/4/2016	Steve Matthias	6:37 AM	8/4/2016
C104-A-5	8/4/2016	Steve Matthias	6:38 AM	8/4/2016
C104-A-6	8/4/2016	Steve Matthias	6:39 AM	8/4/2016
C104-A-7	8/4/2016	Steve Matthias	6:40 AM	8/4/2016
C105B-A	8/4/2016	Steve Matthias	7:27 AM	8/4/2016
C106-A-1	8/4/2016	Steve Matthias	7:28 AM	8/4/2016
C106-A-2	8/4/2016	Steve Matthias	7:29 AM	8/4/2016
C106-A-3	8/4/2016	Steve Matthias	7:30 AM	8/4/2016

L1608427
Page 1 of 5

26°C
No cooling

Stephen Matthias 8-4-16
Collector's Signature Date

MRH 8.4.16 1450
Laboratory Signiture Date

Chain of Custody Record-Water Samples
001-West Linn High School: 5464 West "A" St., West Linn, OR 97068

C106-A-4	8/4/2016	Steve Matthias	7:31 AM	8/4/2016
C106-A-5	8/4/2016	Steve Matthias	7:32 AM	8/4/2016
C106-A-6	8/4/2016	Steve Matthias	7:33 AM	8/4/2016
C106-A-7	8/4/2016	Steve Matthias	7:34 AM	8/4/2016
C110-C-1	8/4/2016	Steve Matthias	7:35 AM	8/4/2016
C110-C-2	8/4/2016	Steve Matthias	7:36 AM	8/4/2016
C113-C-1	8/4/2016	Steve Matthias	7:37 AM	8/4/2016
C113-C-2	8/4/2016	Steve Matthias	7:38 AM	8/4/2016
D101A-A	8/4/2016	Steve Matthias	7:39 AM	8/4/2016
D101B-A	8/4/2016	Steve Matthias	7:40 AM	8/4/2016
D103B-A	8/4/2016	Steve Matthias	7:41 AM	8/4/2016
D103-A-1				
D103-A-2				
D103-A-3				
E107-A	8/4/2016	Steve Matthias	7:42 AM	8/4/2016
E107-B	8/4/2016	Steve Matthias	7:43 AM	8/4/2016
F103-A	8/4/2016	Steve Matthias	7:44 AM	8/4/2016
A207-A	8/4/2016	Steve Matthias	7:50 AM	8/4/2016
A207-B	8/4/2016	Steve Matthias	7:51 AM	8/4/2016
B207-A	8/4/2016	Steve Matthias	7:52 AM	8/4/2016
B207-B	8/4/2016	Steve Matthias	7:53 AM	8/4/2016
C201-A-1	8/4/2016	Steve Matthias	8:12 AM	8/4/2016
C201-A-2	8/4/2016	Steve Matthias	8:13 AM	8/4/2016
C201-A-3	8/4/2016	Steve Matthias	8:14 AM	8/4/2016
C201-A-4	8/4/2016	Steve Matthias	8:15 AM	8/4/2016
C202-A-1	8/4/2016	Steve Matthias	8:16 AM	8/4/2016
C202-A-2	8/4/2016	Steve Matthias	8:17 AM	8/4/2016
C202-A-3	8/4/2016	Steve Matthias	8:18 AM	8/4/2016
C202-A-4	8/4/2016	Steve Matthias	8:19 AM	8/4/2016
C202-A-5	8/4/2016	Steve Matthias	8:20 AM	8/4/2016
C202-A-6	8/4/2016	Steve Matthias	8:21 AM	8/4/2016
C202-A-7	8/4/2016	Steve Matthias	8:22 AM	8/4/2016
C202A-A	8/4/2016	Steve Matthias	8:23 AM	8/4/2016
C203-A-1	8/4/2016	Steve Matthias	8:24 AM	8/4/2016
C203-A-2	8/4/2016	Steve Matthias	8:25 AM	8/4/2016
C203-A-3	8/4/2016	Steve Matthias	8:26 AM	8/4/2016

L0080437
Page 2 of 5

Stephen J Matthias 8-4-16
Collector's Signature Date

MRH 8.4.16 1450
Laboratory Signiture Date

Chain of Custody Record-Water Samples
001-West Linn High School: 5464 West "A" St., West Linn, OR 97068

C203-A-4	8/4/2016	Steve Matthias	8:27 AM	8/4/2016
C203-A-5	8/4/2016	Steve Matthias	8:28 AM	8/4/2016
C203-A-6	8/4/2016	Steve Matthias	8:29 AM	8/4/2016
C203-A-7	8/4/2016	Steve Matthias	8:30 AM	8/4/2016
C205-A-1	8/4/2016	Steve Matthias	8:42 AM	8/4/2016
C205-A-2	8/4/2016	Steve Matthias	8:43 AM	8/4/2016
C205-A-3	8/4/2016	Steve Matthias	8:44 AM	8/4/2016
C205-A-4	8/4/2016	Steve Matthias	8:45 AM	8/4/2016
C205-A-5	8/4/2016	Steve Matthias	8:46 AM	8/4/2016
C205-A-6	8/4/2016	Steve Matthias	8:47 AM	8/4/2016
C205-A-7	8/4/2016	Steve Matthias	8:48 AM	8/4/2016
C205A-A				
C204-A-1	8/4/2016	Steve Matthias	8:35 AM	8/4/2016
C204-A-2	8/4/2016	Steve Matthias	8:36 AM	8/4/2016
C204-A-3	8/4/2016	Steve Matthias	8:37 AM	8/4/2016
C204-A-4	8/4/2016	Steve Matthias	8:38 AM	8/4/2016
C204-A-5	8/4/2016	Steve Matthias	8:39 AM	8/4/2016
C204-A-6	8/4/2016	Steve Matthias	8:40 AM	8/4/2016
C204-A-7	8/4/2016	Steve Matthias	8:41 AM	8/4/2016
C209-C-1	8/4/2016	Steve Matthias	8:53 AM	8/4/2016
C209-C-2	8/4/2016	Steve Matthias	8:54 AM	8/4/2016
C212-C-1	8/4/2016	Steve Matthias	9:03 AM	8/4/2016
C212-C-2	8/4/2016	Steve Matthias	9:03 AM	8/4/2016
D206-A				
D206-B	8/4/2016	Steve Matthias	7:57 AM	8/4/2016
E207-A	8/4/2016	Steve Matthias	7:54 AM	8/4/2016
E207-B	8/4/2016	Steve Matthias	7:55 AM	8/4/2016
F210-A				
F210A-A				
F210B-A				
G204-C-1	8/4/2016	Steve Matthias	6:56 AM	8/4/2016
G204-C-2	8/4/2016	Steve Matthias	6:57 AM	8/4/2016
G207-A	8/4/2016	Steve Matthias	6:58 AM	8/4/2016
G208A-A-1	8/4/2016	Steve Matthias	6:59 AM	8/4/2016
G208A-A-2	8/4/2016	Steve Matthias	7:00 AM	8/4/2016
G208B-A	8/4/2016	Steve Matthias	7:01 AM	8/4/2016

Page 3 of 5
1608043

Steve Matthias 8-4-16
Collector's Signature Date

8.4.16 1450
Laboratory Signiture Date

Chain of Custody Record-Water Samples
001-West Linn High School: 5464 West "A" St., West Linn, OR 97068

G122-A	8/4/2016	Steve Matthias	7:15 AM	8/4/2016
G123-A	8/4/2016	Steve Matthias	7:16 AM	8/4/2016
G127-A	8/4/2016	Steve Matthias	7:17 AM	8/4/2016
G129-A	8/4/2016	Steve Matthias	7:18 AM	8/4/2016
G129A-A	8/4/2016	Steve Matthias	7:19 AM	8/4/2016
G136-C-1	8/4/2016	Steve Matthias	6:53 AM	8/4/2016
G136-C-2	8/4/2016	Steve Matthias	6:54 AM	8/4/2016
G136-D	8/4/2016	Steve Matthias	6:55 AM	8/4/2016
G141-A	8/4/2016	Steve Matthias	7:09 AM	8/4/2016
G141C-A	8/4/2016	Steve Matthias	7:10 AM	8/4/2016
G142B-A	8/4/2016	Steve Matthias	7:11 AM	8/4/2016
G142C-A	8/4/2016	Steve Matthias	7:12 AM	8/4/2016
G143-A	8/4/2016	Steve Matthias	7:13 AM	8/4/2016
G146A-A	8/4/2016	Steve Matthias	7:14 AM	8/4/2016
H108-C-1				
H108-C-2				
H108-D				
H110-A	8/4/2016	Steve Matthias	9:27 AM	8/4/2016
H111-A-1	8/4/2016	Steve Matthias	9:28 AM	8/4/2016
H111-A-2	8/4/2016	Steve Matthias	9:29 AM	8/4/2016
H116-A	8/4/2016	Steve Matthias	9:32 AM	8/4/2016
H117-A-1	8/4/2016	Steve Matthias	9:23 AM	8/4/2016
H117-A-2	8/4/2016	Steve Matthias	9:24 AM	8/4/2016
H117-A-3	8/4/2016	Steve Matthias	9:25 AM	8/4/2016
H117-A-4	8/4/2016	Steve Matthias	9:26 AM	8/4/2016
H118-A-1	8/4/2016	Steve Matthias	9:19 AM	8/4/2016
H118-A-2	8/4/2016	Steve Matthias	9:20 AM	8/4/2016
H118-A-3	8/4/2016	Steve Matthias	9:21 AM	8/4/2016
H118-A-4	8/4/2016	Steve Matthias	9:22 AM	8/4/2016
H120-A-1	8/4/2016	Steve Matthias	9:33 AM	8/4/2016
H120-A-2	8/4/2016	Steve Matthias	9:34 AM	8/4/2016
H120-A-3	8/4/2016	Steve Matthias	9:35 AM	8/4/2016
H120-A-4	8/4/2016	Steve Matthias	9:36 AM	8/4/2016
H121-A-1	8/4/2016	Steve Matthias	9:37 AM	8/4/2016
H121-A-2	8/4/2016	Steve Matthias	9:38 AM	8/4/2016
H121-A-3	8/4/2016	Steve Matthias	9:39 AM	8/4/2016

Collector's Signature Date

Laboratory Signiture 8-4-16 1450 Date

Chain of Custody Record-Water Samples
001-West Linn High School: 5464 West "A" St., West Linn, OR 97068

H121-A-4	8/4/2016	Steve Matthias	9:40 AM	8/4/2016
H132-C	8/4/2016	Steve Matthias	9:15 AM	8/4/2016
H132-D	8/4/2016	Steve Matthias	9:16 AM	8/4/2016
H003-C				
H003C-A				
H005A-A				
H007-A				
H007-C				
H010A-A				
H015-A-1				
H015-A-2				
H021-C-1				
H021-C-2				
H021-D				
H022-A				
H024-A				
M001B-A-1				
M001B-A-2				
M001B-A-3				
M001B-A-4				
M001C-A-1				
M001C-A-2				
M001C-A-3				
M001C-A-4				
M004-D				
M004-C-1				
M004-C-2				
M040A-A				
M043-A				
M050-C-1				
M050-C-2				
M050C-A				
M050D-A				
M055-A				

Steve Matthias 8-4-16
Collector's Signature Date

MRH 8.4.16 1450
Laboratory Signiture Date

60801137
Page 5 of 5

Pixis Labs
12423 NE Whitaker Way
Portland, OR 97230
503-254-1794

Job Number:	6080509
Report Date:	08/30/2016
ORELAP #:	OR100028
Project No:	001-West Linn High School

Cover Letter

Pat McGough
West Linn School District
2755 SW Borland
West Linn, OR 97068

Dear Pat McGough,

Enclosed please find Pixis Labs analytical report for samples received as order number 6080509 on 08/05/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed
Mark Leed
Client Services

Pixis Labs
12423 NE Whitaker Way
Portland, OR 97230
503-254-1794

Job Number: 6080509
Report Date: 08/30/2016
ORELAP #: OR100028
Project No: 001-West Linn High School

Sample Results

Sample: C205A-A | Collected: 08/05/16 06:32 | Temp: 24 C | Matrix: Drinking Water
Lab ID: 117387 | Received: 08/05/16 12:38 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.232	1.3	mg/L	0.0010	1	29163-51		08/15/16 17:25	
Lead	0.0061	0.02	mg/L	0.0002	1	29163-51		08/15/16 17:25	

Sample: D206-A | Collected: 08/05/16 06:33 | Temp: 24 C | Matrix: Drinking Water
Lab ID: 117389 | Received: 08/05/16 12:38 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.125	1.3	mg/L	0.0010	1	29163-52		08/15/16 17:27	
Lead	0.0008	0.02	mg/L	0.0002	1	29163-52		08/15/16 17:27	

Sample: C206B-A | Collected: 08/05/16 06:34 | Temp: 24 C | Matrix: Drinking Water
Lab ID: 117390 | Received: 08/05/16 12:38 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.357	1.3	mg/L	0.0010	1	29163-53		08/15/16 17:29	
Lead	0.0023	0.02	mg/L	0.0002	1	29163-53		08/15/16 17:29	

Sample: F210-A | Collected: 08/05/16 06:35 | Temp: 24 C | Matrix: Drinking Water
Lab ID: 117391 | Received: 08/05/16 12:38 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.154	1.3	mg/L	0.0010	1	29163-54		08/15/16 17:31	
Lead	0.0009	0.02	mg/L	0.0002	1	29163-54		08/15/16 17:31	

Sample: F210A-A | Collected: 08/05/16 06:36 | Temp: 24 C | Matrix: Drinking Water
Lab ID: 117393 | Received: 08/05/16 12:38 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.323	1.3	mg/L	0.0010	1	29163-55		08/15/16 17:34	
Lead	0.0018	0.02	mg/L	0.0002	1	29163-55		08/15/16 17:34	

Sample: F210B-A | Collected: 08/05/16 06:37 | Temp: 24 C | Matrix: Drinking Water
Lab ID: 117394 | Received: 08/05/16 12:38 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0985	1.3	mg/L	0.0010	1	29163-56		08/15/16 17:36	
Lead	0.0031	0.02	mg/L	0.0002	1	29163-56		08/15/16 17:36	

Sample: D103-A-1 | Collected: 08/05/16 06:28 | Temp: 24 C | Matrix: Drinking Water
Lab ID: 117395 | Received: 08/05/16 12:38 | Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.409	1.3	mg/L	0.0010	1	29163-57		08/15/16 17:38	

Lead	0.0050	0.02	mg/L	0.0002	1	29163-57		08/15/16 17:38	

Sample: D103-A-2	Collected: 08/05/16 06:29	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117396	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.181	1.3	mg/L	0.0010	1	29163-58		08/15/16 17:40	
Lead	0.0117	0.02	mg/L	0.0002	1	29163-58		08/15/16 17:40	

Sample: D103-A-3	Collected: 08/05/16 06:30	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117397	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.199	1.3	mg/L	0.0010	1	29163-59		08/15/16 17:42	
Lead	0.0042	0.02	mg/L	0.0002	1	29163-59		08/15/16 17:42	

Sample: H108-C-1	Collected: 08/05/16 06:20	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117398	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.173	1.3	mg/L	0.0010	1	29163-65		08/15/16 17:55	
Lead	0.0002	0.02	mg/L	0.0002	1	29163-65		08/15/16 17:55	

Sample: H108-C-2	Collected: 08/05/16 06:21	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117399	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.111	1.3	mg/L	0.0010	1	29163-66		08/15/16 17:57	
Lead	ND	0.02	mg/L	0.0002	1	29163-66		08/15/16 17:57	

Sample: H108-D	Collected: 08/05/16 06:22	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117400	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.613	1.3	mg/L	0.0010	1	29163-67		08/15/16 18:00	
Lead	ND	0.02	mg/L	0.0002	1	29163-67		08/15/16 18:00	

Sample: H003-C	Collected: 08/05/16 07:07	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117401	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.412	1.3	mg/L	0.0010	1	29163-68		08/15/16 18:02	
Lead	0.0002	0.02	mg/L	0.0002	1	29163-68		08/15/16 18:02	

Sample: H003C-A	Collected: 08/05/16 07:08	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117402	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.468	1.3	mg/L	0.0010	1	29163-69		08/15/16 18:04	
Lead	0.0021	0.02	mg/L	0.0002	1	29163-69		08/15/16 18:04	

Sample: H005A-A	Collected: 08/05/16 07:09	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117403	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									

Copper	0.288	1.3	mg/L	0.0010	1	29163-70		08/15/16 18:06	
Lead	0.0022	0.02	mg/L	0.0002	1	29163-70		08/15/16 18:06	

Sample: H007-A — Collected: 08/05/16 07:10 — Temp: 24 C — Matrix: Drinking Water
Lab ID: 117404 — Received: 08/05/16 12:38 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.327	1.3	mg/L	0.0010	1	29163-71		08/15/16 18:08	
Lead	0.0015	0.02	mg/L	0.0002	1	29163-71		08/15/16 18:08	

Sample: H007-C — Collected: 08/05/16 07:11 — Temp: 24 C — Matrix: Drinking Water
Lab ID: 117405 — Received: 08/05/16 12:38 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.721	1.3	mg/L	0.0010	1	29163-72		08/15/16 18:10	
Lead	ND	0.02	mg/L	0.0002	1	29163-72		08/15/16 18:10	

Sample: H007C-A — Collected: 08/05/16 07:14 — Temp: 24 C — Matrix: Drinking Water
Lab ID: 117406 — Received: 08/05/16 12:38 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.373	1.3	mg/L	0.0010	1	29163-73		08/15/16 18:13	
Lead	0.0011	0.02	mg/L	0.0002	1	29163-73		08/15/16 18:13	

Sample: H007C-C — Collected: 08/05/16 07:15 — Temp: 24 C — Matrix: Drinking Water
Lab ID: 117407 — Received: 08/05/16 12:38 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.510	1.3	mg/L	0.0010	1	29163-74		08/15/16 18:15	
Lead	ND	0.02	mg/L	0.0002	1	29163-74		08/15/16 18:15	

Sample: H011A-A — Collected: 08/05/16 07:16 — Temp: 24 C — Matrix: Drinking Water
Lab ID: 117408 — Received: 08/05/16 12:38 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.178	1.3	mg/L	0.0010	1	29163-79		08/15/16 18:26	
Lead	0.0041	0.02	mg/L	0.0002	1	29163-79		08/15/16 18:26	

Sample: H015-A-1 — Collected: 08/05/16 07:17 — Temp: 24 C — Matrix: Drinking Water
Lab ID: 117409 — Received: 08/05/16 12:38 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.686	1.3	mg/L	0.0010	1	29163-80		08/15/16 18:28	
Lead	0.0008	0.02	mg/L	0.0002	1	29163-80		08/15/16 18:28	

Sample: H015-A-2 — Collected: 08/05/16 07:18 — Temp: 24 C — Matrix: Drinking Water
Lab ID: 117410 — Received: 08/05/16 12:38 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.751	1.3	mg/L	0.0010	1	29163-81		08/15/16 18:30	
Lead	0.0008	0.02	mg/L	0.0002	1	29163-81		08/15/16 18:30	

Sample: H021-C-1 — Collected: 08/05/16 06:47 — Temp: 24 C — Matrix: Drinking Water
Lab ID: 117411 — Received: 08/05/16 12:38 — Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									

Copper	0.170	1.3	mg/L	0.0010	1	29163-82		08/15/16 18:32	
Lead	0.0003	0.02	mg/L	0.0002	1	29163-82		08/15/16 18:32	

Sample: H021-C-2 Collected: 08/05/16 06:48 Temp: 24 C Matrix: Drinking Water
Lab ID: 117412 Received: 08/05/16 12:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.195	1.3	mg/L	0.0010	1	29163-83		08/15/16 18:34	
Lead	0.0002	0.02	mg/L	0.0002	1	29163-83		08/15/16 18:34	

Sample: H021-D Collected: 08/05/16 06:49 Temp: 24 C Matrix: Drinking Water
Lab ID: 117413 Received: 08/05/16 12:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0808	1.3	mg/L	0.0010	1	29163-84		08/15/16 18:37	
Lead	ND	0.02	mg/L	0.0002	1	29163-84		08/15/16 18:37	

Sample: H022-A Collected: 08/05/16 07:05 Temp: 24 C Matrix: Drinking Water
Lab ID: 117414 Received: 08/05/16 12:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.126	1.3	mg/L	0.0010	1	29163-85		08/15/16 18:39	
Lead	0.0004	0.02	mg/L	0.0002	1	29163-85		08/15/16 18:39	

Sample: H024-A-1 Collected: 08/05/16 07:03 Temp: 24 C Matrix: Drinking Water
Lab ID: 117415 Received: 08/05/16 12:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.218	1.3	mg/L	0.0010	1	29163-86		08/15/16 18:41	
Lead	0.0212	0.02	mg/L	0.0002	1	29163-86		08/15/16 18:41	

Sample: H024-A-2 Collected: 08/05/16 07:04 Temp: 24 C Matrix: Drinking Water
Lab ID: 117416 Received: 08/05/16 12:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.188	1.3	mg/L	0.0010	1	29163-87		08/15/16 18:43	
Lead	0.0003	0.02	mg/L	0.0002	1	29163-87		08/15/16 18:43	

Sample: M001B-A-1 Collected: 08/05/16 07:29 Temp: 24 C Matrix: Drinking Water
Lab ID: 117417 Received: 08/05/16 12:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0459	1.3	mg/L	0.0010	1	29163-88		08/15/16 18:45	
Lead	0.0012	0.02	mg/L	0.0002	1	29163-88		08/15/16 18:45	

Sample: M001B-A-2 Collected: 08/05/16 07:30 Temp: 24 C Matrix: Drinking Water
Lab ID: 117418 Received: 08/05/16 12:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0739	1.3	mg/L	0.0010	1	29163-93		08/15/16 18:56	
Lead	0.0026	0.02	mg/L	0.0002	1	29163-93		08/15/16 18:56	

Sample: M001B-A-3 Collected: 08/05/16 07:31 Temp: 24 C Matrix: Drinking Water
Lab ID: 117419 Received: 08/05/16 12:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									

Copper	0.126	1.3	mg/L	0.0010	1	29163-94		08/15/16 18:58	
Lead	0.0053	0.02	mg/L	0.0002	1	29163-94		08/15/16 18:58	

Sample: M001B-A-4	Collected: 08/05/16 07:32	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117420	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.0681	1.3	mg/L	0.0010	1	29163-95		08/15/16 19:00	
Lead	0.0014	0.02	mg/L	0.0002	1	29163-95		08/15/16 19:00	

Sample: M001C-A-1	Collected: 08/05/16 07:33	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117421	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.508	1.3	mg/L	0.0010	1	29163-96		08/15/16 19:03	
Lead	0.0036	0.02	mg/L	0.0002	1	29163-96		08/15/16 19:03	

Sample: M001C-A-2	Collected: 08/05/16 07:34	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117422	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.527	1.3	mg/L	0.0010	1	29163-97		08/15/16 19:05	
Lead	0.0027	0.02	mg/L	0.0002	1	29163-97		08/15/16 19:05	

Sample: M001C-A-3	Collected: 08/05/16 07:35	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117423	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.434	1.3	mg/L	0.0010	1	29163-98		08/15/16 19:07	
Lead	0.0036	0.02	mg/L	0.0002	1	29163-98		08/15/16 19:07	

Sample: M001C-A-4	Collected: 08/05/16 07:36	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117424	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.373	1.3	mg/L	0.0010	1	29163-99		08/15/16 19:09	
Lead	0.0035	0.02	mg/L	0.0002	1	29163-99		08/15/16 19:09	

Sample: M004-D	Collected: 08/05/16 07:26	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117425	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.176	1.3	mg/L	0.0010	1	29163-100		08/15/16 19:11	
Lead	0.0004	0.02	mg/L	0.0002	1	29163-100		08/15/16 19:11	

Sample: M004-C-1	Collected: 08/05/16 07:27	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117426	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.322	1.3	mg/L	0.0010	1	29163-101		08/15/16 19:14	
Lead	0.0016	0.02	mg/L	0.0002	1	29163-101		08/15/16 19:14	

Sample: M004-C-2	Collected: 08/05/16 07:28	Temp: 24 C	Matrix: Drinking Water
Lab ID: 117427	Received: 08/05/16 12:38	Evidence of Cooling:N	

Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**

Method: EPA 200.8									
Copper	0.357	1.3	mg/L	0.0010	1	29163-102		08/15/16 19:16	
Lead	0.0013	0.02	mg/L	0.0002	1	29163-102		08/15/16 19:16	

Sample: M040A-A		Collected: 08/05/16 07:38				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 117428		Received: 08/05/16 12:38				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.0351	1.3	mg/L	0.0010	1	29163-107		08/15/16 19:27	
Lead	0.0011	0.02	mg/L	0.0002	1	29163-107		08/15/16 19:27	

Sample: M043-A		Collected: 08/05/16 07:39				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 117429		Received: 08/05/16 12:38				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.346	1.3	mg/L	0.0010	1	29163-108		08/15/16 19:29	
Lead	0.0015	0.02	mg/L	0.0002	1	29163-108		08/15/16 19:29	

Sample: M050-C-1		Collected: 08/05/16 07:40				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 117430		Received: 08/05/16 12:38				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.502	1.3	mg/L	0.0010	1	29163-109		08/15/16 19:31	
Lead	0.0009	0.02	mg/L	0.0002	1	29163-109		08/15/16 19:31	

Sample: M050-C-2		Collected: 08/05/16 07:41				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 117431		Received: 08/05/16 12:38				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.438	1.3	mg/L	0.0010	1	29163-110		08/15/16 19:33	
Lead	0.0009	0.02	mg/L	0.0002	1	29163-110		08/15/16 19:33	

Sample: M050C-A		Collected: 08/05/16 07:42				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 117432		Received: 08/05/16 12:38				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.0372	1.3	mg/L	0.0010	1	29163-111		08/15/16 19:35	
Lead	0.0010	0.02	mg/L	0.0002	1	29163-111		08/15/16 19:35	

Sample: M050D-A		Collected: 08/05/16 07:43				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 117433		Received: 08/05/16 12:38				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.0486	1.3	mg/L	0.0010	1	29163-112		08/15/16 19:38	
Lead	0.0008	0.02	mg/L	0.0002	1	29163-112		08/15/16 19:38	

Sample: M055-A		Collected: 08/05/16 07:44				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 117434		Received: 08/05/16 12:38				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.442	1.3	mg/L	0.0010	1	29163-113		08/15/16 19:40	
Lead	0.0014	0.02	mg/L	0.0002	1	29163-113		08/15/16 19:40	

Sample: M060A-A		Collected: 08/05/16 07:45				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 117435		Received: 08/05/16 12:38				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**

Method: EPA 200.8									
Copper	0.231	1.3	mg/L	0.0010	1	29163-114		08/15/16 19:42	
Lead	0.0018	0.02	mg/L	0.0002	1	29163-114		08/15/16 19:42	

Sample: M070A-A		Collected: 08/05/16 07:46				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 117436		Received: 08/05/16 12:38				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.386	1.3	mg/L	0.0010	1	29163-115		08/15/16 19:44	
Lead	0.0050	0.02	mg/L	0.0002	1	29163-115		08/15/16 19:44	

Sample: Concessions 1-A		Collected: 08/05/16 06:50				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 117437		Received: 08/05/16 12:38				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.263	1.3	mg/L	0.0010	1	29163-116		08/15/16 19:46	
Lead	0.0003	0.02	mg/L	0.0002	1	29163-116		08/15/16 19:46	

Sample: Boys RR 1-A		Collected: 08/05/16 06:51				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 117438		Received: 08/05/16 12:38				Evidence of Cooling:N			
Analyte	**Result**	**Limit**	**Units**	**MRL**	**Dil.**	**Batch**	**Start/Extract**	**Analyzed**	**Notes**
Method: EPA 200.8									
Copper	0.129	1.3	mg/L	0.0010	1	29163-122		08/15/16 19:59	
Lead	0.0005	0.02	mg/L	0.0002	1	29163-122		08/15/16 19:59	

Abbreviations

MRL	Method Reporting Limit
ND	None Detected at or above the MRL
Limit	Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

Units of Measure:

mg/L	Milligrams Per Liter

Chain of Custody Record-Water Samples
001-West Linn High School: 5464 West "A" St., West Linn, OR 97068

Location/Site	Date Collected	Collector's Name	Time	Date Delivered
C205A-A	8/5/2016	Steve Matthias	6:32 AM	8/5/2016
D206-A	8/5/2016	Steve Matthias	6:33 AM	8/5/2016
C206B-A	8/5/2016	Steve Matthias	6:34 AM	8/5/2016
F210-A	8/5/2016	Steve Matthias	6:35 AM	8/5/2016
F210A-A	8/5/2016	Steve Matthias	6:36 AM	8/5/2016
F210B-A	8/5/2016	Steve Matthias	6:37 AM	8/5/2016
D103-A-1	8/5/2016	Steve Matthias	6:28 AM	8/5/2016
D103-A-2	8/5/2016	Steve Matthias	6:29 AM	8/5/2016
D103-A-3	8/5/2016	Steve Matthias	6:30 AM	8/5/2016
H108-C-1	8/5/2016	Steve Matthias	6:20 AM	8/5/2016
H108-C-2	8/5/2016	Steve Matthias	6:21 AM	8/5/2016
H108-D	8/5/2016	Steve Matthias	6:22 AM	8/5/2016
H003-C	8/5/2016	Steve Matthias	7:07 AM	8/5/2016
H003C-A	8/5/2016	Steve Matthias	7:08 AM	8/5/2016
H005A-A	8/5/2016	Steve Matthias	7:09 AM	8/5/2016
H007-A	8/5/2016	Steve Matthias	7:10 AM	8/5/2016
H007-C	8/5/2016	Steve Matthias	7:11 AM	8/5/2016
H007C-A	8/5/2016	Steve Matthias	7:14 AM	8/5/2016
H007C-C	8/5/2016	Steve Matthias	7:15 AM	8/5/2016
H011A-A	8/5/2016	Steve Matthias	7:16 AM	8/5/2016
H015-A-1	8/5/2016	Steve Matthias	7:17 AM	8/5/2016
H015-A-2	8/5/2016	Steve Matthias	7:18 AM	8/5/2016
H021-C-1	8/5/2016	Steve Matthias	6:47 AM	8/5/2016
H021-C-2	8/5/2016	Steve Matthias	6:48 AM	8/5/2016
H021-D	8/5/2016	Steve Matthias	6:49 AM	8/5/2016
H022-A	8/5/2016	Steve Matthias	7:05 AM	8/5/2016
H024-A-1	8/5/2016	Steve Matthias	7:03 AM	8/5/2016
H024-A-2	8/5/2016	Steve Matthias	7:04 AM	8/5/2016
M001B-A-1	8/5/2016	Steve Matthias	7:29 AM	8/5/2016
M001B-A-2	8/5/2016	Steve Matthias	7:30 AM	8/5/2016
M001B-A-3	8/5/2016	Steve Matthias	7:31 AM	8/5/2016
M001B-A-4	8/5/2016	Steve Matthias	7:32 AM	8/5/2016
M001C-A-1	8/5/2016	Steve Matthias	7:33 AM	8/5/2016
M001C-A-2	8/5/2016	Steve Matthias	7:34 AM	8/5/2016
M001C-A-3	8/5/2016	Steve Matthias	7:35 AM	8/5/2016

WESTLINNSC 6080509
West Linn School District

6080509
Page 1 of 2

Steve Matthias 8-5-16
Collector's Signature Date

8/5/16, 1238
Laboratory Signiture Date

24°C

Chain of Custody Record-Water Samples

001-West Linn High School: 5464 West "A" St., West Linn, OR 97068

M001C-A-4	8/5/2016	Steve Matthias	7:36 AM	8/5/2016
M004-D	8/5/2016	Steve Matthias	7:26 AM	8/5/2016
M004-C-1	8/5/2016	Steve Matthias	7:27 AM	8/5/2016
M004-C-2	8/5/2016	Steve Matthias	7:28 AM	8/5/2016
M040A-A	8/5/2016	Steve Matthias	7:38 AM	8/5/2016
M043-A	8/5/2016	Steve Matthias	7:39 AM	8/5/2016
M050-C-1	8/5/2016	Steve Matthias	7:40 AM	8/5/2016
M050-C-2	8/5/2016	Steve Matthias	7:41 AM	8/5/2016
M050C-A	8/5/2016	Steve Matthias	7:42 AM	8/5/2016
M050D-A	8/5/2016	Steve Matthias	7:43 AM	8/5/2016
M055-A	8/5/2016	Steve Matthias	7:44 AM	8/5/2016
M060A-A	8/5/2016	Steve Matthias	7:45 AM	8/5/2016
M070A-A	8/5/2016	Steve Matthias	7:46 AM	8/5/2016
Consessions 1-A	8/5/2016	Steve Matthias	6:50 AM	8/5/2016
Boy's RR 1-A	8/5/2016	Steve Matthias	6:51 AM	8/5/2016

1608069
Page 2 of 2

8-5-16
Collector's Signature Date

8/5/16, 1238
Laboratory Signiture Date

24C