

PIXIS Labs

Accurate. Reliable. On Time.

Pixis Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

Job Number: 6071335

Report Date: 07/21/2016

ORELAP #: OR100028

Project No: 017-Boeckman Creek

Cover Letter

Pat McGough
West Linn School District
2755 SW Borland
West Linn, OR 97068

Dear Pat McGough,

Enclosed please find Pixis Labs analytical report for samples received as order number 6071335 on 07/13/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed

Richard Reid

Project Manager

Sample Results

Sample: A100-A		Collected: 07/13/16 06:21		Temp: 26 C		Matrix: Drinking Water			
Lab ID: 114170		Received: 07/13/16 13:38		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0536	1.3	mg/L	0.0010	1	28845-199		07/15/16 19:01	
Lead	0.0023	0.02	mg/L	0.0002	1	28845-199		07/15/16 19:01	
Sample: A100-B		Collected: 07/13/16 06:22		Temp: 26 C		Matrix: Drinking Water			
Lab ID: 114171		Received: 07/13/16 13:38		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0545	1.3	mg/L	0.0010	1	28845-204		07/15/16 19:10	
Lead	0.0002	0.02	mg/L	0.0002	1	28845-204		07/15/16 19:10	
Sample: A101-A		Collected: 07/13/16 06:24		Temp: 26 C		Matrix: Drinking Water			
Lab ID: 114172		Received: 07/13/16 13:38		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0510	1.3	mg/L	0.0010	1	28845-205		07/15/16 19:12	
Lead	ND	0.02	mg/L	0.0002	1	28845-205		07/15/16 19:12	
Sample: A101-B		Collected: 07/13/16 06:25		Temp: 26 C		Matrix: Drinking Water			
Lab ID: 114173		Received: 07/13/16 13:38		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0617	1.3	mg/L	0.0010	1	28845-206		07/15/16 19:14	
Lead	0.0020	0.02	mg/L	0.0002	1	28845-206		07/15/16 19:14	
Sample: A102-A		Collected: 07/13/16 06:28		Temp: 26 C		Matrix: Drinking Water			
Lab ID: 114174		Received: 07/13/16 13:38		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0542	1.3	mg/L	0.0010	1	28845-207		07/15/16 19:16	
Lead	0.0012	0.02	mg/L	0.0002	1	28845-207		07/15/16 19:16	
Sample: A102-B		Collected: 07/13/16 06:29		Temp: 26 C		Matrix: Drinking Water			
Lab ID: 114175		Received: 07/13/16 13:38		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0565	1.3	mg/L	0.0010	1	28845-208		07/15/16 19:18	
Lead	0.0033	0.02	mg/L	0.0002	1	28845-208		07/15/16 19:18	
Sample: A103-A		Collected: 07/13/16 06:30		Temp: 26 C		Matrix: Drinking Water			
Lab ID: 114176		Received: 07/13/16 13:38		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0558	1.3	mg/L	0.0010	1	28845-209		07/15/16 19:20	

Lead 0.0011 0.02 mg/L 0.0002 1 28845-209 07/15/16 19:20

Sample: A103-B Collected: 07/13/16 06:31 Temp: 26 C Matrix: Drinking Water
Lab ID: 114177 Received: 07/13/16 13:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0604	1.3	mg/L	0.0010	1	28845-210		07/15/16 19:22	
--------	--------	-----	------	--------	---	-----------	--	----------------	--

Lead	0.0008	0.02	mg/L	0.0002	1	28845-210		07/15/16 19:22	
------	--------	------	------	--------	---	-----------	--	----------------	--

Sample: A107-C-1 Collected: 07/13/16 06:35 Temp: 26 C Matrix: Drinking Water
Lab ID: 114178 Received: 07/13/16 13:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0686	1.3	mg/L	0.0010	1	28845-211		07/15/16 19:24	
--------	--------	-----	------	--------	---	-----------	--	----------------	--

Lead	0.0024	0.02	mg/L	0.0002	1	28845-211		07/15/16 19:24	
------	--------	------	------	--------	---	-----------	--	----------------	--

Sample: A107-C-2 Collected: 07/13/16 06:36 Temp: 26 C Matrix: Drinking Water
Lab ID: 114179 Received: 07/13/16 13:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0662	1.3	mg/L	0.0010	1	28845-212		07/15/16 19:26	
--------	--------	-----	------	--------	---	-----------	--	----------------	--

Lead	0.0007	0.02	mg/L	0.0002	1	28845-212		07/15/16 19:26	
------	--------	------	------	--------	---	-----------	--	----------------	--

Sample: A110-A Collected: 07/13/16 06:43 Temp: 26 C Matrix: Drinking Water
Lab ID: 114180 Received: 07/13/16 13:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0568	1.3	mg/L	0.0010	1	28845-213		07/15/16 19:28	
--------	--------	-----	------	--------	---	-----------	--	----------------	--

Lead	0.0015	0.02	mg/L	0.0002	1	28845-213		07/15/16 19:28	
------	--------	------	------	--------	---	-----------	--	----------------	--

Sample: A110-B Collected: 07/13/16 06:44 Temp: 26 C Matrix: Drinking Water
Lab ID: 114181 Received: 07/13/16 13:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0587	1.3	mg/L	0.0010	1	28845-218		07/15/16 19:37	
--------	--------	-----	------	--------	---	-----------	--	----------------	--

Lead	0.0016	0.02	mg/L	0.0002	1	28845-218		07/15/16 19:37	
------	--------	------	------	--------	---	-----------	--	----------------	--

Sample: A111-A Collected: 07/13/16 06:46 Temp: 26 C Matrix: Drinking Water
Lab ID: 114182 Received: 07/13/16 13:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0489	1.3	mg/L	0.0010	1	28845-219		07/15/16 19:39	
--------	--------	-----	------	--------	---	-----------	--	----------------	--

Lead	ND	0.02	mg/L	0.0002	1	28845-219		07/15/16 19:39	
------	----	------	------	--------	---	-----------	--	----------------	--

Sample: A111-B Collected: 07/13/16 06:47 Temp: 26 C Matrix: Drinking Water
Lab ID: 114183 Received: 07/13/16 13:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0510	1.3	mg/L	0.0010	1	28845-220		07/15/16 19:41	
--------	--------	-----	------	--------	---	-----------	--	----------------	--

Lead	0.0003	0.02	mg/L	0.0002	1	28845-220		07/15/16 19:41	
------	--------	------	------	--------	---	-----------	--	----------------	--

Sample: A112-A Collected: 07/13/16 06:48 Temp: 26 C Matrix: Drinking Water
Lab ID: 114184 Received: 07/13/16 13:38 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0535	1.3	mg/L	0.0010	1	28845-221		07/15/16 19:43	
Lead	0.0002	0.02	mg/L	0.0002	1	28845-221		07/15/16 19:43	

Sample: A112-B	Collected: 07/13/16 06:49	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114185	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0653	1.3	mg/L	0.0010	1	28845-222		07/15/16 19:45	
Lead	0.0008	0.02	mg/L	0.0002	1	28845-222		07/15/16 19:45	

Sample: A113-A	Collected: 07/13/16 06:50	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114186	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0545	1.3	mg/L	0.0010	1	28845-223		07/15/16 19:47	
Lead	0.0002	0.02	mg/L	0.0002	1	28845-223		07/15/16 19:47	

Sample: A113-B	Collected: 07/13/16 06:51	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114187	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0647	1.3	mg/L	0.0010	1	28845-224		07/15/16 19:49	
Lead	0.0010	0.02	mg/L	0.0002	1	28845-224		07/15/16 19:49	

Sample: A114-A	Collected: 07/13/16 06:52	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114188	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0833	1.3	mg/L	0.0010	1	28845-225		07/15/16 19:51	
Lead	0.0026	0.02	mg/L	0.0002	1	28845-225		07/15/16 19:51	

Sample: A114-B	Collected: 07/13/16 06:53	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114189	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0679	1.3	mg/L	0.0010	1	28845-226		07/15/16 19:53	
Lead	0.0022	0.02	mg/L	0.0002	1	28845-226		07/15/16 19:53	

Sample: A115-A	Collected: 07/13/16 06:54	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114190	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0480	1.3	mg/L	0.0010	1	28845-227		07/15/16 19:55	
Lead	0.0025	0.02	mg/L	0.0002	1	28845-227		07/15/16 19:55	

Sample: A115-B	Collected: 07/13/16 06:55	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114191	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.153	1.3	mg/L	0.0010	1	28845-232		07/15/16 20:04	
Lead	0.0176	0.02	mg/L	0.0002	1	28845-232		07/15/16 20:04	

Sample: A122-A	Collected: 07/13/16 07:00	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114192	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									

Copper	0.0442	1.3	mg/L	0.0010	1	28845-233	07/15/16 20:06
Lead	0.0006	0.02	mg/L	0.0002	1	28845-233	07/15/16 20:06

Sample: A122-B	Collected: 07/13/16 07:01	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114193	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0522	1.3	mg/L	0.0010	1	28845-234	07/15/16 20:08
Lead	0.0013	0.02	mg/L	0.0002	1	28845-234	07/15/16 20:08

Sample: A123-A	Collected: 07/13/16 07:02	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114194	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0593	1.3	mg/L	0.0010	1	28845-235	07/15/16 20:10
Lead	0.0017	0.02	mg/L	0.0002	1	28845-235	07/15/16 20:10

Sample: A123-B	Collected: 07/13/16 07:03	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114195	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0664	1.3	mg/L	0.0010	1	28845-236	07/15/16 20:12
Lead	0.0005	0.02	mg/L	0.0002	1	28845-236	07/15/16 20:12

Sample: A124-B	Collected: 07/13/16 07:05	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114196	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0568	1.3	mg/L	0.0010	1	28845-237	07/15/16 20:14
Lead	0.0013	0.02	mg/L	0.0002	1	28845-237	07/15/16 20:14

Sample: A125-A	Collected: 07/13/16 07:06	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114198	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.106	1.3	mg/L	0.0010	1	28845-238	07/15/16 20:16
Lead	0.0007	0.02	mg/L	0.0002	1	28845-238	07/15/16 20:16

Sample: A125-B	Collected: 07/13/16 07:07	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114199	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0684	1.3	mg/L	0.0010	1	28845-239	07/15/16 20:18
Lead	0.0011	0.02	mg/L	0.0002	1	28845-239	07/15/16 20:18

Sample: A126-B	Collected: 07/13/16 07:09	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114201	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0734	1.3	mg/L	0.0010	1	28845-240	07/15/16 20:20
Lead	0.0018	0.02	mg/L	0.0002	1	28845-240	07/15/16 20:20

Sample: A127-A	Collected: 07/13/16 07:10	Temp: 26 C	Matrix: Drinking Water
Lab ID: 114202	Received: 07/13/16 13:38	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0470	1.3	mg/L	0.0010	1	28845-241		07/15/16 20:22	
Lead	0.0008	0.02	mg/L	0.0002	1	28845-241		07/15/16 20:22	
Sample: A127-B		Collected: 07/13/16 07:11			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114203		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0483	1.3	mg/L	0.0010	1	28845-246		07/15/16 20:33	
Lead	0.0006	0.02	mg/L	0.0002	1	28845-246		07/15/16 20:33	
Sample: A128-A		Collected: 07/13/16 07:12			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114204		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0454	1.3	mg/L	0.0010	1	28845-247		07/15/16 20:35	
Lead	0.0009	0.02	mg/L	0.0002	1	28845-247		07/15/16 20:35	
Sample: A128-B		Collected: 07/13/16 07:13			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114205		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0451	1.3	mg/L	0.0010	1	28845-248		07/15/16 20:37	
Lead	0.0010	0.02	mg/L	0.0002	1	28845-248		07/15/16 20:37	
Sample: A134-C		Collected: 07/13/16 06:58			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114206		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0601	1.3	mg/L	0.0010	1	28845-249		07/15/16 20:39	
Lead	ND	0.02	mg/L	0.0002	1	28845-249		07/15/16 20:39	
Sample: A138-A-1		Collected: 07/13/16 07:15			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114207		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0570	1.3	mg/L	0.0010	1	28845-250		07/15/16 20:41	
Lead	0.0008	0.02	mg/L	0.0002	1	28845-250		07/15/16 20:41	
Sample: A138-A-2		Collected: 07/13/16 07:16			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114208		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0565	1.3	mg/L	0.0010	1	28845-251		07/15/16 20:43	
Lead	0.0006	0.02	mg/L	0.0002	1	28845-251		07/15/16 20:43	
Sample: A143-C		Collected: 07/13/16 07:17			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114209		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0526	1.3	mg/L	0.0010	1	28845-252		07/15/16 20:45	
Lead	ND	0.02	mg/L	0.0002	1	28845-252		07/15/16 20:45	
Sample: A143-D		Collected: 07/13/16 07:18			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114210		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes

Method: EPA 200.8									
Copper	0.0737	1.3	mg/L	0.0010	1	28845-253			07/15/16 20:47
Lead	ND	0.02	mg/L	0.0002	1	28845-253			07/15/16 20:47
Sample: A150-A		Collected: 07/13/16 07:21				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 114211		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0576	1.3	mg/L	0.0010	1	28845-254			07/15/16 20:49
Lead	0.0037	0.02	mg/L	0.0002	1	28845-254			07/15/16 20:49
Sample: A150-B		Collected: 07/13/16 07:22				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 114212		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0565	1.3	mg/L	0.0010	1	28845-255			07/15/16 20:51
Lead	0.0007	0.02	mg/L	0.0002	1	28845-255			07/15/16 20:51
Sample: A151-A		Collected: 07/13/16 07:23				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 114213		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0378	1.3	mg/L	0.0010	1	28845-260			07/15/16 21:00
Lead	ND	0.02	mg/L	0.0002	1	28845-260			07/15/16 21:00
Sample: A152-A		Collected: 07/13/16 07:24				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 114214		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0722	1.3	mg/L	0.0010	1	28845-261			07/15/16 21:02
Lead	0.0005	0.02	mg/L	0.0002	1	28845-261			07/15/16 21:02
Sample: A154-A		Collected: 07/13/16 07:25				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 114215		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0567	1.3	mg/L	0.0010	1	28845-262			07/15/16 21:04
Lead	0.0009	0.02	mg/L	0.0002	1	28845-262			07/15/16 21:04
Sample: A159-A		Collected: 07/13/16 07:27				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 114216		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0607	1.3	mg/L	0.0010	1	28845-263			07/15/16 21:06
Lead	0.0015	0.02	mg/L	0.0002	1	28845-263			07/15/16 21:06
Sample: A159-B		Collected: 07/13/16 07:28				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 114217		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0481	1.3	mg/L	0.0010	1	28845-264			07/15/16 21:08
Lead	0.0007	0.02	mg/L	0.0002	1	28845-264			07/15/16 21:08
Sample: A160-A		Collected: 07/13/16 07:29				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 114218		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes

Method: EPA 200.8									
Copper	0.0912	1.3	mg/L	0.0010	1	28845-265			07/15/16 21:10
Lead	0.0006	0.02	mg/L	0.0002	1	28845-265			07/15/16 21:10
Sample: A160-B		Collected: 07/13/16 07:30			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114219		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0700	1.3	mg/L	0.0010	1	28845-266			07/15/16 21:12
Lead	0.0020	0.02	mg/L	0.0002	1	28845-266			07/15/16 21:12
Sample: A161-A		Collected: 07/13/16 07:31			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114220		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.107	1.3	mg/L	0.0010	1	28845-267			07/15/16 21:14
Lead	0.0019	0.02	mg/L	0.0002	1	28845-267			07/15/16 21:14
Sample: A161-B		Collected: 07/13/16 07:32			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114221		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0482	1.3	mg/L	0.0010	1	28845-268			07/15/16 21:16
Lead	0.0004	0.02	mg/L	0.0002	1	28845-268			07/15/16 21:16
Sample: A162-A		Collected: 07/13/16 07:33			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114222		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.436	1.3	mg/L	0.0010	1	28845-269			07/15/16 21:18
Lead	0.0041	0.02	mg/L	0.0002	1	28845-269			07/15/16 21:18
Sample: A162-B		Collected: 07/13/16 07:34			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114223		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0551	1.3	mg/L	0.0010	1	28852-1			07/15/16 21:28
Lead	0.0009	0.02	mg/L	0.0002	1	28852-1			07/15/16 21:28
Sample: A172-A		Collected: 07/13/16 07:36			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114224		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.269	1.3	mg/L	0.0010	1	28852-2			07/15/16 21:30
Lead	0.0017	0.02	mg/L	0.0002	1	28852-2			07/15/16 21:30
Sample: A172-B		Collected: 07/13/16 07:37			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114225		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.207	1.3	mg/L	0.0010	1	28852-3			07/15/16 21:32
Lead	0.0058	0.02	mg/L	0.0002	1	28852-3			07/15/16 21:32
Sample: A173-A		Collected: 07/13/16 07:38			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114226		Received: 07/13/16 13:38			Evidence of Cooling:N				

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0476	1.3	mg/L	0.0010	1	28852-4		07/15/16 21:34	
Lead	0.0009	0.02	mg/L	0.0002	1	28852-4		07/15/16 21:34	
Sample: A173-B		Collected: 07/13/16 07:39			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114227		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0458	1.3	mg/L	0.0010	1	28852-5		07/15/16 21:35	
Lead	0.0004	0.02	mg/L	0.0002	1	28852-5		07/15/16 21:35	
Sample: A174-A		Collected: 07/13/16 07:40			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114228		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.220	1.3	mg/L	0.0010	1	28852-6		07/15/16 21:37	
Lead	0.0014	0.02	mg/L	0.0002	1	28852-6		07/15/16 21:37	
Sample: A174-B		Collected: 07/13/16 07:41			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114229		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0573	1.3	mg/L	0.0010	1	28852-7		07/15/16 21:39	
Lead	ND	0.02	mg/L	0.0002	1	28852-7		07/15/16 21:39	
Sample: A175-A		Collected: 07/13/16 07:42			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114230		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.272	1.3	mg/L	0.0010	1	28852-8		07/15/16 21:41	
Lead	0.0027	0.02	mg/L	0.0002	1	28852-8		07/15/16 21:41	
Sample: A175-B		Collected: 07/13/16 07:43			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114231		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0719	1.3	mg/L	0.0010	1	28852-9		07/15/16 21:43	
Lead	0.0023	0.02	mg/L	0.0002	1	28852-9		07/15/16 21:43	
Sample: A179-C		Collected: 07/13/16 07:35			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114232		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0573	1.3	mg/L	0.0010	1	28852-10		07/15/16 21:45	
Lead	ND	0.02	mg/L	0.0002	1	28852-10		07/15/16 21:45	
Sample: A181-A		Collected: 07/13/16 07:36			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 114233		Received: 07/13/16 13:38			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0987	1.3	mg/L	0.0010	1	28859-8		07/18/16 12:00	
Lead	0.0008	0.02	mg/L	0.0002	1	28859-8		07/18/16 12:00	
Sample: A184-A		Collected: 07/13/16 07:45			Temp: 26 C		Matrix: Drinking Water		

Lab ID: 114234		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0444	1.3	mg/L	0.0010	1	28859-9		07/18/16 12:02	
Lead	0.0004	0.02	mg/L	0.0002	1	28859-9		07/18/16 12:02	
Sample: A185-A		Collected: 07/13/16 07:46				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 114235		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0477	1.3	mg/L	0.0010	1	28859-10		07/18/16 12:04	
Lead	0.0003	0.02	mg/L	0.0002	1	28859-10		07/18/16 12:04	
Sample: B102-C		Collected: 07/13/16 07:51				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 114236		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0653	1.3	mg/L	0.0010	1	28859-11		07/18/16 12:06	
Lead	ND	0.02	mg/L	0.0002	1	28859-11		07/18/16 12:06	
Sample: B111-A		Collected: 07/13/16 07:50				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 114237		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0381	1.3	mg/L	0.0010	1	28859-12		07/18/16 12:08	
Lead	0.0006	0.02	mg/L	0.0002	1	28859-12		07/18/16 12:08	
Sample: B114-A-1		Collected: 07/13/16 07:51				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 114238		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0827	1.3	mg/L	0.0010	1	28859-13		07/18/16 12:10	
Lead	0.0043	0.02	mg/L	0.0002	1	28859-13		07/18/16 12:10	
Sample: B114-A-2		Collected: 07/13/16 07:52				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 114239		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0216	1.3	mg/L	0.0010	1	28859-14		07/18/16 12:12	
Lead	0.0033	0.02	mg/L	0.0002	1	28859-14		07/18/16 12:12	
Sample: B114-A-3		Collected: 07/13/16 07:53				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 114240		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0342	1.3	mg/L	0.0010	1	28859-15		07/18/16 12:14	
Lead	0.0029	0.02	mg/L	0.0002	1	28859-15		07/18/16 12:14	
Sample: B114-A-4		Collected: 07/13/16 07:54				Temp: 26 C		Matrix: Drinking Water	
Lab ID: 114241		Received: 07/13/16 13:38				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0275	1.3	mg/L	0.0010	1	28859-16		07/18/16 12:15	
Lead	0.0005	0.02	mg/L	0.0002	1	28859-16		07/18/16 12:15	

Sample: B117-A Lab ID: 114242	Collected: 07/13/16 07:56 Received: 07/13/16 13:38	Temp: 26 C Evidence of Cooling:N	Matrix: Drinking Water
----------------------------------	---	-------------------------------------	------------------------

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0543	1.3	mg/L	0.0010	1	28859-17		07/18/16 12:17	
Lead	0.0005	0.02	mg/L	0.0002	1	28859-17		07/18/16 12:17	


Abbreviations

MRL Method Reporting Limit
 ND None Detected at or above the MRL
 Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

Units of Measure:

mg/L Milligrams Per Liter

Chain of Custody Record-Water Samples
017-Boeckman Creek: 6700 SW Wilsonville Rd., Wilsonville, OR 97070



Location/Site	Date Collected	Collector's Name	Time	Date Delivered
A100-A	7/13/2016	Steve Matthias	6:21 AM	7/13/2016
A100-B	7/13/2016	Steve Matthias	6:22 AM	7/13/2016
A101-A	7/13/2016	Steve Matthias	6:24 AM	7/13/2016
A101-B	7/13/2016	Steve Matthias	6:25 AM	7/13/2016
A102-A	7/13/2016	Steve Matthias	6:28 AM	7/13/2016
A102-B	7/13/2016	Steve Matthias	6:29 AM	7/13/2016
A103-A	7/13/2016	Steve Matthias	6:30 AM	7/13/2016
A103-B	7/13/2016	Steve Matthias	6:31 AM	7/13/2016
A107-C-1	7/13/2016	Steve Matthias	6:35 AM	7/13/2016
A107-C-2	7/13/2016	Steve Matthias	6:36 AM	7/13/2016
A110-A	7/13/2016	Steve Matthias	6:43 AM	7/13/2016
A110-B	7/13/2016	Steve Matthias	6:44 AM	7/13/2016
A111-A	7/13/2016	Steve Matthias	6:46 AM	7/13/2016
A111-B	7/13/2016	Steve Matthias	6:47 AM	7/13/2016
A112-A	7/13/2016	Steve Matthias	6:48 AM	7/13/2016
A112-B	7/13/2016	Steve Matthias	6:49 AM	7/13/2016
A113-A	7/13/2016	Steve Matthias	6:50 AM	7/13/2016
A113-B	7/13/2016	Steve Matthias	6:51 AM	7/13/2016
A114-A	7/13/2016	Steve Matthias	6:52 AM	7/13/2016
A114-B	7/13/2016	Steve Matthias	6:53 AM	7/13/2016
A115-A	7/13/2016	Steve Matthias	6:54 AM	7/13/2016
A115-B	7/13/2016	Steve Matthias	6:55 AM	7/13/2016
A122-A	7/13/2016	Steve Matthias	7:00 AM	7/13/2016
A122-B	7/13/2016	Steve Matthias	7:01 AM	7/13/2016
A123-A	7/13/2016	Steve Matthias	7:02 AM	7/13/2016
A123-B	7/13/2016	Steve Matthias	7:03 AM	7/13/2016
* A124-A	7/13/2016	Steve Matthias	7:04 AM	7/13/2016
* A124-B present	7/13/2016	Steve Matthias	7:05 AM	7/13/2016
A125-A	7/13/2016	Steve Matthias	7:06 AM	7/13/2016
A125-B	7/13/2016	Steve Matthias	7:07 AM	7/13/2016
* A126-A	7/13/2016	Steve Matthias	7:08 AM	7/13/2016
o v t A126-B	7/13/2016	Steve Matthias	7:09 AM	7/13/2016
A127-A	7/13/2016	Steve Matthias	7:10 AM	7/13/2016
A127-B	7/13/2016	Steve Matthias	7:11 AM	7/13/2016
A128-A	7/13/2016	Steve Matthias	7:12 AM	7/13/2016

* Samples missing, notified Pat MPRH T.13.16

WestlinnsC
6071335
Page 1 of 3

[Signature]
Collector's Signature 7-13-16 Date

[Signature] 7-13-16, 1338 Date
26°C

Chain of Custody Record-Water Samples
017-Boeckman Creek: 6700 SW Wilsonville Rd., Wilsonville, OR 97070

A128-B	7/13/2016	Steve Matthias	7:13 AM	7/13/2016
A134-C	7/13/2016	Steve Matthias	6:58 AM	7/13/2016
A138-A-1	7/13/2016	Steve Matthias	7:15 AM	7/13/2016
A138-A-2	7/13/2016	Steve Matthias	7:16 AM	7/13/2016
A143-C	7/13/2016	Steve Matthias	7:17 AM	7/13/2016
A143-D	7/13/2016	Steve Matthias	7:18 AM	7/13/2016
A150-A	7/13/2016	Steve Matthias	7:21 AM	7/13/2016
A150-B	7/13/2016	Steve Matthias	7:22 AM	7/13/2016
A151-A	7/13/2016	Steve Matthias	7:23 AM	7/13/2016
A152-A	7/13/2016	Steve Matthias	7:24 AM	7/13/2016
A154-A	7/13/2016	Steve Matthias	7:25 AM	7/13/2016
A159-A	7/13/2016	Steve Matthias	7:27 AM	7/13/2016
A159-B	7/13/2016	Steve Matthias	7:28 AM	7/13/2016
A160-A	7/13/2016	Steve Matthias	7:29 AM	7/13/2016
A160-B	7/13/2016	Steve Matthias	7:30 AM	7/13/2016
A161-A	7/13/2016	Steve Matthias	7:31 AM	7/13/2016
A161-B	7/13/2016	Steve Matthias	7:32 AM	7/13/2016
A162-A	7/13/2016	Steve Matthias	7:33 AM	7/13/2016
A162-B	7/13/2016	Steve Matthias	7:34 AM	7/13/2016
A172-A	7/13/2016	Steve Matthias	7:36 AM	7/13/2016
A172-B	7/13/2016	Steve Matthias	7:37 AM	7/13/2016
A173-A	7/13/2016	Steve Matthias	7:38 AM	7/13/2016
A173-B	7/13/2016	Steve Matthias	7:39 AM	7/13/2016
A174-A	7/13/2016	Steve Matthias	7:40 AM	7/13/2016
A174-B	7/13/2016	Steve Matthias	7:41 AM	7/13/2016
A175-A	7/13/2016	Steve Matthias	7:42 AM	7/13/2016
A175-B	7/13/2016	Steve Matthias	7:43 AM	7/13/2016
A179-C	7/13/2016	Steve Matthias	7:35 AM	7/13/2016
A181-A	7/13/2016	Steve Matthias	7:36 AM	7/13/2016
A184-A	7/13/2016	Steve Matthias	7:45 AM	7/13/2016
A185-A	7/13/2016	Steve Matthias	7:46 AM	7/13/2016
B102-C	7/13/2016	Steve Matthias	7:51 AM	7/13/2016
B111-A	7/13/2016	Steve Matthias	7:50 AM	7/13/2016
B114-A-1	7/13/2016	Steve Matthias	7:51 AM	7/13/2016
B114-A-2	7/13/2016	Steve Matthias	7:52 AM	7/13/2016
B114-A-3	7/13/2016	Steve Matthias	7:53 AM	7/13/2016

00713335
Page 2 of 3

Shawn
Collector's Signature

7-13-16
Date

M. Wood
Laboratory Signature

7-13-16, 1338
Date

26°C

Chain of Custody Record-Water Samples
017-Boeckman Creek: 6700 SW Wilsonville Rd., Wilsonville, OR 97070

B114-A-4	7/13/2016	Steve Matthias	7:54 AM	7/13/2016
B117-A	7/13/2016	Steve Matthias	7:56 AM	7/13/2016

0171338
 page 3 of 3

[Handwritten Signature]
 Collector's Signature

7-13-16
 Date

[Handwritten Signature]
 Laboratory Signature

7-13-16, 1338
 Date

26°C

PIXIS Labs

Accurate. Reliable. On Time.

Pixis Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

Job Number: 6071927

Report Date: 07/20/2016

ORELAP #: OR100028

Project No: 017-Boeckman Creek

Cover Letter

Pat McGough
West Linn School District
2755 SW Borland
West Linn, OR 97068

Dear Pat McGough,

Enclosed please find Pixis Labs analytical report for samples received as order number 6071927 on 07/19/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed

Richard Reid

Project Manager

Sample Results

Sample: A124-A		Collected: 07/19/16 06:44		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 114582		Received: 07/19/16 12:15		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0487	1.3	mg/L	0.0010	1	28863-26		07/19/16 20:57	
Lead	ND	0.02	mg/L	0.0002	1	28863-26		07/19/16 20:57	
Sample: A126-A		Collected: 07/19/16 06:45		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 114583		Received: 07/19/16 12:15		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0571	1.3	mg/L	0.0010	1	28863-27		07/19/16 21:01	
Lead	0.0006	0.02	mg/L	0.0002	1	28863-27		07/19/16 21:01	

Abbreviations

MRL Method Reporting Limit
ND None Detected at or above the MRL
Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

Units of Measure:

mg/L Milligrams Per Liter

Chain of Custody Record-Water Samples
017-Boeckman Creek: 6700 SW Wilsonville Rd., Wilsonville, OR 97070

Location/Site	Date Collected	Collector's Name	Time	Date Delivered
A124-A	7/19/2016	Steve Matthias	6:44 AM	7/19/2016
A126-A	7/19/2016	Steve Matthias	6:45 AM	7/19/2016

Samples A124-A and A126-A were not delivered on 6-23-16. These two tap samples are to complete the initial testing.

West Inn Se
Le01127
Page 1 of 1

22.4°C
No cooling

Stephen J. Matthias 7-19-16
Collector's Signature Date

MRH 7.19.16 12:15
Laboratory Signature Date