

PIXIS Labs

Accurate. Reliable. On Time.

PIXIS Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

Job Number: 6071928
Report Date: 07/26/2016
ORELAP #: OR100028
Project No: 027-Lowrie Primary School

Cover Letter

Pat McGough
West Linn School District
2755 SW Borland
West Linn, OR 97068

Dear Pat McGough,

Enclosed please find Pixis Labs analytical report for samples received as order number 6071928 on 07/19/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

The action level for lead has been set at 0.02 mg/L at the request of the client.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed
Richard Reid
Project Manager

Sample Results

Sample: A106-A		Collected: 07/19/16 06:24		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 114584		Received: 07/19/16 12:15		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.112	1.3	mg/L	0.0010	1	28885-16		07/20/16 11:17	
Lead	0.0020	0.02	mg/L	0.0002	1	28885-16		07/20/16 11:17	
Sample: A110-A		Collected: 07/19/16 06:21		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 114585		Received: 07/19/16 12:15		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0277	1.3	mg/L	0.0010	1	28885-17		07/20/16 11:19	
Lead	0.0008	0.02	mg/L	0.0002	1	28885-17		07/20/16 11:19	
Sample: A111-A		Collected: 07/19/16 06:22		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 114586		Received: 07/19/16 12:15		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0285	1.3	mg/L	0.0010	1	28885-18		07/20/16 11:21	
Lead	0.0006	0.02	mg/L	0.0002	1	28885-18		07/20/16 11:21	
Sample: A112-A		Collected: 07/19/16 06:23		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 114587		Received: 07/19/16 12:15		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.113	1.3	mg/L	0.0010	1	28885-23		07/20/16 11:31	
Lead	0.0007	0.02	mg/L	0.0002	1	28885-23		07/20/16 11:31	
Sample: A117-A		Collected: 07/19/16 06:27		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 114588		Received: 07/19/16 12:15		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0998	1.3	mg/L	0.0010	1	28885-24		07/20/16 11:33	
Lead	0.0012	0.02	mg/L	0.0002	1	28885-24		07/20/16 11:33	
Sample: A119-A		Collected: 07/19/16 06:30		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 114590		Received: 07/19/16 12:15		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.174	1.3	mg/L	0.0010	1	28885-25		07/20/16 11:35	
Lead	0.0024	0.02	mg/L	0.0002	1	28885-25		07/20/16 11:35	
Sample: A120A-C		Collected: 07/19/16 06:33		Temp: 22 C		Matrix: Drinking Water			
Lab ID: 114591		Received: 07/19/16 12:15		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.103	1.3	mg/L	0.0010	1	28885-26		07/20/16 11:37	

Lead 0.0004 0.02 mg/L 0.0002 1 28885-26 07/20/16 11:37

Sample: A120A-D Collected: 07/19/16 06:34 Temp: 22 C Matrix: Drinking Water
Lab ID: 114592 Received: 07/19/16 12:15 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper 0.0865 1.3 mg/L 0.0010 1 28885-27 07/20/16 11:39

Lead 0.0004 0.02 mg/L 0.0002 1 28885-27 07/20/16 11:39

Sample: A120-A-1 Collected: 07/19/16 06:35 Temp: 22 C Matrix: Drinking Water
Lab ID: 114594 Received: 07/19/16 12:15 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper 0.0545 1.3 mg/L 0.0010 1 28885-28 07/20/16 11:41

Lead 0.0009 0.02 mg/L 0.0002 1 28885-28 07/20/16 11:41

Sample: A120-A-2 Collected: 07/19/16 06:36 Temp: 22 C Matrix: Drinking Water
Lab ID: 114595 Received: 07/19/16 12:15 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper 0.0372 1.3 mg/L 0.0010 1 28885-29 07/20/16 11:44

Lead 0.0013 0.02 mg/L 0.0002 1 28885-29 07/20/16 11:44

Sample: A120-A-3 Collected: 07/19/16 06:37 Temp: 22 C Matrix: Drinking Water
Lab ID: 114597 Received: 07/19/16 12:15 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper 0.0466 1.3 mg/L 0.0010 1 28885-30 07/20/16 11:46

Lead 0.0012 0.02 mg/L 0.0002 1 28885-30 07/20/16 11:46

Sample: A120-A-4 Collected: 07/19/16 06:38 Temp: 22 C Matrix: Drinking Water
Lab ID: 114598 Received: 07/19/16 12:15 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper 0.0310 1.3 mg/L 0.0010 1 28885-31 07/20/16 11:48

Lead 0.0014 0.02 mg/L 0.0002 1 28885-31 07/20/16 11:48

Sample: A121-A-1 Collected: 07/19/16 06:40 Temp: 22 C Matrix: Drinking Water
Lab ID: 114599 Received: 07/19/16 12:15 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper 0.0392 1.3 mg/L 0.0010 1 28885-32 07/20/16 11:50

Lead 0.0005 0.02 mg/L 0.0002 1 28885-32 07/20/16 11:50

Sample: A121-A-2 Collected: 07/19/16 06:41 Temp: 22 C Matrix: Drinking Water
Lab ID: 114600 Received: 07/19/16 12:15 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper 0.0315 1.3 mg/L 0.0010 1 28885-37 07/20/16 12:02

Lead 0.0009 0.02 mg/L 0.0002 1 28885-37 07/20/16 12:02

Sample: A121-A-3 Collected: 07/19/16 06:42 Temp: 22 C Matrix: Drinking Water
Lab ID: 114601 Received: 07/19/16 12:15 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0529	1.3	mg/L	0.0010	1	28885-38		07/20/16 12:04	
Lead	0.0007	0.02	mg/L	0.0002	1	28885-38		07/20/16 12:04	

Sample: A121-A-4	Collected: 07/19/16 06:43	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114602	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0287	1.3	mg/L	0.0010	1	28885-39		07/20/16 12:07	
Lead	0.0007	0.02	mg/L	0.0002	1	28885-39		07/20/16 12:07	

Sample: A122-A	Collected: 07/19/16 06:45	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114603	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0250	1.3	mg/L	0.0010	1	28885-40		07/20/16 12:09	
Lead	0.0006	0.02	mg/L	0.0002	1	28885-40		07/20/16 12:09	

Sample: A133-A	Collected: 07/19/16 06:46	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114604	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.133	1.3	mg/L	0.0010	1	28885-41		07/20/16 12:11	
Lead	0.0046	0.02	mg/L	0.0002	1	28885-41		07/20/16 12:11	

Sample: A133-B	Collected: 07/19/16 06:48	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114605	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.172	1.3	mg/L	0.0010	1	28885-42		07/20/16 12:13	
Lead	0.0017	0.02	mg/L	0.0002	1	28885-42		07/20/16 12:13	

Sample: B101-A	Collected: 07/19/16 06:57	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114606	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.138	1.3	mg/L	0.0010	1	28885-43		07/20/16 12:15	
Lead	0.0010	0.02	mg/L	0.0002	1	28885-43		07/20/16 12:15	

Sample: B101-B	Collected: 07/19/16 06:58	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114607	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.257	1.3	mg/L	0.0010	1	28885-44		07/20/16 12:17	
Lead	0.0006	0.02	mg/L	0.0002	1	28885-44		07/20/16 12:17	

Sample: B102-A	Collected: 07/19/16 06:59	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114608	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.142	1.3	mg/L	0.0010	1	28885-45		07/20/16 12:19	
Lead	0.0009	0.02	mg/L	0.0002	1	28885-45		07/20/16 12:19	

Sample: B102-B	Collected: 07/19/16 07:00	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114609	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									

Copper	0.228	1.3	mg/L	0.0010	1	28885-46	07/20/16 12:21
Lead	0.0015	0.02	mg/L	0.0002	1	28885-46	07/20/16 12:21

Sample: B103-A	Collected: 07/19/16 07:01	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114610	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.161	1.3	mg/L	0.0010	1	28885-51	07/20/16 12:32
Lead	0.0005	0.02	mg/L	0.0002	1	28885-51	07/20/16 12:32

Sample: B103-B	Collected: 07/19/16 07:02	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114611	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.204	1.3	mg/L	0.0010	1	28885-52	07/20/16 12:34
Lead	0.0012	0.02	mg/L	0.0002	1	28885-52	07/20/16 12:34

Sample: B104-A	Collected: 07/19/16 07:03	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114612	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.135	1.3	mg/L	0.0010	1	28885-53	07/20/16 12:36
Lead	0.0005	0.02	mg/L	0.0002	1	28885-53	07/20/16 12:36

Sample: B104-B	Collected: 07/19/16 07:04	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114613	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.147	1.3	mg/L	0.0010	1	28885-54	07/20/16 12:38
Lead	0.0005	0.02	mg/L	0.0002	1	28885-54	07/20/16 12:38

Sample: B105-A	Collected: 07/19/16 07:05	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114614	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.145	1.3	mg/L	0.0010	1	28885-55	07/20/16 12:40
Lead	0.0007	0.02	mg/L	0.0002	1	28885-55	07/20/16 12:40

Sample: B105-B	Collected: 07/19/16 07:06	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114615	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.281	1.3	mg/L	0.0010	1	28885-56	07/20/16 12:42
Lead	0.0004	0.02	mg/L	0.0002	1	28885-56	07/20/16 12:42

Sample: B106-A	Collected: 07/19/16 07:08	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114616	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.154	1.3	mg/L	0.0010	1	28885-57	07/20/16 12:44
Lead	0.0007	0.02	mg/L	0.0002	1	28885-57	07/20/16 12:44

Sample: B106-B	Collected: 07/19/16 07:09	Temp: 22 C	Matrix: Drinking Water
Lab ID: 114617	Received: 07/19/16 12:15	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.247	1.3	mg/L	0.0010	1	28885-58		07/20/16 12:46	
Lead	0.0009	0.02	mg/L	0.0002	1	28885-58		07/20/16 12:46	
Sample: B107-A		Collected: 07/19/16 07:10			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114618		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0597	1.3	mg/L	0.0010	1	28885-59		07/20/16 12:49	
Lead	ND	0.02	mg/L	0.0002	1	28885-59		07/20/16 12:49	
Sample: B107-B		Collected: 07/19/16 07:11			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114619		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.173	1.3	mg/L	0.0010	1	28885-60		07/20/16 12:51	
Lead	0.0006	0.02	mg/L	0.0002	1	28885-60		07/20/16 12:51	
Sample: B108-A		Collected: 07/19/16 07:12			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114620		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.113	1.3	mg/L	0.0010	1	28885-65		07/20/16 13:01	
Lead	0.0013	0.02	mg/L	0.0002	1	28885-65		07/20/16 13:01	
Sample: B108-B		Collected: 07/19/16 07:13			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114621		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.242	1.3	mg/L	0.0010	1	28885-66		07/20/16 13:03	
Lead	0.0021	0.02	mg/L	0.0002	1	28885-66		07/20/16 13:03	
Sample: B109-A		Collected: 07/19/16 07:14			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114622		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.116	1.3	mg/L	0.0010	1	28885-67		07/20/16 13:06	
Lead	0.0015	0.02	mg/L	0.0002	1	28885-67		07/20/16 13:06	
Sample: B109-B		Collected: 07/19/16 07:15			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114623		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.228	1.3	mg/L	0.0010	1	28885-68		07/20/16 13:08	
Lead	0.0015	0.02	mg/L	0.0002	1	28885-68		07/20/16 13:08	
Sample: B110-A		Collected: 07/19/16 07:16			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114624		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.117	1.3	mg/L	0.0010	1	28885-69		07/20/16 13:10	
Lead	0.0006	0.02	mg/L	0.0002	1	28885-69		07/20/16 13:10	
Sample: B110-B		Collected: 07/19/16 07:17			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114625		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes

Method: EPA 200.8									
Copper	0.185	1.3	mg/L	0.0010	1	28885-70		07/20/16 13:12	
Lead	0.0006	0.02	mg/L	0.0002	1	28885-70		07/20/16 13:12	
Sample: B111-A		Collected: 07/19/16 07:07			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114626		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.167	1.3	mg/L	0.0010	1	28885-71		07/20/16 13:14	
Lead	0.0010	0.02	mg/L	0.0002	1	28885-71		07/20/16 13:14	
Sample: B112-A		Collected: 07/19/16 07:18			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114627		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.140	1.3	mg/L	0.0010	1	28885-72		07/20/16 13:16	
Lead	0.0008	0.02	mg/L	0.0002	1	28885-72		07/20/16 13:16	
Sample: B120-A		Collected: 07/19/16 07:19			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114628		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0827	1.3	mg/L	0.0010	1	28885-73		07/20/16 13:18	
Lead	0.0003	0.02	mg/L	0.0002	1	28885-73		07/20/16 13:18	
Sample: B121-A-1		Collected: 07/19/16 07:23			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114629		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0494	1.3	mg/L	0.0010	1	28885-74		07/20/16 13:20	
Lead	0.0006	0.02	mg/L	0.0002	1	28885-74		07/20/16 13:20	
Sample: B121-A-2		Collected: 07/19/16 07:24			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114630		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0763	1.3	mg/L	0.0010	1	28885-80		07/20/16 13:33	
Lead	0.0010	0.02	mg/L	0.0002	1	28885-80		07/20/16 13:33	
Sample: B121-A-3		Collected: 07/19/16 07:25			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114632		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.127	1.3	mg/L	0.0010	1	28885-81		07/20/16 13:35	
Lead	0.0020	0.02	mg/L	0.0002	1	28885-81		07/20/16 13:35	
Sample: B121-A-4		Collected: 07/19/16 07:26			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114633		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.155	1.3	mg/L	0.0010	1	28885-82		07/20/16 13:38	
Lead	0.0008	0.02	mg/L	0.0002	1	28885-82		07/20/16 13:38	
Sample: B121-C		Collected: 07/19/16 07:27			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114634		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes

Method: EPA 200.8									
Copper	0.0945	1.3	mg/L	0.0010	1	28885-83		07/20/16 13:40	
Lead	ND	0.02	mg/L	0.0002	1	28885-83		07/20/16 13:40	
Sample: B121-D		Collected: 07/19/16 07:28			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114636		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.138	1.3	mg/L	0.0010	1	28885-84		07/20/16 13:42	
Lead	ND	0.02	mg/L	0.0002	1	28885-84		07/20/16 13:42	
Sample: B122-A-1		Collected: 07/19/16 07:29			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114637		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.101	1.3	mg/L	0.0010	1	28885-85		07/20/16 13:44	
Lead	0.0005	0.02	mg/L	0.0002	1	28885-85		07/20/16 13:44	
Sample: B122-A-2		Collected: 07/19/16 07:30			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114638		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.111	1.3	mg/L	0.0010	1	28885-86		07/20/16 13:46	
Lead	0.0011	0.02	mg/L	0.0002	1	28885-86		07/20/16 13:46	
Sample: B122-A-3		Collected: 07/19/16 07:31			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114639		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0323	1.3	mg/L	0.0010	1	28885-102		07/20/16 14:20	
Lead	0.0007	0.02	mg/L	0.0002	1	28885-102		07/20/16 14:20	
Sample: B122-A-4		Collected: 07/19/16 07:32			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114640		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.120	1.3	mg/L	0.0010	1	28885-107		07/20/16 14:33	
Lead	0.0008	0.02	mg/L	0.0002	1	28885-107		07/20/16 14:33	
Sample: B127-A-1		Collected: 07/19/16 07:35			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114641		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.130	1.3	mg/L	0.0010	1	28885-108		07/20/16 14:35	
Lead	0.0002	0.02	mg/L	0.0002	1	28885-108		07/20/16 14:35	
Sample: B127-A-2		Collected: 07/19/16 07:36			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114642		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0259	1.3	mg/L	0.0010	1	28885-109		07/20/16 14:37	
Lead	0.0025	0.02	mg/L	0.0002	1	28885-109		07/20/16 14:37	
Sample: B127-A-3		Collected: 07/19/16 07:37			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114643		Received: 07/19/16 12:15			Evidence of Cooling:N				

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0923	1.3	mg/L	0.0010	1	28885-110		07/20/16 14:40	
Lead	0.0014	0.02	mg/L	0.0002	1	28885-110		07/20/16 14:40	
Sample: B127-A-4		Collected: 07/19/16 07:38			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114644		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0381	1.3	mg/L	0.0010	1	28885-111		07/20/16 14:42	
Lead	0.0329	0.02	mg/L	0.0002	1	28885-111		07/20/16 14:42	
Sample: B127-A-5		Collected: 07/19/16 07:39			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114645		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0411	1.3	mg/L	0.0010	1	28885-112		07/20/16 14:44	
Lead	0.0138	0.02	mg/L	0.0002	1	28885-112		07/20/16 14:44	
Sample: C101-A		Collected: 07/19/16 07:41			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114646		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.113	1.3	mg/L	0.0010	1	28885-113		07/20/16 14:46	
Lead	0.0017	0.02	mg/L	0.0002	1	28885-113		07/20/16 14:46	
Sample: C101-B		Collected: 07/19/16 07:42			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114647		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.137	1.3	mg/L	0.0010	1	28885-114		07/20/16 14:48	
Lead	0.0015	0.02	mg/L	0.0002	1	28885-114		07/20/16 14:48	
Sample: C102-A		Collected: 07/19/16 07:43			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114648		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.110	1.3	mg/L	0.0010	1	28885-115		07/20/16 14:50	
Lead	0.0019	0.02	mg/L	0.0002	1	28885-115		07/20/16 14:50	
Sample: C102-B		Collected: 07/19/16 07:44			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114650		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.179	1.3	mg/L	0.0010	1	28885-116		07/20/16 14:53	
Lead	0.0012	0.02	mg/L	0.0002	1	28885-116		07/20/16 14:53	
Sample: C103-A		Collected: 07/19/16 07:45			Temp: 22 C		Matrix: Drinking Water		
Lab ID: 114651		Received: 07/19/16 12:15			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.144	1.3	mg/L	0.0010	1	28885-121		07/20/16 15:03	
Lead	0.0018	0.02	mg/L	0.0002	1	28885-121		07/20/16 15:03	
Sample: C103-B		Collected: 07/19/16 07:46			Temp: 22 C		Matrix: Drinking Water		

Lab ID: 114652		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.198	1.3	mg/L	0.0010	1	28885-122		07/20/16 15:06	
Lead	0.0029	0.02	mg/L	0.0002	1	28885-122		07/20/16 15:06	
Sample: C104-A		Collected: 07/19/16 07:47				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114653		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0670	1.3	mg/L	0.0010	1	28885-123		07/20/16 15:08	
Lead	ND	0.02	mg/L	0.0002	1	28885-123		07/20/16 15:08	
Sample: C104-B		Collected: 07/19/16 07:48				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114654		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.145	1.3	mg/L	0.0010	1	28885-124		07/20/16 15:10	
Lead	0.0011	0.02	mg/L	0.0002	1	28885-124		07/20/16 15:10	
Sample: C105-A		Collected: 07/19/16 07:49				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114655		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0889	1.3	mg/L	0.0010	1	28885-125		07/20/16 15:12	
Lead	0.0003	0.02	mg/L	0.0002	1	28885-125		07/20/16 15:12	
Sample: C105-B		Collected: 07/19/16 07:50				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114656		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.139	1.3	mg/L	0.0010	1	28885-126		07/20/16 15:14	
Lead	ND	0.02	mg/L	0.0002	1	28885-126		07/20/16 15:14	
Sample: C106-A		Collected: 07/19/16 07:51				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114659		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0699	1.3	mg/L	0.0010	1	28885-127		07/20/16 15:17	
Lead	0.0004	0.02	mg/L	0.0002	1	28885-127		07/20/16 15:17	
Sample: C106-C		Collected: 07/19/16 07:52				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114660		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0703	1.3	mg/L	0.0010	1	28885-128		07/20/16 15:19	
Lead	ND	0.02	mg/L	0.0002	1	28885-128		07/20/16 15:19	
Sample: C106-D		Collected: 07/19/16 07:53				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114661		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0780	1.3	mg/L	0.0010	1	28885-129		07/20/16 15:21	
Lead	ND	0.02	mg/L	0.0002	1	28885-129		07/20/16 15:21	

Sample: C109-A-1 Lab ID: 114662		Collected: 07/19/16 07:54 Received: 07/19/16 12:15				Temp: 22 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0173	1.3	mg/L	0.0010	1	28885-130		07/20/16 15:23	
Lead	0.0116	0.02	mg/L	0.0002	1	28885-130		07/20/16 15:23	
Sample: C109-A-2 Lab ID: 114663		Collected: 07/19/16 07:55 Received: 07/19/16 12:15				Temp: 22 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.130	1.3	mg/L	0.0010	1	28885-135		07/20/16 15:34	
Lead	0.0042	0.02	mg/L	0.0002	1	28885-135		07/20/16 15:34	
Sample: C111-A Lab ID: 114664		Collected: 07/19/16 07:56 Received: 07/19/16 12:15				Temp: 22 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0163	1.3	mg/L	0.0010	1	28885-136		07/20/16 15:36	
Lead	ND	0.02	mg/L	0.0002	1	28885-136		07/20/16 15:36	
Sample: B201-A Lab ID: 114666		Collected: 07/19/16 08:02 Received: 07/19/16 12:15				Temp: 22 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.192	1.3	mg/L	0.0010	1	28885-137		07/20/16 15:38	
Lead	0.0003	0.02	mg/L	0.0002	1	28885-137		07/20/16 15:38	
Sample: B201-B Lab ID: 114667		Collected: 07/19/16 08:03 Received: 07/19/16 12:15				Temp: 22 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.218	1.3	mg/L	0.0010	1	28885-138		07/20/16 15:40	
Lead	0.0003	0.02	mg/L	0.0002	1	28885-138		07/20/16 15:40	
Sample: B202-A Lab ID: 114668		Collected: 07/19/16 08:04 Received: 07/19/16 12:15				Temp: 22 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.110	1.3	mg/L	0.0010	1	28885-139		07/20/16 15:43	
Lead	0.0017	0.02	mg/L	0.0002	1	28885-139		07/20/16 15:43	
Sample: B202-B Lab ID: 114670		Collected: 07/19/16 08:05 Received: 07/19/16 12:15				Temp: 22 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.195	1.3	mg/L	0.0010	1	28885-140		07/20/16 15:45	
Lead	0.0013	0.02	mg/L	0.0002	1	28885-140		07/20/16 15:45	
Sample: B203-A Lab ID: 114671		Collected: 07/19/16 08:06 Received: 07/19/16 12:15				Temp: 22 C Evidence of Cooling:N		Matrix: Drinking Water	
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.132	1.3	mg/L	0.0010	1	28885-141		07/20/16 15:47	
Lead	0.0005	0.02	mg/L	0.0002	1	28885-141		07/20/16 15:47	

Sample: B203-B		Collected: 07/19/16 08:07				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114672		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.211	1.3	mg/L	0.0010	1	28885-142		07/20/16 15:49	
Lead	0.0004	0.02	mg/L	0.0002	1	28885-142		07/20/16 15:49	
Sample: B204-A		Collected: 07/19/16 08:08				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114673		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.112	1.3	mg/L	0.0010	1	28885-143		07/20/16 15:51	
Lead	0.0007	0.02	mg/L	0.0002	1	28885-143		07/20/16 15:51	
Sample: B204-B		Collected: 07/19/16 08:09				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114674		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.170	1.3	mg/L	0.0010	1	28885-144		07/20/16 15:53	
Lead	0.0008	0.02	mg/L	0.0002	1	28885-144		07/20/16 15:53	
Sample: B205-A		Collected: 07/19/16 08:10				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114675		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0965	1.3	mg/L	0.0010	1	28885-149		07/20/16 16:04	
Lead	0.0011	0.02	mg/L	0.0002	1	28885-149		07/20/16 16:04	
Sample: B205-B		Collected: 07/19/16 08:11				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114677		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.166	1.3	mg/L	0.0010	1	28885-150		07/20/16 16:06	
Lead	0.0004	0.02	mg/L	0.0002	1	28885-150		07/20/16 16:06	
Sample: B206-A		Collected: 07/19/16 08:14				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114678		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.127	1.3	mg/L	0.0010	1	28885-151		07/20/16 16:08	
Lead	0.0007	0.02	mg/L	0.0002	1	28885-151		07/20/16 16:08	
Sample: B206-B		Collected: 07/19/16 08:15				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114679		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.183	1.3	mg/L	0.0010	1	28885-152		07/20/16 16:11	
Lead	0.0012	0.02	mg/L	0.0002	1	28885-152		07/20/16 16:11	
Sample: B207-A		Collected: 07/19/16 08:16				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114680		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.150	1.3	mg/L	0.0010	1	28885-153		07/20/16 16:13	
Lead	0.0008	0.02	mg/L	0.0002	1	28885-153		07/20/16 16:13	

Sample: B207-B		Collected: 07/19/16 08:17				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114681		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.173	1.3	mg/L	0.0010	1	28885-154		07/20/16 16:15	
Lead	0.0008	0.02	mg/L	0.0002	1	28885-154		07/20/16 16:15	
Sample: B208-A		Collected: 07/19/16 08:18				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114682		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.163	1.3	mg/L	0.0010	1	28885-155		07/20/16 16:17	
Lead	0.0012	0.02	mg/L	0.0002	1	28885-155		07/20/16 16:17	
Sample: B208-B		Collected: 07/19/16 08:19				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114683		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.168	1.3	mg/L	0.0010	1	28885-156		07/20/16 16:19	
Lead	0.0015	0.02	mg/L	0.0002	1	28885-156		07/20/16 16:19	
Sample: B209-A		Collected: 07/19/16 08:20				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114684		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.122	1.3	mg/L	0.0010	1	28885-157		07/20/16 16:22	
Lead	0.0005	0.02	mg/L	0.0002	1	28885-157		07/20/16 16:22	
Sample: B209-B		Collected: 07/19/16 08:21				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114685		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.198	1.3	mg/L	0.0010	1	28885-158		07/20/16 16:24	
Lead	0.0006	0.02	mg/L	0.0002	1	28885-158		07/20/16 16:24	
Sample: B210-A		Collected: 07/19/16 08:22				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114686		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.156	1.3	mg/L	0.0010	1	28885-163		07/20/16 16:37	
Lead	ND	0.02	mg/L	0.0002	1	28885-163		07/20/16 16:37	
Sample: B210-B		Collected: 07/19/16 08:23				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114687		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.124	1.3	mg/L	0.0010	1	28885-164		07/20/16 16:39	
Lead	ND	0.02	mg/L	0.0002	1	28885-164		07/20/16 16:39	
Sample: B211-A		Collected: 07/19/16 08:12				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114688		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.117	1.3	mg/L	0.0010	1	28885-165		07/20/16 16:41	
Lead	0.0010	0.02	mg/L	0.0002	1	28885-165		07/20/16 16:41	

Sample: B212-A		Collected: 07/19/16 08:24				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114689		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0897	1.3	mg/L	0.0010	1	28885-166		07/20/16 16:44	
Lead	0.0022	0.02	mg/L	0.0002	1	28885-166		07/20/16 16:44	
Sample: B218-C		Collected: 07/19/16 08:26				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114690		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0670	1.3	mg/L	0.0010	1	28885-167		07/20/16 16:46	
Lead	ND	0.02	mg/L	0.0002	1	28885-167		07/20/16 16:46	
Sample: B218-D		Collected: 07/19/16 08:27				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114691		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0996	1.3	mg/L	0.0010	1	28885-168		07/20/16 16:48	
Lead	ND	0.02	mg/L	0.0002	1	28885-168		07/20/16 16:48	
Sample: B220-A		Collected: 07/19/16 08:25				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114692		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0344	1.3	mg/L	0.0010	1	28885-169		07/20/16 16:50	
Lead	0.0004	0.02	mg/L	0.0002	1	28885-169		07/20/16 16:50	
Sample: B221-A-1		Collected: 07/19/16 08:26				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114693		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.116	1.3	mg/L	0.0010	1	28885-170		07/20/16 16:52	
Lead	0.0005	0.02	mg/L	0.0002	1	28885-170		07/20/16 16:52	
Sample: B221-A-2		Collected: 07/19/16 08:27				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114694		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0982	1.3	mg/L	0.0010	1	28885-171		07/20/16 16:55	
Lead	0.0017	0.02	mg/L	0.0002	1	28885-171		07/20/16 16:55	
Sample: B221-A-3		Collected: 07/19/16 08:28				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114695		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0898	1.3	mg/L	0.0010	1	28885-172		07/20/16 16:57	
Lead	0.0024	0.02	mg/L	0.0002	1	28885-172		07/20/16 16:57	
Sample: B221-A-4		Collected: 07/19/16 08:29				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114696		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0725	1.3	mg/L	0.0010	1	28885-177		07/20/16 17:08	
Lead	0.0023	0.02	mg/L	0.0002	1	28885-177		07/20/16 17:08	

Sample: B222-A-1		Collected: 07/19/16 08:30				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114697		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.117	1.3	mg/L	0.0010	1	28885-178		07/20/16 17:10	
Lead	0.0015	0.02	mg/L	0.0002	1	28885-178		07/20/16 17:10	
Sample: B222-A-2		Collected: 07/19/16 08:31				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114698		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0205	1.3	mg/L	0.0010	1	28885-179		07/20/16 17:12	
Lead	0.0024	0.02	mg/L	0.0002	1	28885-179		07/20/16 17:12	
Sample: B222-A-3		Collected: 07/19/16 08:32				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114699		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0292	1.3	mg/L	0.0010	1	28885-180		07/20/16 17:14	
Lead	0.0005	0.02	mg/L	0.0002	1	28885-180		07/20/16 17:14	
Sample: B222-A-4		Collected: 07/19/16 08:33				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114700		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.139	1.3	mg/L	0.0010	1	28885-181		07/20/16 17:16	
Lead	0.0030	0.02	mg/L	0.0002	1	28885-181		07/20/16 17:16	
Sample: B227-A-1		Collected: 07/19/16 08:35				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114701		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0784	1.3	mg/L	0.0010	1	28885-182		07/20/16 17:18	
Lead	0.0010	0.02	mg/L	0.0002	1	28885-182		07/20/16 17:18	
Sample: B227-A-2		Collected: 07/19/16 08:36				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114702		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0465	1.3	mg/L	0.0010	1	28885-183		07/20/16 17:21	
Lead	0.0056	0.02	mg/L	0.0002	1	28885-183		07/20/16 17:21	
Sample: B227-A-3		Collected: 07/19/16 08:37				Temp: 22 C		Matrix: Drinking Water	
Lab ID: 114703		Received: 07/19/16 12:15				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.188	1.3	mg/L	0.0010	1	28885-184		07/20/16 17:23	
Lead	0.0008	0.02	mg/L	0.0002	1	28885-184		07/20/16 17:23	

Abbreviations

MRL Method Reporting Limit

ND None Detected at or above the MRL

Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.


Units of Measure:
mg/L Milligrams Per Liter

Chain of Custody Record-Water Samples
027-Lowrie Primary School: 28995 SW Brown Rd., Wilsonville, OR 97070


Location/Site	Date Collected	Collector's Name	Time	Date Delivered
A106-A	7/19/2016	Jeff Chambers	6:24 AM	7/19/2016
A110-A	7/19/2016	Jeff Chambers	6:21 AM	7/19/2016
A111-A	7/19/2016	Jeff Chambers	6:22 AM	7/19/2016
A112-A	7/19/2016	Jeff Chambers	6:23 AM	7/19/2016
A117-A	7/19/2016	Jeff Chambers	6:27 AM	7/19/2016
A119-A	7/19/2016	Jeff Chambers	6:30 AM	7/19/2016
A120A-C	7/19/2016	Jeff Chambers	6:33 AM	7/19/2016
A120A-D	7/19/2016	Jeff Chambers	6:34 AM	7/19/2016
A120-A-1	7/19/2016	Jeff Chambers	6:35 AM	7/19/2016
A120-A-2	7/19/2016	Jeff Chambers	6:36 AM	7/19/2016
A120-A-3	7/19/2016	Jeff Chambers	6:37 AM	7/19/2016
A120-A-4	7/19/2016	Jeff Chambers	6:38 AM	7/19/2016
A121-A-1	7/19/2016	Jeff Chambers	6:40 AM	7/19/2016
A121-A-2	7/19/2016	Jeff Chambers	6:41 AM	7/19/2016
A121-A-3	7/19/2016	Jeff Chambers	6:42 AM	7/19/2016
A121-A-4	7/19/2016	Jeff Chambers	6:43 AM	7/19/2016
A122-A	7/19/2016	Jeff Chambers	6:45 AM	7/19/2016
A133-A	7/19/2016	Jeff Chambers	6:46 AM	7/19/2016
A133-B	7/19/2016	Jeff Chambers	6:48 AM	7/19/2016
B101-A	7/19/2016	Jeff Chambers	6:57 AM	7/19/2016
B101-B	7/19/2016	Jeff Chambers	6:58 AM	7/19/2016
B102-A	7/19/2016	Jeff Chambers	6:59 AM	7/19/2016
B102-B	7/19/2016	Jeff Chambers	7:00 AM	7/19/2016
B103-A	7/19/2016	Jeff Chambers	7:01 AM	7/19/2016
B103-B	7/19/2016	Jeff Chambers	7:02 AM	7/19/2016
B104-A	7/19/2016	Jeff Chambers	7:03 AM	7/19/2016
B104-B	7/19/2016	Jeff Chambers	7:04 AM	7/19/2016
B105-A	7/19/2016	Jeff Chambers	7:05 AM	7/19/2016
B105-B	7/19/2016	Jeff Chambers	7:06 AM	7/19/2016
B106-A	7/19/2016	Jeff Chambers	7:08 AM	7/19/2016
B106-B	7/19/2016	Jeff Chambers	7:09 AM	7/19/2016
B107-A	7/19/2016	Jeff Chambers	7:10 AM	7/19/2016
B107-B	7/19/2016	Jeff Chambers	7:11 AM	7/19/2016
B108-A	7/19/2016	Jeff Chambers	7:12 AM	7/19/2016
B108-B	7/19/2016	Jeff Chambers	7:13 AM	7/19/2016

Westlins =
 Le011928
 Page 1 of 1

22.4°C
 No Cooling


 Collector's Signature

7-19-16
 Date



 Laboratory Signature

7-19-16 12:15
 Date

Chain of Custody Record-Water Samples
027-Lowrie Primary School: 28995 SW Brown Rd., Wilsonville, OR 97070

B109-A	7/19/2016	Jeff Chambers	7:14 AM	7/19/2016
B109-B	7/19/2016	Jeff Chambers	7:15 AM	7/19/2016
B110-A	7/19/2016	Jeff Chambers	7:16 AM	7/19/2016
B110-B	7/19/2016	Jeff Chambers	7:17 AM	7/19/2016
B111-A	7/19/2016	Jeff Chambers	7:07 AM	7/19/2016
B112-A	7/19/2016	Jeff Chambers	7:18 AM	7/19/2016
B120-A	7/19/2016	Jeff Chambers	7:19 AM	7/19/2016
B121-A-1	7/19/2016	Jeff Chambers	7:23 AM	7/19/2016
B121-A-2	7/19/2016	Jeff Chambers	7:24 AM	7/19/2016
B121-A-3	7/19/2016	Jeff Chambers	7:25 AM	7/19/2016
B121-A-4	7/19/2016	Jeff Chambers	7:26 AM	7/19/2016
B121-C	7/19/2016	Jeff Chambers	7:27 AM	7/19/2016
B121-D	7/19/2016	Jeff Chambers	7:28 AM	7/19/2016
B122-A-1	7/19/2016	Jeff Chambers	7:29 AM	7/19/2016
B122-A-2	7/19/2016	Jeff Chambers	7:30 AM	7/19/2016
B122-A-3	7/19/2016	Jeff Chambers	7:31 AM	7/19/2016
B122-A-4	7/19/2016	Jeff Chambers	7:32 AM	7/19/2016
B127-A-1	7/19/2016	Jeff Chambers	7:35 AM	7/19/2016
B127-A-2	7/19/2016	Jeff Chambers	7:36 AM	7/19/2016
B127-A-3	7/19/2016	Jeff Chambers	7:37 AM	7/19/2016
B127-A-4	7/19/2016	Jeff Chambers	7:38 AM	7/19/2016
B127-A-5	7/19/2016	Jeff Chambers	7:39 AM	7/19/2016
C101-A	7/19/2016	Jeff Chambers	7:41 AM	7/19/2016
C101-B	7/19/2016	Jeff Chambers	7:42 AM	7/19/2016
C102-A	7/19/2016	Jeff Chambers	7:43 AM	7/19/2016
C102-B	7/19/2016	Jeff Chambers	7:44 AM	7/19/2016
C103-A	7/19/2016	Jeff Chambers	7:45 AM	7/19/2016
C103-B	7/19/2016	Jeff Chambers	7:46 AM	7/19/2016
C104-A	7/19/2016	Jeff Chambers	7:47 AM	7/19/2016
C104-B	7/19/2016	Jeff Chambers	7:48 AM	7/19/2016
C105-A	7/19/2016	Jeff Chambers	7:49 AM	7/19/2016
C105-B	7/19/2016	Jeff Chambers	7:50 AM	7/19/2016
C106-A	7/19/2016	Jeff Chambers	7:51 AM	7/19/2016
C106-C	7/19/2016	Jeff Chambers	7:52 AM	7/19/2016
C106-D	7/19/2016	Jeff Chambers	7:53 AM	7/19/2016
C109-A-1	7/19/2016	Jeff Chambers	7:54 AM	7/19/2016

0671928
 Page 2 of 7


 Collector's Signature 7-19-16
 Date


 Laboratory Signature 7-19-16 12:15
 Date

Chain of Custody Record-Water Samples
027-Lowrie Primary School: 28995 SW Brown Rd., Wilsonville, OR 97070

C109-A-2	7/19/2016	Jeff Chambers	7:55 AM	7/19/2016
C111-A	7/19/2016	Jeff Chambers	7:56 AM	7/19/2016
B201-A	7/19/2016	Jeff Chambers	8:02 AM	7/19/2016
B201-B	7/19/2016	Jeff Chambers	8:03 AM	7/19/2016
B202-A	7/19/2016	Jeff Chambers	8:04 AM	7/19/2016
B202-B	7/19/2016	Jeff Chambers	8:05 AM	7/19/2016
B203-A	7/19/2016	Jeff Chambers	8:06 AM	7/19/2016
B203-B	7/19/2016	Jeff Chambers	8:07 AM	7/19/2016
B204-A	7/19/2016	Jeff Chambers	8:08 AM	7/19/2016
B204-B	7/19/2016	Jeff Chambers	8:09 AM	7/19/2016
B205-A	7/19/2016	Jeff Chambers	8:10 AM	7/19/2016
B205-B	7/19/2016	Jeff Chambers	8:11 AM	7/19/2016
B206-A	7/19/2016	Jeff Chambers	8:14 AM	7/19/2016
B206-B	7/19/2016	Jeff Chambers	8:15 AM	7/19/2016
B207-A	7/19/2016	Jeff Chambers	8:16 AM	7/19/2016
B207-B	7/19/2016	Jeff Chambers	8:17 AM	7/19/2016
B208-A	7/19/2016	Jeff Chambers	8:18 AM	7/19/2016
B208-B	7/19/2016	Jeff Chambers	8:19 AM	7/19/2016
B209-A	7/19/2016	Jeff Chambers	8:20 AM	7/19/2016
B209-B	7/19/2016	Jeff Chambers	8:21 AM	7/19/2016
B210-A	7/19/2016	Jeff Chambers	8:22 AM	7/19/2016
B210-B	7/19/2016	Jeff Chambers	8:23 AM	7/19/2016
B211-A	7/19/2016	Jeff Chambers	8:12 AM	7/19/2016
B212-A	7/19/2016	Jeff Chambers	8:24 AM	7/19/2016
B218-C	7/19/2016	Jeff Chambers	8:26 AM	7/19/2016
B218-D	7/19/2016	Jeff Chambers	8:27 AM	7/19/2016
B220-A	7/19/2016	Jeff Chambers	8:25 AM	7/19/2016
B221-A-1	7/19/2016	Jeff Chambers	8:26 AM	7/19/2016
B221-A-2	7/19/2016	Jeff Chambers	8:27 AM	7/19/2016
B221-A-3	7/19/2016	Jeff Chambers	8:28 AM	7/19/2016
B221-A-4	7/19/2016	Jeff Chambers	8:29 AM	7/19/2016
B222-A-1	7/19/2016	Jeff Chambers	8:30 AM	7/19/2016
B222-A-2	7/19/2016	Jeff Chambers	8:31 AM	7/19/2016
B222-A-3	7/19/2016	Jeff Chambers	8:32 AM	7/19/2016
B222-A-4	7/19/2016	Jeff Chambers	8:33 AM	7/19/2016
B227-A-1	7/19/2016	Jeff Chambers	8:35 AM	7/19/2016

071928
 page 3 of 4


 Collector's Signature

7-19-16
 Date



 Laboratory Signature

7.19.16 12:15
 Date


Chain of Custody Record-Water Samples
027-Lowrie Primary School: 28995 SW Brown Rd., Wilsonville, OR 97070

B227-A-2	7/19/2016	Jeff Chambers	\8:36	7/19/2016
B227-A-3	7/19/2016	Jeff Chambers	8:37 AM	7/19/2016

u071928
page 4 of 4


Collector's Signature

7-19-16
Date


Laboratory Signature

7.19.16 12:15
Date