



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Revised 1-30-20

Page 1 of 12

LEAD & COPPER RULE REPORT

Client Name: West Linn - Wilsonville School District
2755 SW Borland Rd.
Tualatin, OR 97062

Reference Number: **19-48173**

Project: 025 Meridian Creek Middle School

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 12/19/2019
Report Date: 12/30/2019
Approved By: ajw
Authorized by:

Thanh B Phan
Lab Manager, Portland

| Lab Number | Date Collected | Site / Location | EPA # | Analyte Name | Result | Units | AL | RL | METHOD | Lab | Comments |
|------------|----------------|---|-------|--------------|--------|-------|------|----|--------|------|----------|
| 19_93447 | 12/19/2019 | Room A102 (A102-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 115 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93448 | 12/19/2019 | Room A102 (A102-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 140 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93449 | 12/19/2019 | Room A104 (A104-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 102 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93450 | 12/19/2019 | Room A104 (A104-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 107 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93451 | 12/19/2019 | Room A105 (A105-A-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 114 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93452 | 12/19/2019 | Room A105 (A105-A-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 241 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93453 | 12/19/2019 | Room A105 (A105-A-3) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 225 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93454 | 12/19/2019 | Room A105 (A105-A-4) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 109 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93455 | 12/19/2019 | Room A105 (A105-A-5) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 129 | ppb | 1300 | 5 | 200.8 | 4072 | |

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

LEAD & COPPER RULE REPORT

| Lab Number | Date Collected | Site / Location | EPA # | Analyte Name | Result | Units | AL | RL | METHOD | Lab | Comments |
|------------|----------------|---|-------|--------------|--------|-------|------|----|--------|------|----------|
| 19_93456 | 12/19/2019 | Room A105 (A105-A-6) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 108 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93457 | 12/19/2019 | Room A105 (A105-A-7) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 161 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93458 | 12/19/2019 | Room A105 (A105-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 133 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93459 | 12/19/2019 | Room A106 (A106-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 85.9 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93460 | 12/19/2019 | Room A108 (A108-A-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 101 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93461 | 12/19/2019 | Room A108 (A108-A-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 186 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93462 | 12/19/2019 | Room A108 (A108-A-3) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 172 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93463 | 12/19/2019 | Room A108 (A108-A-4) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 92.5 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93464 | 12/19/2019 | Room A108 (A108-A-5) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 106 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93465 | 12/19/2019 | Room A108 (A108-A-6) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 137 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93466 | 12/19/2019 | Room A108 (A108-A-7) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 101 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93467 | 12/19/2019 | Room A108 (A108-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 110 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93468 | 12/19/2019 | Room A109 (A109-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 108 | ppb | 1300 | 5 | 200.8 | 4072 | |
| | | | | | | | | | | | |

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

| Lab Number | Date Collected | Site / Location | EPA # | Analyte Name | Result | Units | AL | RL | METHOD | Lab | Comments |
|------------|----------------|---|-------|--------------|--------|-------|------|----|--------|------|----------|
| 19_93469 | 12/19/2019 | Room A109 (A109-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 124 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93470 | 12/19/2019 | Room A110 (A110-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 114 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93471 | 12/19/2019 | Room A110 (A110-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 133 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93472 | 12/19/2019 | Room A113 (A113-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 149 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93473 | 12/19/2019 | Room A114 (A114-A-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 60.6 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93474 | 12/19/2019 | Room A114 (A114-A-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 46.4 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93475 | 12/19/2019 | Room A114 (A114-A-3) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 44.8 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93476 | 12/19/2019 | Room A114 (A114-A-4) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 129 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93477 | 12/19/2019 | Room A114 (A114-A-5) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 57.2 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93478 | 12/19/2019 | Room A114 (A114-A-6) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 114 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93479 | 12/19/2019 | Room A114 (A114-A-7) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 59.1 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93480 | 12/19/2019 | Room A115 (A115-A-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 44.5 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93481 | 12/19/2019 | Room A115 (A115-A-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 75.6 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93482 | 12/19/2019 | Room A115 (A115-A-3) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

| Lab Number | Date Collected | Site / Location | EPA # | Analyte Name | Result | Units | AL | RL | METHOD | Lab | Comments |
|------------|----------------|---|-------|--------------|--------|-------|------|----|--------|------|----------|
| 19_93482 | 12/19/2019 | Room A115 (A115-A-3) - 6300 SW Hazel St. Wilsonville OR 97070 | 1022 | COPPER | 82.8 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93483 | 12/19/2019 | Room A115 (A115-A-4) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 108 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93484 | 12/19/2019 | Room A115 (A115-A-5) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 50.3 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93485 | 12/19/2019 | Room A115 (A115-A-6) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 64.8 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93486 | 12/19/2019 | Room A115 (A115-A-7) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 114 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93487 | 12/19/2019 | Room B107 (B107-A-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 93.2 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93488 | 12/19/2019 | Room B107 (B107-A-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 69.9 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93489 | 12/19/2019 | Room B107 (B107-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 123 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93490 | 12/19/2019 | Room B109 (B109-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 264 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93491 | 12/19/2019 | Room B109 (B109-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 247 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93492 | 12/19/2019 | Room B113 (B113-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 144 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93493 | 12/19/2019 | Room B113 (B113-D) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 24.2 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93494 | 12/19/2019 | Room B127 (B127-C-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 28.8 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93495 | 12/19/2019 | Room B127 (B127-C-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 31.7 | ppb | 1300 | 5 | 200.8 | 4072 | |

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

| Lab Number | Date Collected | Site / Location | EPA # | Analyte Name | Result | Units | AL | RL | METHOD | Lab | Comments |
|------------|----------------|---|-------|--------------|--------|-------|------|----|--------|------|----------|
| 19_93496 | 12/19/2019 | Room B127 (B127-D-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 31.9 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93497 | 12/19/2019 | Room C107 (C107-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 107 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93498 | 12/19/2019 | Room C107 (C107-D) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 91.6 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93499 | 12/19/2019 | Room C108 (C108-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 126 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93500 | 12/19/2019 | Room C113 (C113-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 104 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93501 | 12/19/2019 | Room C114 (C114-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 109 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93502 | 12/19/2019 | Room C115 (C115-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 68.1 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93503 | 12/19/2019 | Room C120 (C120-A-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | 1.7 | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 135 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93504 | 12/19/2019 | Room C120 (C120-A-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 93.3 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93505 | 12/19/2019 | Room C120 (C120-A-3) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 84.7 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93506 | 12/19/2019 | Room C130 (C130-A-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 40 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93507 | 12/19/2019 | Room C130 (C130-A-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 48.2 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93508 | 12/19/2019 | Room C130 (C130-A-3) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 78 | ppb | 1300 | 5 | 200.8 | 4072 | |
| | | | | | | | | | | | |

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

| Lab Number | Date Collected | Site / Location | EPA # | Analyte Name | Result | Units | AL | RL | METHOD | Lab | Comments |
|------------|----------------|---|-------|--------------|--------|-------|------|----|--------|------|----------|
| 19_93509 | 12/19/2019 | Room C130 (C130-A-4) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 34.3 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93510 | 12/19/2019 | Room C130 (C130-A-5) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 69.7 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93511 | 12/19/2019 | Room C130 (C130-A-6) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 44.4 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93512 | 12/19/2019 | Room C130 (C130-A-7) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 148 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93513 | 12/19/2019 | Room C138 (C138-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 67.6 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93514 | 12/19/2019 | Room D101 (D101-C-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 12.1 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93515 | 12/19/2019 | Room D101 (D101-C-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 12.2 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93516 | 12/19/2019 | Room D101 (D101-D) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 12.3 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93517 | 12/19/2019 | Room E107 (E107-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 114 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93518 | 12/19/2019 | Room E107 (E107-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 170 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93519 | 12/19/2019 | Room E109 (E109-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 122 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93520 | 12/19/2019 | Room E109 (E109-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 165 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93521 | 12/19/2019 | Room E114 (E114-C-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 19.4 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93522 | 12/19/2019 | Room E114 (E114-C-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

| Lab Number | Date Collected | Site / Location | EPA # | Analyte Name | Result | Units | AL | RL | METHOD | Lab | Comments |
|------------|----------------|---|-------|--------------|--------|-------|------|----|--------|------|----------|
| 19_93522 | 12/19/2019 | Room E114 (E114-C-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1022 | COPPER | 20.7 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93523 | 12/19/2019 | Room E114 (E114-C-3) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 19.9 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93524 | 12/19/2019 | Room E114 (E114-D-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 19.3 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93525 | 12/19/2019 | Room E114 (E114-D-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 23.1 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93526 | 12/19/2019 | Room E115 (E115-C-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 19.5 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93527 | 12/19/2019 | Room E115 (E115-C-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 20.1 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93528 | 12/19/2019 | Room E115 (E115-D) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 21.3 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93529 | 12/19/2019 | Room E118 (E118-A-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 61.5 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93530 | 12/19/2019 | Room E118 (E118-A-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 51.9 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93531 | 12/19/2019 | Room E118 (E118-A-3) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 90.2 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93532 | 12/19/2019 | Room E118 (E118-A-4) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 66.7 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93533 | 12/19/2019 | Room E120 (E120-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 123 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93534 | 12/19/2019 | Room E124 (E124-A-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 62.5 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93535 | 12/19/2019 | Room E124 (E124-A-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 96.1 | ppb | 1300 | 5 | 200.8 | 4072 | |

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

| Lab Number | Date Collected | Site / Location | EPA # | Analyte Name | Result | Units | AL | RL | METHOD | Lab | Comments |
|------------|----------------|---|-------|--------------|--------|-------|------|----|--------|------|----------|
| 19_93536 | 12/19/2019 | Room E124 (E124-A-3) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 51.1 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93537 | 12/19/2019 | Room E124 (E124-A-4) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 96 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93538 | 12/19/2019 | Room E126 (E126-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 133 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93539 | 12/19/2019 | Room E131 (E131-A-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 50 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93540 | 12/19/2019 | Room E131 (E131-A-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 49.3 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93541 | 12/19/2019 | Room E131 (E131-A-3) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 93.1 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93542 | 12/19/2019 | Room E131 (E131-A-4) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 56 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93543 | 12/19/2019 | Room E131 (E131-A-5) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 94.4 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93544 | 12/19/2019 | Room E131 (E131-A-6) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 78.1 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93545 | 12/19/2019 | Room E132 (E132-A-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 45.4 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93546 | 12/19/2019 | Room E132 (E132-A-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 107 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93547 | 12/19/2019 | Room E132 (E132-A-3) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 52.9 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93548 | 12/19/2019 | Room E132 (E132-A-4) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 54 | ppb | 1300 | 5 | 200.8 | 4072 | |

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

| Lab Number | Date Collected | Site / Location | EPA # | Analyte Name | Result | Units | AL | RL | METHOD | Lab | Comments |
|------------|----------------|---|-------|--------------|--------|-------|------|----|--------|------|----------|
| 19_93549 | 12/19/2019 | Room E132 (E132-A-5) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 103 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93550 | 12/19/2019 | Room E132 (E132-A-6) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 85.1 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93551 | 12/19/2019 | Room E135 (E135-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 55 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93552 | 12/19/2019 | Room A202 (A202-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 101 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93553 | 12/19/2019 | Room A202 (A202-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 122 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93554 | 12/19/2019 | Room A204 (A204-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 95.4 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93555 | 12/19/2019 | Room A204 (A204-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 114 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93556 | 12/19/2019 | Room A205 (A205-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 110 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93557 | 12/19/2019 | Room A205 (A205-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 165 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93558 | 12/19/2019 | Room A206 (A206-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 105 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93559 | 12/19/2019 | Room A206 (A206-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 175 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93560 | 12/19/2019 | Room A208 (A208-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 104 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93561 | 12/19/2019 | Room A208 (A208-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 145 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93562 | 12/19/2019 | Room A209 (A209-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

| Lab Number | Date Collected | Site / Location | EPA # | Analyte Name | Result | Units | AL | RL | METHOD | Lab | Comments |
|------------|----------------|---|-------|--------------|--------|-------|------|----|--------|------|----------|
| 19_93562 | 12/19/2019 | Room A209 (A209-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1022 | COPPER | 110 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93563 | 12/19/2019 | Room A209 (A209-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 139 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93564 | 12/19/2019 | Room A210 (A210-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 85.6 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93565 | 12/19/2019 | Room A210 (A210-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 122 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93566 | 12/19/2019 | Room A213 (A213-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 110 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93567 | 12/19/2019 | Room A214 (A214-A-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 100 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93568 | 12/19/2019 | Room A214 (A214-A-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 43.1 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93569 | 12/19/2019 | Room A214 (A214-A-3) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 43.8 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93570 | 12/19/2019 | Room A214 (A214-A-4) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | 5.3 | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 495 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93571 | 12/19/2019 | Room A214 (A214-A-5) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 51.2 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93572 | 12/19/2019 | Room A214 (A214-A-6) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 55.2 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93573 | 12/19/2019 | Room A214 (A214-A-7) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 81.8 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93574 | 12/19/2019 | Room A215 (A215-A-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 50.2 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93575 | 12/19/2019 | Room A215 (A215-A-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 45.8 | ppb | 1300 | 5 | 200.8 | 4072 | |

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

| Lab Number | Date Collected | Site / Location | EPA # | Analyte Name | Result | Units | AL | RL | METHOD | Lab | Comments |
|------------|----------------|---|-------|--------------|--------|-------|------|----|--------|------|----------|
| 19_93576 | 12/19/2019 | Room A215 (A215-A-3) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 52 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93577 | 12/19/2019 | Room A215 (A215-A-4) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 52.2 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93578 | 12/19/2019 | Room A215 (A215-A-5) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 50.2 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93579 | 12/19/2019 | Room A215 (A215-A-6) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 52.4 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93580 | 12/19/2019 | Room A215 (A215-A-7) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 8.2 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93581 | 12/19/2019 | Room B213 (B213-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 97.6 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93582 | 12/19/2019 | Room B214 (B214-A-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 384 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93583 | 12/19/2019 | Room B214 (B214-A-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 124 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93584 | 12/19/2019 | Room B214 (B214-A-3) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 100 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93585 | 12/19/2019 | Room B214 (B214-A-4) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 91.1 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93586 | 12/19/2019 | Room B214 (B214-A-5) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 95.7 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93587 | 12/19/2019 | Room B214 (B214-A-6) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 114 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93588 | 12/19/2019 | Room B214 (B214-A-7) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 137 | ppb | 1300 | 5 | 200.8 | 4072 | |
| | | | | | | | | | | | |

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

| Lab Number | Date Collected | Site / Location | EPA # | Analyte Name | Result | Units | AL | RL | METHOD | Lab | Comments |
|------------|----------------|---|-------|--------------|--------|-------|------|----|--------|------|----------|
| 19_93589 | 12/19/2019 | Room B214 (B214-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 140 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93590 | 12/19/2019 | Room B215 (B215-A) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 168 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93591 | 12/19/2019 | Room B215 (B215-B) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 154 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93592 | 12/19/2019 | Room B227 (B227-C-1) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 18.9 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93593 | 12/19/2019 | Room B227 (B227-C-2) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 22.6 | ppb | 1300 | 5 | 200.8 | 4072 | |
| 19_93594 | 12/19/2019 | Room B227 (B227-D) - 6300 SW Hazel St. Wilsonville OR 97070 | 1030 | LEAD | ND | ppb | 15 | 1 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 23.9 | ppb | 1300 | 5 | 200.8 | 4072 | |
| | | | | | | | | | | | |

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.