EDGE ANALYTICAL

Burlington, WA *Corporate Laboratory (a)*
1620 S Walnut St - Burlington, WA 98233 - **800.755.9295** • 360.757.1400

Bellingham, WA *Microbiology (b)*
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR *Microbiology/Chemistry (d)*
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

Bend, OR *Microbiology (e)*
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

NELAP ACCREDITED TNI LABORATORY

LEAD & COPPER RULE REPORT

Client Name: West Linn - Wilsonville School District
2755 SW Borland Rd.
Tualatin, OR 97062

Reference Number: **18-27845**
Project: 025 Meridian Creek Middle School

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 7/31/2018
Report Date: 8/9/2018
Approved By: anp
Authorized by:

Thanh B Phan
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56604	7/31/2018	A102-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.206	mg/L	1.3	0.005	200.8	4072	
18_56605	7/31/2018	A102-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.296	mg/L	1.3	0.005	200.8	4072	
18_56606	7/31/2018	A104-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.162	mg/L	1.3	0.005	200.8	4072	
18_56607	7/31/2018	A104-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.179	mg/L	1.3	0.005	200.8	4072	
18_56608	7/31/2018	A105-A-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.143	mg/L	1.3	0.005	200.8	4072	
18_56609	7/31/2018	A105-A-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.318	mg/L	1.3	0.005	200.8	4072	
18_56610	7/31/2018	A105-A-3 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.280	mg/L	1.3	0.005	200.8	4072	
18_56611	7/31/2018	A105-A-4 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.258	mg/L	1.3	0.005	200.8	4072	
18_56612	7/31/2018	A105-A-5 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	1.13	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.
If you have any questions concerning this report contact Thanh B Phan at the above phone number.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56613	7/31/2018	A105-A-6 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.189	mg/L	1.3	0.005	200.8	4072	
18_56614	7/31/2018	A105-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.206	mg/L	1.3	0.005	200.8	4072	
18_56615	7/31/2018	A105-A-7 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.271	mg/L	1.3	0.005	200.8	4072	
18_56616	7/31/2018	A106-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.156	mg/L	1.3	0.005	200.8	4072	
18_56617	7/31/2018	A108-A-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.186	mg/L	1.3	0.005	200.8	4072	
18_56618	7/31/2018	A108-A-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.428	mg/L	1.3	0.005	200.8	4072	
18_56619	7/31/2018	A108-A-3 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.294	mg/L	1.3	0.005	200.8	4072	
18_56620	7/31/2018	A108-A-4 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.252	mg/L	1.3	0.005	200.8	4072	
18_56621	7/31/2018	A108-A-5 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.304	mg/L	1.3	0.005	200.8	4072	
18_56622	7/31/2018	A108-A-6 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.211	mg/L	1.3	0.005	200.8	4072	
18_56623	7/31/2018	A108-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.222	mg/L	1.3	0.005	200.8	4072	
18_56624	7/31/2018	A108-A-7 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.280	mg/L	1.3	0.005	200.8	4072	
18_56625	7/31/2018	A109-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.147	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56626	7/31/2018	A109-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.178	mg/L	1.3	0.005	200.8	4072	
18_56627	7/31/2018	A110-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.134	mg/L	1.3	0.005	200.8	4072	
18_56628	7/31/2018	A110-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.185	mg/L	1.3	0.005	200.8	4072	
18_56629	7/31/2018	A113-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.239	mg/L	1.3	0.005	200.8	4072	
18_56630	7/31/2018	A114-A-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.197	mg/L	1.3	0.005	200.8	4072	
18_56631	7/31/2018	A114-A-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.107	mg/L	1.3	0.005	200.8	4072	
18_56632	7/31/2018	A114-A-3 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.041	mg/L	1.3	0.005	200.8	4072	
18_56633	7/31/2018	A114-A-4 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.238	mg/L	1.3	0.005	200.8	4072	
18_56634	7/31/2018	A114-A-5 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.202	mg/L	1.3	0.005	200.8	4072	
18_56635	7/31/2018	A114-A-6 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.183	mg/L	1.3	0.005	200.8	4072	
18_56636	7/31/2018	A114-A-7 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.184	mg/L	1.3	0.005	200.8	4072	
18_56637	7/31/2018	A115-A-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.238	mg/L	1.3	0.005	200.8	4072	
18_56638	7/31/2018	A115-A-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.231	mg/L	1.3	0.005	200.8	4072	
18_56639	7/31/2018	A115-A-3 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56639	7/31/2018	A115-A-3 - 6300 SW Hazel St. Wilsonville OR 97070	1022	COPPER	0.256	mg/L	1.3	0.005	200.8	4072	
18_56640	7/31/2018	A115-A-4 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.290	mg/L	1.3	0.005	200.8	4072	
18_56641	7/31/2018	A115-A-5 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.252	mg/L	1.3	0.005	200.8	4072	
18_56642	7/31/2018	A115-A-6 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.304	mg/L	1.3	0.005	200.8	4072	
18_56643	7/31/2018	A115-A-7 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.273	mg/L	1.3	0.005	200.8	4072	
18_56644	7/31/2018	B107-A-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.125	mg/L	1.3	0.005	200.8	4072	
18_56645	7/31/2018	B107-A-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.070	mg/L	1.3	0.005	200.8	4072	
18_56646	7/31/2018	B107-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.201	mg/L	1.3	0.005	200.8	4072	
18_56647	7/31/2018	B109-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.465	mg/L	1.3	0.005	200.8	4072	
18_56648	7/31/2018	B109-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.295	mg/L	1.3	0.005	200.8	4072	
18_56649	7/31/2018	B113-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.314	mg/L	1.3	0.005	200.8	4072	
18_56650	7/31/2018	B113-D - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.040	mg/L	1.3	0.005	200.8	4072	
18_56651	7/31/2018	B127-C-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.062	mg/L	1.3	0.005	200.8	4072	
18_56652	7/31/2018	B127-C-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.059	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56653	7/31/2018	B127-D - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.087	mg/L	1.3	0.005	200.8	4072	
18_56654	7/31/2018	C107-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.115	mg/L	1.3	0.005	200.8	4072	
18_56655	7/31/2018	C107-D - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.017	mg/L	1.3	0.005	200.8	4072	
18_56656	7/31/2018	C108-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.231	mg/L	1.3	0.005	200.8	4072	
18_56657	7/31/2018	C113-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.105	mg/L	1.3	0.005	200.8	4072	
18_56658	7/31/2018	C114-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.180	mg/L	1.3	0.005	200.8	4072	
18_56659	7/31/2018	C115-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.236	mg/L	1.3	0.005	200.8	4072	
18_56660	7/31/2018	C120-A-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.217	mg/L	1.3	0.005	200.8	4072	
18_56661	7/31/2018	C120-A-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.417	mg/L	1.3	0.005	200.8	4072	
18_56662	7/31/2018	C120-A-3 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.077	mg/L	1.3	0.005	200.8	4072	
18_56663	7/31/2018	C130-A-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.130	mg/L	1.3	0.005	200.8	4072	
18_56664	7/31/2018	C130-A-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.172	mg/L	1.3	0.005	200.8	4072	
18_56665	7/31/2018	C130-A-3 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.098	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56666	7/31/2018	C130-A-4 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.112	mg/L	1.3	0.005	200.8	4072	
18_56667	7/31/2018	C130-A-5 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.085	mg/L	1.3	0.005	200.8	4072	
18_56668	7/31/2018	C130-A-6 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.087	mg/L	1.3	0.005	200.8	4072	
18_56669	7/31/2018	C130-A-7 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.125	mg/L	1.3	0.005	200.8	4072	
18_56670	7/31/2018	C131-A-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.059	mg/L	1.3	0.005	200.8	4072	
18_56671	7/31/2018	C131-A-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.057	mg/L	1.3	0.005	200.8	4072	
18_56672	7/31/2018	C131-A-3 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.078	mg/L	1.3	0.005	200.8	4072	
18_56673	7/31/2018	C131-A-4 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.084	mg/L	1.3	0.005	200.8	4072	
18_56674	7/31/2018	C131-A-5 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.080	mg/L	1.3	0.005	200.8	4072	
18_56675	7/31/2018	C131-A-6 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.127	mg/L	1.3	0.005	200.8	4072	
18_56676	7/31/2018	C132-A-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.046	mg/L	1.3	0.005	200.8	4072	
18_56677	7/31/2018	C132-A-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.152	mg/L	1.3	0.005	200.8	4072	
18_56678	7/31/2018	C132-A-3 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.132	mg/L	1.3	0.005	200.8	4072	
18_56679	7/31/2018	C132-A-4 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56679	7/31/2018	C132-A-4 - 6300 SW Hazel St. Wilsonville OR 97070	1022	COPPER	0.120	mg/L	1.3	0.005	200.8	4072	
18_56680	7/31/2018	C132-A-5 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.089	mg/L	1.3	0.005	200.8	4072	
18_56681	7/31/2018	C132-A-6 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.046	mg/L	1.3	0.005	200.8	4072	
18_56682	7/31/2018	C138-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.096	mg/L	1.3	0.005	200.8	4072	
18_56683	7/31/2018	D101-C-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.030	mg/L	1.3	0.005	200.8	4072	
18_56684	7/31/2018	D101-C-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.030	mg/L	1.3	0.005	200.8	4072	
18_56685	7/31/2018	D101-D - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.030	mg/L	1.3	0.005	200.8	4072	
18_56686	7/31/2018	E107-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.196	mg/L	1.3	0.005	200.8	4072	
18_56687	7/31/2018	E107-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.242	mg/L	1.3	0.005	200.8	4072	
18_56688	7/31/2018	E109-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.123	mg/L	1.3	0.005	200.8	4072	
18_56689	7/31/2018	E109-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.144	mg/L	1.3	0.005	200.8	4072	
18_56690	7/31/2018	E114-C-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.069	mg/L	1.3	0.005	200.8	4072	
18_56691	7/31/2018	E114-C-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.075	mg/L	1.3	0.005	200.8	4072	
18_56692	7/31/2018	E114-C-3 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.132	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56693	7/31/2018	E114-D-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.069	mg/L	1.3	0.005	200.8	4072	
18_56694	7/31/2018	E114-D-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.123	mg/L	1.3	0.005	200.8	4072	
18_56695	7/31/2018	E118-A-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.199	mg/L	1.3	0.005	200.8	4072	
18_56696	7/31/2018	E118-A-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.259	mg/L	1.3	0.005	200.8	4072	
18_56697	7/31/2018	E118-A-3 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.283	mg/L	1.3	0.005	200.8	4072	
18_56698	7/31/2018	E118-A-4 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.238	mg/L	1.3	0.005	200.8	4072	
18_56699	7/31/2018	E120-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.268	mg/L	1.3	0.005	200.8	4072	
18_56700	7/31/2018	E124-A-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.096	mg/L	1.3	0.005	200.8	4072	
18_56701	7/31/2018	E124-A-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.118	mg/L	1.3	0.005	200.8	4072	
18_56702	7/31/2018	E124-A-3 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.150	mg/L	1.3	0.005	200.8	4072	
18_56703	7/31/2018	E124-A-4 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.128	mg/L	1.3	0.005	200.8	4072	
18_56704	7/31/2018	E126-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.212	mg/L	1.3	0.005	200.8	4072	
18_56705	7/31/2018	E135-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.059	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56706	7/31/2018	E135-C-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.064	mg/L	1.3	0.005	200.8	4072	
18_56707	7/31/2018	E135-C-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.066	mg/L	1.3	0.005	200.8	4072	
18_56708	7/31/2018	E135-D - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.062	mg/L	1.3	0.005	200.8	4072	
18_56709	7/31/2018	A202-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.179	mg/L	1.3	0.005	200.8	4072	
18_56710	7/31/2018	A202-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.162	mg/L	1.3	0.005	200.8	4072	
18_56711	7/31/2018	A204-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.122	mg/L	1.3	0.005	200.8	4072	
18_56712	7/31/2018	A204-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.161	mg/L	1.3	0.005	200.8	4072	
18_56713	7/31/2018	A205-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.173	mg/L	1.3	0.005	200.8	4072	
18_56714	7/31/2018	A205-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.574	mg/L	1.3	0.005	200.8	4072	
18_56715	7/31/2018	A206-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.217	mg/L	1.3	0.005	200.8	4072	
18_56716	7/31/2018	A206-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.420	mg/L	1.3	0.005	200.8	4072	
18_56717	7/31/2018	A208-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.153	mg/L	1.3	0.005	200.8	4072	
18_56718	7/31/2018	A208-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.349	mg/L	1.3	0.005	200.8	4072	
18_56719	7/31/2018	A209-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56719	7/31/2018	A209-A - 6300 SW Hazel St. Wilsonville OR 97070	1022	COPPER	0.177	mg/L	1.3	0.005	200.8	4072	
18_56720	7/31/2018	A209-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.223	mg/L	1.3	0.005	200.8	4072	
18_56721	7/31/2018	A210-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.133	mg/L	1.3	0.005	200.8	4072	
18_56722	7/31/2018	A210-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.280	mg/L	1.3	0.005	200.8	4072	
18_56723	7/31/2018	A213-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.237	mg/L	1.3	0.005	200.8	4072	
18_56724	7/31/2018	A214-A-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.213	mg/L	1.3	0.005	200.8	4072	
18_56725	7/31/2018	A214-A-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.171	mg/L	1.3	0.005	200.8	4072	
18_56726	7/31/2018	A214-A-3 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.202	mg/L	1.3	0.005	200.8	4072	
18_56727	7/31/2018	A214-A-4 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.167	mg/L	1.3	0.005	200.8	4072	
18_56728	7/31/2018	A214-A-5 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.176	mg/L	1.3	0.005	200.8	4072	
18_56729	7/31/2018	A214-A-6 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.184	mg/L	1.3	0.005	200.8	4072	
18_56730	7/31/2018	A214-A-7 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.117	mg/L	1.3	0.005	200.8	4072	
18_56731	7/31/2018	A215-A-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.373	mg/L	1.3	0.005	200.8	4072	
18_56732	7/31/2018	A215-A-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.313	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56733	7/31/2018	A215-A-3 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.315	mg/L	1.3	0.005	200.8	4072	
18_56734	7/31/2018	A215-A-4 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.285	mg/L	1.3	0.005	200.8	4072	
18_56735	7/31/2018	A215-A-5 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.204	mg/L	1.3	0.005	200.8	4072	
18_56736	7/31/2018	A215-A-6 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.114	mg/L	1.3	0.005	200.8	4072	
18_56737	7/31/2018	A215-A-7 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.237	mg/L	1.3	0.005	200.8	4072	
18_56738	7/31/2018	B213-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.141	mg/L	1.3	0.005	200.8	4072	
18_56739	7/31/2018	B214-A-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.093	mg/L	1.3	0.005	200.8	4072	
18_56740	7/31/2018	B214-A-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.387	mg/L	1.3	0.005	200.8	4072	
18_56741	7/31/2018	B214-A-3 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.944	mg/L	1.3	0.005	200.8	4072	
18_56742	7/31/2018	B214-A-4 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.149	mg/L	1.3	0.005	200.8	4072	
18_56743	7/31/2018	B214-A-5 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.127	mg/L	1.3	0.005	200.8	4072	
18_56744	7/31/2018	B214-A-6 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.182	mg/L	1.3	0.005	200.8	4072	
18_56745	7/31/2018	B214-A-7 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.170	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56746	7/31/2018	B214-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.151	mg/L	1.3	0.005	200.8	4072	
18_56747	7/31/2018	B215-A - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.213	mg/L	1.3	0.005	200.8	4072	
18_56748	7/31/2018	B215-B - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.398	mg/L	1.3	0.005	200.8	4072	
18_56749	7/31/2018	B227-C-1 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.092	mg/L	1.3	0.005	200.8	4072	
18_56750	7/31/2018	B227-C-2 - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.089	mg/L	1.3	0.005	200.8	4072	
18_56751	7/31/2018	B227-D - 6300 SW Hazel St. Wilsonville OR 97070	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.074	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.