



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946
Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Page 1 of 9

LEAD & COPPER RULE REPORT

Client Name: West Linn - Wilsonville School District
2755 SW Borland Rd.
Tualatin, OR 97062

Reference Number: **18-27290**

Project: 021 Rosemont Ridge
Middle School

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 7/25/2018
Report Date: 8/6/2018
Approved By: anp
Authorized by:

Thanh B Phan
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_55414	7/25/2018	A104-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.047	mg/L	1.3	0.005	200.8	4072	
18_55415	7/25/2018	A105-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.114	mg/L	1.3	0.005	200.8	4072	
18_55416	7/25/2018	A108-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.056	mg/L	1.3	0.005	200.8	4072	
18_55417	7/25/2018	A109-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.048	mg/L	1.3	0.005	200.8	4072	
18_55418	7/25/2018	A109A-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.048	mg/L	1.3	0.005	200.8	4072	
18_55419	7/25/2018	A119-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.061	mg/L	1.3	0.005	200.8	4072	
18_55420	7/25/2018	A124-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.079	mg/L	1.3	0.005	200.8	4072	
18_55421	7/25/2018	A125-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.085	mg/L	1.3	0.005	200.8	4072	
18_55422	7/25/2018	A126-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.026	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_55423	7/25/2018	A127-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.023	mg/L	1.3	0.005	200.8	4072	
18_55424	7/25/2018	A128-C - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.034	mg/L	1.3	0.005	200.8	4072	
18_55425	7/25/2018	A128-D - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.034	mg/L	1.3	0.005	200.8	4072	
18_55426	7/25/2018	A129-A-1 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.053	mg/L	1.3	0.005	200.8	4072	
18_55427	7/25/2018	A129-A-2 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.061	mg/L	1.3	0.005	200.8	4072	
18_55428	7/25/2018	A129-A-3 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.044	mg/L	1.3	0.005	200.8	4072	
18_55429	7/25/2018	A129-A-4 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.073	mg/L	1.3	0.005	200.8	4072	
18_55430	7/25/2018	A129-A-5 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.086	mg/L	1.3	0.005	200.8	4072	
18_55431	7/25/2018	A129-A-6 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.013	mg/L	1.3	0.005	200.8	4072	
18_55432	7/25/2018	A129-A-7 - Rosemont Ridge Middle School	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.067	mg/L	1.3	0.005	200.8	4072	
18_55433	7/25/2018	A129-A-8 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.028	mg/L	1.3	0.005	200.8	4072	
18_55434	7/25/2018	A129-A-9 - Rosemont Ridge Middle School	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.087	mg/L	1.3	0.005	200.8	4072	
18_55435	7/25/2018	A130-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.051	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_55436	7/25/2018	A131-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.025	mg/L	1.3	0.005	200.8	4072	
18_55437	7/25/2018	A134-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.023	mg/L	1.3	0.005	200.8	4072	
18_55438	7/25/2018	A135-A-1 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.026	mg/L	1.3	0.005	200.8	4072	
18_55439	7/25/2018	A135-A-2 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.025	mg/L	1.3	0.005	200.8	4072	
18_55440	7/25/2018	A136-A-1 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.033	mg/L	1.3	0.005	200.8	4072	
18_55441	7/25/2018	A136-A-2 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.032	mg/L	1.3	0.005	200.8	4072	
18_55442	7/25/2018	A137-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.056	mg/L	1.3	0.005	200.8	4072	
18_55443	7/25/2018	A138-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.057	mg/L	1.3	0.005	200.8	4072	
18_55444	7/25/2018	A139-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.022	mg/L	1.3	0.005	200.8	4072	
18_55445	7/25/2018	A140-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.028	mg/L	1.3	0.005	200.8	4072	
18_55446	7/25/2018	A142-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.022	mg/L	1.3	0.005	200.8	4072	
18_55447	7/25/2018	A143-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.048	mg/L	1.3	0.005	200.8	4072	
18_55448	7/25/2018	A144-A-1 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.122	mg/L	1.3	0.005	200.8	4072	
18_55449	7/25/2018	A144-A-2 - Rosemont Ridge Middle School	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_55449	7/25/2018	A144-A-2 - Rosemont Ridge Middle School	1022	COPPER	0.062	mg/L	1.3	0.005	200.8	4072	
18_55450	7/25/2018	A144-A-3 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.036	mg/L	1.3	0.005	200.8	4072	
18_55451	7/25/2018	A144-A-4 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.019	mg/L	1.3	0.005	200.8	4072	
18_55452	7/25/2018	A144-A-5 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.060	mg/L	1.3	0.005	200.8	4072	
18_55453	7/25/2018	A144-A-6 - Rosemont Ridge Middle School	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.179	mg/L	1.3	0.005	200.8	4072	
18_55454	7/25/2018	A144-A-7 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.032	mg/L	1.3	0.005	200.8	4072	
18_55455	7/25/2018	A144-A-8 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.058	mg/L	1.3	0.005	200.8	4072	
18_55456	7/25/2018	A144-A-9 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.039	mg/L	1.3	0.005	200.8	4072	
18_55457	7/25/2018	B101-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.103	mg/L	1.3	0.005	200.8	4072	
18_55458	7/25/2018	B102-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.094	mg/L	1.3	0.005	200.8	4072	
18_55459	7/25/2018	B103-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.045	mg/L	1.3	0.005	200.8	4072	
18_55460	7/25/2018	B104-A-1 - Rosemont Ridge Middle School	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.131	mg/L	1.3	0.005	200.8	4072	
18_55461	7/25/2018	B104-A-2 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.046	mg/L	1.3	0.005	200.8	4072	
18_55462	7/25/2018	B104-A-3 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.055	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_55463	7/25/2018	B104-A-4 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.057	mg/L	1.3	0.005	200.8	4072	
18_55464	7/25/2018	B104-A-5 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.216	mg/L	1.3	0.005	200.8	4072	
18_55465	7/25/2018	B104-A-6 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.171	mg/L	1.3	0.005	200.8	4072	
18_55466	7/25/2018	B104-A-7 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.099	mg/L	1.3	0.005	200.8	4072	
18_55467	7/25/2018	B104-A-8 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.053	mg/L	1.3	0.005	200.8	4072	
18_55468	7/25/2018	B104-A-9 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.068	mg/L	1.3	0.005	200.8	4072	
18_55469	7/25/2018	B105-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.048	mg/L	1.3	0.005	200.8	4072	
18_55470	7/25/2018	B106-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.052	mg/L	1.3	0.005	200.8	4072	
18_55471	7/25/2018	B107-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.042	mg/L	1.3	0.005	200.8	4072	
18_55472	7/25/2018	B110-C - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.056	mg/L	1.3	0.005	200.8	4072	
18_55473	7/25/2018	B110-D - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.053	mg/L	1.3	0.005	200.8	4072	
18_55474	7/25/2018	B111-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.030	mg/L	1.3	0.005	200.8	4072	
18_55475	7/25/2018	B112-A-1 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.054	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_55476	7/25/2018	B112-A-2 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.049	mg/L	1.3	0.005	200.8	4072	
18_55477	7/25/2018	B113-A-1 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.031	mg/L	1.3	0.005	200.8	4072	
18_55478	7/25/2018	B113-A-2 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.039	mg/L	1.3	0.005	200.8	4072	
18_55479	7/25/2018	B114-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.144	mg/L	1.3	0.005	200.8	4072	
18_55480	7/25/2018	B116-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.051	mg/L	1.3	0.005	200.8	4072	
18_55481	7/25/2018	B117-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.060	mg/L	1.3	0.005	200.8	4072	
18_55482	7/25/2018	B118-A-1 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.060	mg/L	1.3	0.005	200.8	4072	
18_55483	7/25/2018	B118-A-2 - Rosemont Ridge Middle School	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.064	mg/L	1.3	0.005	200.8	4072	
18_55484	7/25/2018	B118-A-3 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.221	mg/L	1.3	0.005	200.8	4072	
18_55485	7/25/2018	B118-A-4 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.114	mg/L	1.3	0.005	200.8	4072	
18_55486	7/25/2018	B118-A-5 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.225	mg/L	1.3	0.005	200.8	4072	
18_55487	7/25/2018	B118-A-6 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.042	mg/L	1.3	0.005	200.8	4072	
18_55488	7/25/2018	B118-A-7 - Rosemont Ridge Middle School	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.027	mg/L	1.3	0.005	200.8	4072	
18_55489	7/25/2018	B118-A-8 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_55489	7/25/2018	B118-A-8 - Rosemont Ridge Middle School	1022	COPPER	0.026	mg/L	1.3	0.005	200.8	4072	
18_55490	7/25/2018	B118-A-9 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.146	mg/L	1.3	0.005	200.8	4072	
18_55491	7/25/2018	B119-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.064	mg/L	1.3	0.005	200.8	4072	
18_55492	7/25/2018	B120-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.066	mg/L	1.3	0.005	200.8	4072	
18_55493	7/25/2018	B121-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.063	mg/L	1.3	0.005	200.8	4072	
18_55494	7/25/2018	C101-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.040	mg/L	1.3	0.005	200.8	4072	
18_55495	7/25/2018	C101-C-1 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.049	mg/L	1.3	0.005	200.8	4072	
18_55496	7/25/2018	C101-C-2 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.037	mg/L	1.3	0.005	200.8	4072	
18_55497	7/25/2018	C103-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.060	mg/L	1.3	0.005	200.8	4072	
18_55498	7/25/2018	C104-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.059	mg/L	1.3	0.005	200.8	4072	
18_55499	7/25/2018	C105-A-1 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.041	mg/L	1.3	0.005	200.8	4072	
18_55500	7/25/2018	C105-A-2 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.078	mg/L	1.3	0.005	200.8	4072	
18_55501	7/25/2018	C106-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.062	mg/L	1.3	0.005	200.8	4072	
18_55502	7/25/2018	C107-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.033	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_55503	7/25/2018	D108-A-1 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.065	mg/L	1.3	0.005	200.8	4072	
18_55504	7/25/2018	D108-A-2 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.074	mg/L	1.3	0.005	200.8	4072	
18_55505	7/25/2018	D109-A-1 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.051	mg/L	1.3	0.005	200.8	4072	
18_55506	7/25/2018	D109-A-2 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.055	mg/L	1.3	0.005	200.8	4072	
18_55507	7/25/2018	D111-C-1 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.065	mg/L	1.3	0.005	200.8	4072	
18_55508	7/25/2018	D111-D - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.058	mg/L	1.3	0.005	200.8	4072	
18_55509	7/25/2018	(Gym) D111-C-2 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.079	mg/L	1.3	0.005	200.8	4072	
18_55510	7/25/2018	(Gym) D111-C-3 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.072	mg/L	1.3	0.005	200.8	4072	
18_55511	7/25/2018	D113-C-1 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.065	mg/L	1.3	0.005	200.8	4072	
18_55512	7/25/2018	D113-C-2 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.067	mg/L	1.3	0.005	200.8	4072	
18_55513	7/25/2018	D114B-A - Rosemont Ridge Middle School	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.097	mg/L	1.3	0.005	200.8	4072	
18_55514	7/25/2018	D114-A-1 - Rosemont Ridge Middle School	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.053	mg/L	1.3	0.005	200.8	4072	
18_55515	7/25/2018	D114-A-2 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.064	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_55516	7/25/2018	D114-A-3 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.078	mg/L	1.3	0.005	200.8	4072	
18_55517	7/25/2018	D118-A-1 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.067	mg/L	1.3	0.005	200.8	4072	
18_55518	7/25/2018	D118-A-2 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.071	mg/L	1.3	0.005	200.8	4072	
18_55519	7/25/2018	D118-A-3 - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.071	mg/L	1.3	0.005	200.8	4072	
18_55520	7/25/2018	D123-A-1 - Rosemont Ridge Middle School	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.076	mg/L	1.3	0.005	200.8	4072	
18_55521	7/25/2018	D123-A-2 - Rosemont Ridge Middle School	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.086	mg/L	1.3	0.005	200.8	4072	
18_55522	7/25/2018	D123-A-3 - Rosemont Ridge Middle School	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.075	mg/L	1.3	0.005	200.8	4072	
18_55523	7/25/2018	E104-A - Rosemont Ridge Middle School	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.097	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.