

Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757

Bellingham, WA Microbiology (b) 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212 Portland, OR Microbiology/Chemistry (c) 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d) 540 SW Third Street - Corvallis, OR 97333 - 541,753,4946

Bend, OR Microbiology (e) 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Page 1 of 1

Project: 005-Sunset Primary

School

Reference Number: 18-29782

LEAD & COPPER RULE REPORT

Client Name: West Linn - Wilsonville School District

2755 SW Borland Rd. Tualatin, OR 97062

System Name: Analyst: bj

System ID Number: Date Received: 8/13/2018

DWP Source Number: Report Date: 8/21/2018

Multiple Sources: Approved By: anp

Sample Type: Authorized by:

Sample Purpose: Investigative or Other

County:

Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA#	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_60198	8/13/2018	A164-A - 2351 Oxford St., West Linn, OR 97068	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.101	mg/L	1.3	0.005	200.8	4072	
18_60199	8/13/2018	C134-A-1 - 2351 Oxford St., West Linn, OR 97068	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.093	mg/L	1.3	0.005	200.8	4072	

NOTES:

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).