



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Revised 1-30-20

Page 1 of 8

LEAD & COPPER RULE REPORT

Client Name: West Linn - Wilsonville School District
2755 SW Borland Rd.
Tualatin, OR 97062

Reference Number: **19-48321**

Project: 005 Sunset Primary School

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 12/20/2019
Report Date: 12/31/2019
Approved By: ajw
Authorized by:

Thanh B Phan
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
19_93856	12/20/2019	Room A155 (A155-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	133	ppb	1300	5	200.8	4072	
19_93857	12/20/2019	Room A157 (A157-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	49.2	ppb	1300	5	200.8	4072	
19_93858	12/20/2019	Room A159 (A159-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	35.4	ppb	1300	5	200.8	4072	
19_93859	12/20/2019	Room A164 (A164-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	218	ppb	1300	5	200.8	4072	
19_93860	12/20/2019	Room A171 (A171-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	220	ppb	1300	5	200.8	4072	
19_93861	12/20/2019	Room A180 (A180-C-1) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	32.1	ppb	1300	5	200.8	4072	
19_93862	12/20/2019	Room A180 (A180-C-2) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	36.7	ppb	1300	5	200.8	4072	
19_93863	12/20/2019	Room A180 (A180-D) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	34.4	ppb	1300	5	200.8	4072	
19_93864	12/20/2019	Room A181 (A181-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	261	ppb	1300	5	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
19_93865	12/20/2019	Room A191 (A191-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	130	ppb	1300	5	200.8	4072	
19_93866	12/20/2019	Room A192 (A192-A-1) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	34.4	ppb	1300	5	200.8	4072	
19_93867	12/20/2019	Room A192 (A192-A-2) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	41.2	ppb	1300	5	200.8	4072	
19_93868	12/20/2019	Room A192 (A192-A-3) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	72.7	ppb	1300	5	200.8	4072	
19_93869	12/20/2019	Room A192 (A192-A-4) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	119	ppb	1300	5	200.8	4072	
19_93870	12/20/2019	Room A193 (A193-A-1) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	34.7	ppb	1300	5	200.8	4072	
19_93871	12/20/2019	Room A193 (A193-A-2) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	40.1	ppb	1300	5	200.8	4072	
19_93872	12/20/2019	Room A193 (A193-A-3) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	36.7	ppb	1300	5	200.8	4072	
19_93873	12/20/2019	Room A193 (A193-A-4) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	35.6	ppb	1300	5	200.8	4072	
19_93874	12/20/2019	Room A197 (A193-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	43.3	ppb	1300	5	200.8	4072	
19_93875	12/20/2019	Room B110 (B110-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	173	ppb	1300	5	200.8	4072	
19_93876	12/20/2019	Room B110 (B110-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	276	ppb	1300	5	200.8	4072	
19_93877	12/20/2019	Room B111 (B111-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	125	ppb	1300	5	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
19_93878	12/20/2019	Room B111 (B111-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	210	ppb	1300	5	200.8	4072	
19_93879	12/20/2019	Room B112 (B112-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	135	ppb	1300	5	200.8	4072	
19_93880	12/20/2019	Room B112 (B112-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	189	ppb	1300	5	200.8	4072	
19_93881	12/20/2019	Room B113 (B113-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	113	ppb	1300	5	200.8	4072	
19_93882	12/20/2019	Room B113 (B113-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	170	ppb	1300	5	200.8	4072	
19_93883	12/20/2019	Room B114 (B114-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	207	ppb	1300	5	200.8	4072	
19_93884	12/20/2019	Room B114 (B114-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	246	ppb	1300	5	200.8	4072	
19_93885	12/20/2019	Room B115 (B115-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	206	ppb	1300	5	200.8	4072	
19_93886	12/20/2019	Room B120 (B120-C-1) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	17.2	ppb	1300	5	200.8	4072	
19_93887	12/20/2019	Room B120 (B120-C-2) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	18.2	ppb	1300	5	200.8	4072	
19_93888	12/20/2019	Room B120 (B120-D) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	17.7	ppb	1300	5	200.8	4072	
19_93889	12/20/2019	Room B120 (B120-E-1) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	64.6	ppb	1300	5	200.8	4072	
19_93890	12/20/2019	Room B120 (B120-E-2) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	65	ppb	1300	5	200.8	4072	
19_93891	12/20/2019	Room B120 (B120-E-3) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
19_93891	12/20/2019	Room B120 (B120-E-3) - 2351 Oxford St. West Linn OR	1022	COPPER	66	ppb	1300	5	200.8	4072	
19_93892	12/20/2019	Room B120 (B120-E-4) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	32.8	ppb	1300	5	200.8	4072	
19_93893	12/20/2019	Room B120 (B120-E-5) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	32.9	ppb	1300	5	200.8	4072	
19_93894	12/20/2019	Room B120 (B120-E-6) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	33.2	ppb	1300	5	200.8	4072	
19_93895	12/20/2019	Room B142 (B142-A) - 2351 Oxford St. West Linn OR	1030	LEAD	4.7	ppb	15	1	200.8	4072	
			1022	COPPER	368	ppb	1300	5	200.8	4072	
19_93896	12/20/2019	Room B147 (B147-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	39.8	ppb	1300	5	200.8	4072	
19_93897	12/20/2019	Room C101 (C101--A) - 2351 Oxford St. West Linn OR	1030	LEAD	1.1	ppb	15	1	200.8	4072	
			1022	COPPER	122	ppb	1300	5	200.8	4072	
19_93898	12/20/2019	Room C101 (C101--B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	155	ppb	1300	5	200.8	4072	
19_93899	12/20/2019	Room C102 (C102--A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	201	ppb	1300	5	200.8	4072	
19_93900	12/20/2019	Room C102 (C102--B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	194	ppb	1300	5	200.8	4072	
19_93901	12/20/2019	Room C103 (C103--A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	138	ppb	1300	5	200.8	4072	
19_93902	12/20/2019	Room C103 (C103-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	186	ppb	1300	5	200.8	4072	
19_93903	12/20/2019	Room C104 (C104-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	158	ppb	1300	5	200.8	4072	
19_93904	12/20/2019	Room C104 (C104--B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	214	ppb	1300	5	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
19_93905	12/20/2019	Room C105 (C105-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	168	ppb	1300	5	200.8	4072	
19_93906	12/20/2019	Room C105 (C105-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	302	ppb	1300	5	200.8	4072	
19_93907	12/20/2019	Room C107 (C107-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	151	ppb	1300	5	200.8	4072	
19_93908	12/20/2019	Room C131 (C131-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	34	ppb	1300	5	200.8	4072	
19_93909	12/20/2019	Room C134 (C134-A-1) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	71.5	ppb	1300	5	200.8	4072	
19_93910	12/20/2019	Room C134 (C134-A-2) - 2351 Oxford St. West Linn OR	1030	LEAD	1.1	ppb	15	1	200.8	4072	
			1022	COPPER	170	ppb	1300	5	200.8	4072	
19_93911	12/20/2019	Room C134 (C134-A-3) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	66.7	ppb	1300	5	200.8	4072	
19_93912	12/20/2019	Room B210 (B210-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	127	ppb	1300	5	200.8	4072	
19_93913	12/20/2019	Room B210 (B210-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	188	ppb	1300	5	200.8	4072	
19_93914	12/20/2019	Room B211 (B211-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	119	ppb	1300	5	200.8	4072	
19_93915	12/20/2019	Room B211 (B211-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	174	ppb	1300	5	200.8	4072	
19_93916	12/20/2019	Room B212 (B212-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	148	ppb	1300	5	200.8	4072	
19_93917	12/20/2019	Room B212 (B212-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	143	ppb	1300	5	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
19_93918	12/20/2019	Room B213 (B213-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	114	ppb	1300	5	200.8	4072	
19_93919	12/20/2019	Room B213 (B213-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	143	ppb	1300	5	200.8	4072	
19_93920	12/20/2019	Room B214 (B214-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	205	ppb	1300	5	200.8	4072	
19_93921	12/20/2019	Room B214 (B214-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	222	ppb	1300	5	200.8	4072	
19_93922	12/20/2019	Room B216 (B216-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	176	ppb	1300	5	200.8	4072	
19_93923	12/20/2019	Room B240 (B240-C-1) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	14.8	ppb	1300	5	200.8	4072	
19_93924	12/20/2019	Room B240 (B240-C-2) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	16.6	ppb	1300	5	200.8	4072	
19_93925	12/20/2019	Room B240 (B240-D-1) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	16.6	ppb	1300	5	200.8	4072	
19_93926	12/20/2019	Room B240 (B240-E-1) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	57.3	ppb	1300	5	200.8	4072	
19_93927	12/20/2019	Room B240 (B240-E-2) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	70.8	ppb	1300	5	200.8	4072	
19_93928	12/20/2019	Room B240 (B240-E-3) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	67.5	ppb	1300	5	200.8	4072	
19_93929	12/20/2019	Room B240 (B240-E-4) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	32.1	ppb	1300	5	200.8	4072	
19_93930	12/20/2019	Room B240 (B240-E-5) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	37.4	ppb	1300	5	200.8	4072	
19_93931	12/20/2019	Room B240 (B240-E-6) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
19_93931	12/20/2019	Room B240 (B240-E-6) - 2351 Oxford St. West Linn OR	1022	COPPER	35.7	ppb	1300	5	200.8	4072	
19_93932	12/20/2019	Room B247 (B247-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	45.2	ppb	1300	5	200.8	4072	
19_93933	12/20/2019	Room C201 (C201-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	81.1	ppb	1300	5	200.8	4072	
19_93934	12/20/2019	Room C201 (C201-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	95.4	ppb	1300	5	200.8	4072	
19_93935	12/20/2019	Room C202 (C202-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	173	ppb	1300	5	200.8	4072	
19_93936	12/20/2019	Room C202 (C202-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	160	ppb	1300	5	200.8	4072	
19_93937	12/20/2019	Room C203 (C203-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	101	ppb	1300	5	200.8	4072	
19_93938	12/20/2019	Room C203 (C203-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	143	ppb	1300	5	200.8	4072	
19_93939	12/20/2019	Room C204 (C204-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	111	ppb	1300	5	200.8	4072	
19_93940	12/20/2019	Room C204 (C204-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	163	ppb	1300	5	200.8	4072	
19_93941	12/20/2019	Room C205 (C205-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	151	ppb	1300	5	200.8	4072	
19_93942	12/20/2019	Room C205 (C205-B) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	293	ppb	1300	5	200.8	4072	
19_93943	12/20/2019	Room C207 (C207-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	134	ppb	1300	5	200.8	4072	
19_93944	12/20/2019	Room C231 (C231-A) - 2351 Oxford St. West Linn OR	1030	LEAD	ND	ppb	15	1	200.8	4072	
			1022	COPPER	29.5	ppb	1300	5	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
19_93945	12/20/2019	Room C234 (C234-A-1) - 2351 Oxford St. West Linn OR	1030	LEAD	8	ppb	15	1	200.8	4072	
			1022	COPPER	15.9	ppb	1300	5	200.8	4072	
19_93946	12/20/2019	Room C234 (C234-A-2) - 2351 Oxford St. West Linn OR	1030	LEAD	5.1	ppb	15	1	200.8	4072	
			1022	COPPER	99.3	ppb	1300	5	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.