



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



LEAD & COPPER RULE REPORT

Client Name: West Linn - Wilsonville School District
2755 SW Borland Rd.
Tualatin, OR 97062

Reference Number: **18-27633**

Project: 005 - Sunset Primary School

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 7/27/2018
Report Date: 8/9/2018
Approved By: anp
Authorized by:

Thanh B Phan
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56109	7/27/2018	A155-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.224	mg/L	1.3	0.005	200.8	4072	
18_56110	7/27/2018	A157-A - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.201	mg/L	1.3	0.005	200.8	4072	
18_56111	7/27/2018	A159-A - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.056	mg/L	1.3	0.005	200.8	4072	
18_56112	7/27/2018	A164-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	2.75	mg/L	1.3	0.005	200.8	4072	
18_56113	7/27/2018	A180-C-1 - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.116	mg/L	1.3	0.005	200.8	4072	
18_56114	7/27/2018	A180-C-2 - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.112	mg/L	1.3	0.005	200.8	4072	
18_56115	7/27/2018	A180-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.345	mg/L	1.3	0.005	200.8	4072	
18_56116	7/27/2018	A180-D - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.098	mg/L	1.3	0.005	200.8	4072	
18_56117	7/27/2018	A191-A - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.088	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56118	7/27/2018	A192-A-1 - 2351 Oxford St. West Linn OR	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.068	mg/L	1.3	0.005	200.8	4072	
18_56119	7/27/2018	A192-A-2 - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.135	mg/L	1.3	0.005	200.8	4072	
18_56120	7/27/2018	A192-A-3 - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.075	mg/L	1.3	0.005	200.8	4072	
18_56121	7/27/2018	A192-A-4 - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.062	mg/L	1.3	0.005	200.8	4072	
18_56122	7/27/2018	A193-A-1 - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.087	mg/L	1.3	0.005	200.8	4072	
18_56123	7/27/2018	A193-A-2 - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.061	mg/L	1.3	0.005	200.8	4072	
18_56124	7/27/2018	A193-A-3 - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.054	mg/L	1.3	0.005	200.8	4072	
18_56125	7/27/2018	A193-A-4 - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.067	mg/L	1.3	0.005	200.8	4072	
18_56126	7/27/2018	A197-A - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.052	mg/L	1.3	0.005	200.8	4072	
18_56127	7/27/2018	B110-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.152	mg/L	1.3	0.005	200.8	4072	
18_56128	7/27/2018	B110-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.188	mg/L	1.3	0.005	200.8	4072	
18_56129	7/27/2018	B111-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.244	mg/L	1.3	0.005	200.8	4072	
18_56130	7/27/2018	B111-B - 2351 Oxford St. West Linn OR	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.269	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56131	7/27/2018	B112-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.137	mg/L	1.3	0.005	200.8	4072	
18_56132	7/27/2018	B112-B - 2351 Oxford St. West Linn OR	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.180	mg/L	1.3	0.005	200.8	4072	
18_56133	7/27/2018	B113-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.383	mg/L	1.3	0.005	200.8	4072	
18_56134	7/27/2018	B113-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.378	mg/L	1.3	0.005	200.8	4072	
18_56135	7/27/2018	B114-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.284	mg/L	1.3	0.005	200.8	4072	
18_56136	7/27/2018	B114-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.571	mg/L	1.3	0.005	200.8	4072	
18_56137	7/27/2018	B115-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.157	mg/L	1.3	0.005	200.8	4072	
18_56138	7/27/2018	B120-C-1 - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.139	mg/L	1.3	0.005	200.8	4072	
18_56139	7/27/2018	B120-C-2 - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.140	mg/L	1.3	0.005	200.8	4072	
18_56140	7/27/2018	B120-D - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.123	mg/L	1.3	0.005	200.8	4072	
18_56141	7/27/2018	B142-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.399	mg/L	1.3	0.005	200.8	4072	
18_56142	7/27/2018	B147-A - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.089	mg/L	1.3	0.005	200.8	4072	
18_56143	7/27/2018	C101-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.103	mg/L	1.3	0.005	200.8	4072	
18_56144	7/27/2018	C101-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56144	7/27/2018	C101-B - 2351 Oxford St. West Linn OR	1022	COPPER	0.144	mg/L	1.3	0.005	200.8	4072	
18_56145	7/27/2018	C102-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.138	mg/L	1.3	0.005	200.8	4072	
18_56146	7/27/2018	C102-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.112	mg/L	1.3	0.005	200.8	4072	
18_56147	7/27/2018	C103-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.098	mg/L	1.3	0.005	200.8	4072	
18_56148	7/27/2018	C103-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.065	mg/L	1.3	0.005	200.8	4072	
18_56149	7/27/2018	C104-A - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.053	mg/L	1.3	0.005	200.8	4072	
18_56150	7/27/2018	C104-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.056	mg/L	1.3	0.005	200.8	4072	
18_56151	7/27/2018	C105-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.154	mg/L	1.3	0.005	200.8	4072	
18_56152	7/27/2018	C105-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.235	mg/L	1.3	0.005	200.8	4072	
18_56153	7/27/2018	C107-A - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.065	mg/L	1.3	0.005	200.8	4072	
18_56154	7/27/2018	C131-A - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.042	mg/L	1.3	0.005	200.8	4072	
18_56155	7/27/2018	C134-A-1 - 2351 Oxford St. West Linn OR	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	6.33	mg/L	1.3	0.005	200.8	4072	
18_56156	7/27/2018	C134-A-2 - 2351 Oxford St. West Linn OR	1030	LEAD	0.009	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.120	mg/L	1.3	0.005	200.8	4072	
18_56157	7/27/2018	B210-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.137	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56158	7/27/2018	B210-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.128	mg/L	1.3	0.005	200.8	4072	
18_56159	7/27/2018	B211-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.171	mg/L	1.3	0.005	200.8	4072	
18_56160	7/27/2018	B211-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.168	mg/L	1.3	0.005	200.8	4072	
18_56161	7/27/2018	B212-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.137	mg/L	1.3	0.005	200.8	4072	
18_56162	7/27/2018	B212-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.137	mg/L	1.3	0.005	200.8	4072	
18_56163	7/27/2018	B213-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.162	mg/L	1.3	0.005	200.8	4072	
18_56164	7/27/2018	B213-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.141	mg/L	1.3	0.005	200.8	4072	
18_56165	7/27/2018	B214-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.285	mg/L	1.3	0.005	200.8	4072	
18_56166	7/27/2018	B214-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.203	mg/L	1.3	0.005	200.8	4072	
18_56167	7/27/2018	B216-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.104	mg/L	1.3	0.005	200.8	4072	
18_56168	7/27/2018	B240-C-1 - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.168	mg/L	1.3	0.005	200.8	4072	
18_56169	7/27/2018	B240-C-2 - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.177	mg/L	1.3	0.005	200.8	4072	
18_56170	7/27/2018	B240-D - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.168	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_56171	7/27/2018	C201-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.066	mg/L	1.3	0.005	200.8	4072	
18_56172	7/27/2018	C201-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.069	mg/L	1.3	0.005	200.8	4072	
18_56173	7/27/2018	C202-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.048	mg/L	1.3	0.005	200.8	4072	
18_56174	7/27/2018	C202-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.057	mg/L	1.3	0.005	200.8	4072	
18_56175	7/27/2018	C203-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.083	mg/L	1.3	0.005	200.8	4072	
18_56176	7/27/2018	C203-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.050	mg/L	1.3	0.005	200.8	4072	
18_56177	7/27/2018	C204-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.095	mg/L	1.3	0.005	200.8	4072	
18_56178	7/27/2018	C204-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.049	mg/L	1.3	0.005	200.8	4072	
18_56179	7/27/2018	C205-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.190	mg/L	1.3	0.005	200.8	4072	
18_56180	7/27/2018	C205-B - 2351 Oxford St. West Linn OR	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.101	mg/L	1.3	0.005	200.8	4072	
18_56181	7/27/2018	C207-A - 2351 Oxford St. West Linn OR	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.047	mg/L	1.3	0.005	200.8	4072	
18_56182	7/27/2018	C234-A-1 - 2351 Oxford St. West Linn OR	1030	LEAD	0.011	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.062	mg/L	1.3	0.005	200.8	4072	
18_56183	7/27/2018	C234-A-2 - 2351 Oxford St. West Linn OR	1030	LEAD	0.007	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.188	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.