WLWSD QUARTERLY SAFETY INSPECTIONS

ISSUE LOG

DATE: 7/14/2016 FACILITY: WHS Page:

Number	Location	Issue Code	Notes	W.O.
	Rm. 227		Items hanging from lights	
	Rm. 214-A		Items blocking fire exit	
	Rm. 218-A		Items blocking electric panel	
	Rm. 103		Extension cord plugged to surge	
	Rm. 104-A		Surge protector tripping hazard	
	B-11		Door does not close wrestling room	