WLWSD QUARTERLY SAFETY INSPECTIONS

ISSUE LOG

DATE: 9/20/2016 FACILITY: WLHS Page:

Number	Location	Issue Code	Notes	W.O.
	B-114 Elect Rm.		Items in front of panels	
	A-103		Surge protector - daisy chained	
	E- 103		Surge protector - daisy chained	
	D-102		Extension cord plugged to surge protector	
	D-201		Items hanging from lights	
	C-204		Door blocked for egress	