

PIXIS Labs

Accurate. Reliable. On Time.

Pixis Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

Job Number: 6083129
Report Date: 09/09/2016
ORELAP #: OR100028
Project No: 001-West Linn High School

Cover Letter

Pat McGough
West Linn School District
2755 SW Borland
West Linn, OR 97068

Dear Pat McGough,

Enclosed please find Pixis Labs analytical report for samples received as order number 6083129 on 08/31/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed

Richard Reid

Project Manager

Sample Results

Sample: G204-C-1		Collected: 08/31/16 07:25		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 120478		Received: 08/31/16 13:36		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.562	1.3	mg/L	0.0010	1	29362-231		09/06/16 21:48	
Lead	0.0002	0.02	mg/L	0.0002	1	29362-231		09/06/16 21:48	
Sample: B207-B		Collected: 08/31/16 07:34		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 120479		Received: 08/31/16 13:36		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.470	1.3	mg/L	0.0010	1	29362-232		09/06/16 21:50	
Lead	0.0019	0.02	mg/L	0.0002	1	29362-232		09/06/16 21:50	
Sample: C205-A-4		Collected: 08/31/16 07:40		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 120480		Received: 08/31/16 13:36		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.229	1.3	mg/L	0.0010	1	29362-233		09/06/16 21:52	
Lead	0.0018	0.02	mg/L	0.0002	1	29362-233		09/06/16 21:52	
Sample: C104-A-4		Collected: 08/31/16 07:45		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 120481		Received: 08/31/16 13:36		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.264	1.3	mg/L	0.0010	1	29362-234		09/06/16 21:55	
Lead	0.0008	0.02	mg/L	0.0002	1	29362-234		09/06/16 21:55	
Sample: G146A-A		Collected: 08/31/16 07:50		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 120482		Received: 08/31/16 13:36		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.210	1.3	mg/L	0.0010	1	29362-235		09/06/16 21:57	
Lead	0.0052	0.02	mg/L	0.0002	1	29362-235		09/06/16 21:57	
Sample: H024-A-1		Collected: 08/31/16 07:56		Temp: 23 C		Matrix: Drinking Water			
Lab ID: 120483		Received: 08/31/16 13:36		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.145	1.3	mg/L	0.0010	1	29369-29		09/06/16 23:00	
Lead	0.0010	0.02	mg/L	0.0002	1	29369-29		09/06/16 23:00	

Abbreviations

- MRL Method Reporting Limit
- ND None Detected at or above the MRL
- Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

Units of Measure:

mg/L Milligrams Per Liter

Chain of Custody Record-Water Samples
001-West Linn High School: 5464 West "A" St., West Linn, OR 97068 *Pb/Cu*

Location/Site	Date Collected	Collector's Name	Time	Date Delivered
G204-C-1	8/31/2016	Steve Matthias	7:25 AM	8/31/2016
B207-B	8/31/2016	Steve Matthias	7:34 AM	8/31/2016
C205-A-4	8/31/2016	Steve Matthias	7:40 AM	8/31/2016
C104-A-4	8/31/2016	Steve Matthias	7:45 AM	8/31/2016
G146A-A	8/31/2016	Steve Matthias	7:50 AM	8/31/2016
H024-A-1	8/31/2016	Steve Matthias	7:56 AM	8/31/2016

*Westlins
 W083129
 Page 1 of 1*

Stephen Matthias *8-31-16*
 Collector's Signature Date

MW Led *8/31/16 1336*
 Laboratory Signature Date

23°C