



WEST LINN - WILSONVILLE SCHOOL DISTRICT

Water Quality Information

September 9, 2016

Dear West Linn High School Families,

This letter is being sent to update you about the water quality testing results that were shared on August 30. The initial results from testing at West Linn High School showed that out of 185 test locations, five indicated elevated levels of lead that exceeded the action level of 20 parts per billion and one indicated elevated levels of copper that exceeded the action level of 1,350 parts per billion. The elevated levels of lead were found in two classroom sink faucets, a laundry room sink faucet, a lab sink faucet, and a bubbler in a classroom porch area. The elevated levels of copper were in a drinking fountain.

Immediate remediation steps were taken include turning water off at these locations, replacing subject fixtures, and retesting. After remediation, water was retested. The fixtures tested below the action levels for lead and copper. These results have cleared all fixtures at West Linn High School for elevated levels of lead or copper.

More information about District water quality testing is available at <http://www.wlwg.k12.or.us/Page/10603> .

West Linn-Wilsonville School District
Department of Operations
Tim K. Woodley, Director