WLWSD QUARTERLY SAFETY INSPECTIONS

ISSUE LOG

DATE: March 8 2016 FACILITY: Willamette Page:

Number	Location	Issue Code	Notes	W.O.
	Rm. 214	C-4	Items hanging from light	
	Rm. 218		Ceiling tile missing	
	Rm. 235		Surge protector under rug	
	Rm. 237		Surge protector under rug	
	Rm. 238		Extension cord plugged to surge protector	
	Rm. 239		Power cords under rug	
	Rm. 240		Items stored on high shelving	
	Rm.124		Cord under rug	
	Rm. 122		Cord under rug Art hanging from lights	
	Rm. 121		Cord under rug Cloth covering lights	
	B01A		Items stored in front of electrical panels	
	B03		Items hanging from lights	
			Main entry egress compromised	
	B06		Light burned out mechanical room	
	B04		Cord under rug	