WLWSD QUARTERLY SAFETY INSPECTIONS

ISSUE LOG

DATE: 10/12/2016 FACILITY: Wood Page:

Number	Location	Issue Code	Notes	W.O.
	183		GFI needed	
	184		GFI needed	
	185		GFI needed	
	153		GFI needed	
	154		GFI needed	
	155		GFI needed	
	112		Keep area clear in front of light	