WLWSD QUARTERLY SAFETY INSPECTIONS

ISSUE LOG

DATE: March 24 2016 FACILITY: Wood Page:

Number	Location	Issue Code	Notes	W.O.
	185		GFI needed next to sink	
	184		GFI needed next to sink - cord under rug	
	183		GFI needed next to sink	
	155		GFI needed next to sink	
	154		GFI needed next to sink	
	153		GFI needed next to sink	
	112		Clear path in storage area for electrical access	