

# PIXIS Labs

Accurate. Reliable. On Time.

## Pixis Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

**Job Number:** 6070719  
**Report Date:** 07/20/2016  
**ORELAP #:** OR100028  
**Project No:** 011-Inza Wood Middle School

### Cover Letter

Pat McGough  
West Linn School District  
2755 SW Borland  
West Linn, OR 97068

Dear Pat McGough,

Enclosed please find Pixis Labs analytical report for samples received as order number 6070719 on 07/07/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed

Richard Reid

Project Manager

### Sample Results

Sample: A100-A		Collected: 07/07/16 06:08		Temp: 24 C		Matrix: Drinking Water			
Lab ID: 113570		Received: 07/07/16 12:00		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0642	1.3	mg/L	0.0010	1	28836-136		07/14/16 17:30	
Lead	0.0020	0.02	mg/L	0.0002	1	28836-136		07/14/16 17:30	
Sample: A100-B		Collected: 07/07/16 06:09		Temp: 24 C		Matrix: Drinking Water			
Lab ID: 113571		Received: 07/07/16 12:00		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0841	1.3	mg/L	0.0010	1	28836-137		07/14/16 17:32	
Lead	0.0012	0.02	mg/L	0.0002	1	28836-137		07/14/16 17:32	
Sample: A101-A-1		Collected: 07/07/16 06:10		Temp: 24 C		Matrix: Drinking Water			
Lab ID: 113572		Received: 07/07/16 12:00		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0761	1.3	mg/L	0.0010	1	28836-138		07/14/16 17:34	
Lead	0.0019	0.02	mg/L	0.0002	1	28836-138		07/14/16 17:34	
Sample: A101-A-2		Collected: 07/07/16 06:11		Temp: 24 C		Matrix: Drinking Water			
Lab ID: 113573		Received: 07/07/16 12:00		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.176	1.3	mg/L	0.0010	1	28836-139		07/14/16 17:36	
Lead	0.0041	0.02	mg/L	0.0002	1	28836-139		07/14/16 17:36	
Sample: A103-A		Collected: 07/07/16 06:12		Temp: 24 C		Matrix: Drinking Water			
Lab ID: 113574		Received: 07/07/16 12:00		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0829	1.3	mg/L	0.0010	1	28836-140		07/14/16 17:38	
Lead	0.0030	0.02	mg/L	0.0002	1	28836-140		07/14/16 17:38	
Sample: A103-B		Collected: 07/07/16 06:13		Temp: 24 C		Matrix: Drinking Water			
Lab ID: 113575		Received: 07/07/16 12:00		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0955	1.3	mg/L	0.0010	1	28836-141		07/14/16 17:40	
Lead	0.0006	0.02	mg/L	0.0002	1	28836-141		07/14/16 17:40	
Sample: B105-A-1		Collected: 07/07/16 06:32		Temp: 24 C		Matrix: Drinking Water			
Lab ID: 113576		Received: 07/07/16 12:00		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.134	1.3	mg/L	0.0010	1	28836-142		07/14/16 17:42	

Lead 0.0082 0.02 mg/L 0.0002 1 28836-142 07/14/16 17:42

**Sample:** B105-A-2 Collected: 07/07/16 06:33 Temp: 24 C Matrix: Drinking Water  
Lab ID: 113577 Received: 07/07/16 12:00 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0677	1.3	mg/L	0.0010	1	28836-143		07/14/16 17:44	
--------	--------	-----	------	--------	---	-----------	--	----------------	--

Lead	0.0058	0.02	mg/L	0.0002	1	28836-143		07/14/16 17:44	
------	--------	------	------	--------	---	-----------	--	----------------	--

**Sample:** B105-A-3 Collected: 07/07/16 06:34 Temp: 24 C Matrix: Drinking Water  
Lab ID: 113578 Received: 07/07/16 12:00 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0521	1.3	mg/L	0.0010	1	28836-148		07/14/16 17:56	
--------	--------	-----	------	--------	---	-----------	--	----------------	--

Lead	0.0071	0.02	mg/L	0.0002	1	28836-148		07/14/16 17:56	
------	--------	------	------	--------	---	-----------	--	----------------	--

**Sample:** B105-A-4 Collected: 07/07/16 06:35 Temp: 24 C Matrix: Drinking Water  
Lab ID: 113579 Received: 07/07/16 12:00 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0624	1.3	mg/L	0.0010	1	28836-149		07/14/16 17:58	
--------	--------	-----	------	--------	---	-----------	--	----------------	--

Lead	0.0118	0.02	mg/L	0.0002	1	28836-149		07/14/16 17:58	
------	--------	------	------	--------	---	-----------	--	----------------	--

**Sample:** B105A-A-1 Collected: 07/07/16 06:36 Temp: 24 C Matrix: Drinking Water  
Lab ID: 113580 Received: 07/07/16 12:00 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0615	1.3	mg/L	0.0010	1	28836-150		07/14/16 18:00	
--------	--------	-----	------	--------	---	-----------	--	----------------	--

Lead	0.0055	0.02	mg/L	0.0002	1	28836-150		07/14/16 18:00	
------	--------	------	------	--------	---	-----------	--	----------------	--

**Sample:** B105A-A-2 Collected: 07/07/16 06:37 Temp: 24 C Matrix: Drinking Water  
Lab ID: 113581 Received: 07/07/16 12:00 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0541	1.3	mg/L	0.0010	1	28836-151		07/14/16 18:02	
--------	--------	-----	------	--------	---	-----------	--	----------------	--

Lead	0.0035	0.02	mg/L	0.0002	1	28836-151		07/14/16 18:02	
------	--------	------	------	--------	---	-----------	--	----------------	--

**Sample:** Gym Entry C Collected: 07/07/16 06:16 Temp: 24 C Matrix: Drinking Water  
Lab ID: 113582 Received: 07/07/16 12:00 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0634	1.3	mg/L	0.0010	1	28836-152		07/14/16 18:04	
--------	--------	-----	------	--------	---	-----------	--	----------------	--

Lead	ND	0.02	mg/L	0.0002	1	28836-152		07/14/16 18:04	
------	----	------	------	--------	---	-----------	--	----------------	--

**Sample:** Gym Entry D Collected: 07/07/16 06:17 Temp: 24 C Matrix: Drinking Water  
Lab ID: 113583 Received: 07/07/16 12:00 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0663	1.3	mg/L	0.0010	1	28836-153		07/14/16 18:06	
--------	--------	-----	------	--------	---	-----------	--	----------------	--

Lead	ND	0.02	mg/L	0.0002	1	28836-153		07/14/16 18:06	
------	----	------	------	--------	---	-----------	--	----------------	--

**Sample:** B108-A Collected: 07/07/16 06:18 Temp: 24 C Matrix: Drinking Water  
Lab ID: 113584 Received: 07/07/16 12:00 Evidence of Cooling:N

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0246	1.3	mg/L	0.0010	1	28836-154		07/14/16 18:08	
Lead	ND	0.02	mg/L	0.0002	1	28836-154		07/14/16 18:08	

<b>Sample:</b> B109-A-1	Collected: 07/07/16 06:22	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113585	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.106	1.3	mg/L	0.0010	1	28836-155		07/14/16 18:10	
Lead	0.0032	0.02	mg/L	0.0002	1	28836-155		07/14/16 18:10	

<b>Sample:</b> B109-A-2	Collected: 07/07/16 06:23	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113586	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0829	1.3	mg/L	0.0010	1	28836-156		07/14/16 18:12	
Lead	0.0029	0.02	mg/L	0.0002	1	28836-156		07/14/16 18:12	

<b>Sample:</b> B114-A-1	Collected: 07/07/16 06:25	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113587	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.158	1.3	mg/L	0.0010	1	28836-157		07/14/16 18:14	
Lead	0.0034	0.02	mg/L	0.0002	1	28836-157		07/14/16 18:14	

<b>Sample:</b> B114-A-2	Collected: 07/07/16 06:26	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113588	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.147	1.3	mg/L	0.0010	1	28836-162		07/14/16 18:25	
Lead	0.0032	0.02	mg/L	0.0002	1	28836-162		07/14/16 18:25	

<b>Sample:</b> B115-A	Collected: 07/07/16 06:28	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113589	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0943	1.3	mg/L	0.0010	1	28836-163		07/14/16 18:27	
Lead	0.0033	0.02	mg/L	0.0002	1	28836-163		07/14/16 18:27	

<b>Sample:</b> C100-A	Collected: 07/07/16 06:41	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113590	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0306	1.3	mg/L	0.0010	1	28836-164		07/14/16 18:29	
Lead	0.0023	0.02	mg/L	0.0002	1	28836-164		07/14/16 18:29	

<b>Sample:</b> C100-B	Collected: 07/07/16 06:42	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113591	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0394	1.3	mg/L	0.0010	1	28836-165		07/14/16 18:31	
Lead	0.0005	0.02	mg/L	0.0002	1	28836-165		07/14/16 18:31	

<b>Sample:</b> C101-A	Collected: 07/07/16 06:43	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113592	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									

Copper	0.0850	1.3	mg/L	0.0010	1	28836-166	07/14/16 18:33
Lead	0.0203	0.02	mg/L	0.0002	1	28836-166	07/14/16 18:33

<b>Sample:</b> C101-B	Collected: 07/07/16 06:44	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113593	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0392	1.3	mg/L	0.0010	1	28836-167	07/14/16 18:35
Lead	0.0002	0.02	mg/L	0.0002	1	28836-167	07/14/16 18:35

<b>Sample:</b> C102-A	Collected: 07/07/16 06:47	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113594	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0182	1.3	mg/L	0.0010	1	28836-168	07/14/16 18:37
Lead	0.0022	0.02	mg/L	0.0002	1	28836-168	07/14/16 18:37

<b>Sample:</b> C102-B	Collected: 07/07/16 06:48	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113595	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0400	1.3	mg/L	0.0010	1	28836-169	07/14/16 18:39
Lead	0.0003	0.02	mg/L	0.0002	1	28836-169	07/14/16 18:39

<b>Sample:</b> C103-A	Collected: 07/07/16 06:49	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113596	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0368	1.3	mg/L	0.0010	1	28836-170	07/14/16 18:41
Lead	0.0069	0.02	mg/L	0.0002	1	28836-170	07/14/16 18:41

<b>Sample:</b> C103-B	Collected: 07/07/16 06:50	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113597	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0405	1.3	mg/L	0.0010	1	28836-171	07/14/16 18:43
Lead	0.0008	0.02	mg/L	0.0002	1	28836-171	07/14/16 18:43

<b>Sample:</b> C104-A-1	Collected: 07/07/16 06:51	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113598	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.168	1.3	mg/L	0.0010	1	28836-176	07/14/16 18:53
Lead	0.0174	0.02	mg/L	0.0002	1	28836-176	07/14/16 18:53

<b>Sample:</b> C104-A-2	Collected: 07/07/16 06:52	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113599	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.203	1.3	mg/L	0.0010	1	28836-177	07/14/16 18:55
Lead	0.0104	0.02	mg/L	0.0002	1	28836-177	07/14/16 18:55

<b>Sample:</b> C104-A-3	Collected: 07/07/16 06:53	Temp: 24 C	Matrix: Drinking Water
Lab ID: 113600	Received: 07/07/16 12:00	Evidence of Cooling:N	

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
---------	--------	-------	-------	-----	------	-------	---------------	----------	-------

Method: EPA 200.8

Copper	0.0677	1.3	mg/L	0.0010	1	28836-178		07/14/16 18:57	
Lead	0.0019	0.02	mg/L	0.0002	1	28836-178		07/14/16 18:57	
<b>Sample:</b> C104-A-4		Collected: 07/07/16 06:54		Temp: 24 C		Matrix: Drinking Water			
Lab ID: 113601		Received: 07/07/16 12:00		Evidence of Cooling:N					
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0733	1.3	mg/L	0.0010	1	28836-179		07/14/16 18:59	
Lead	0.0015	0.02	mg/L	0.0002	1	28836-179		07/14/16 18:59	
<b>Sample:</b> C104-A-5		Collected: 07/07/16 06:55		Temp: 24 C		Matrix: Drinking Water			
Lab ID: 113602		Received: 07/07/16 12:00		Evidence of Cooling:N					
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0604	1.3	mg/L	0.0010	1	28836-180		07/14/16 19:01	
Lead	0.0020	0.02	mg/L	0.0002	1	28836-180		07/14/16 19:01	
<b>Sample:</b> C104-A-6		Collected: 07/07/16 06:56		Temp: 24 C		Matrix: Drinking Water			
Lab ID: 113603		Received: 07/07/16 12:00		Evidence of Cooling:N					
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.322	1.3	mg/L	0.0010	1	28836-181		07/14/16 19:03	
Lead	0.0113	0.02	mg/L	0.0002	1	28836-181		07/14/16 19:03	
<b>Sample:</b> C107-A-1		Collected: 07/07/16 07:03		Temp: 24 C		Matrix: Drinking Water			
Lab ID: 113604		Received: 07/07/16 12:00		Evidence of Cooling:N					
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0552	1.3	mg/L	0.0010	1	28836-182		07/14/16 19:05	
Lead	0.0006	0.02	mg/L	0.0002	1	28836-182		07/14/16 19:05	
<b>Sample:</b> C107-A-2		Collected: 07/07/16 07:04		Temp: 24 C		Matrix: Drinking Water			
Lab ID: 113605		Received: 07/07/16 12:00		Evidence of Cooling:N					
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0541	1.3	mg/L	0.0010	1	28836-183		07/14/16 19:07	
Lead	0.0007	0.02	mg/L	0.0002	1	28836-183		07/14/16 19:07	
<b>Sample:</b> C108-A-1		Collected: 07/07/16 07:01		Temp: 24 C		Matrix: Drinking Water			
Lab ID: 113606		Received: 07/07/16 12:00		Evidence of Cooling:N					
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0537	1.3	mg/L	0.0010	1	28836-184		07/14/16 19:09	
Lead	0.0003	0.02	mg/L	0.0002	1	28836-184		07/14/16 19:09	
<b>Sample:</b> C108-A-2		Collected: 07/07/16 07:02		Temp: 24 C		Matrix: Drinking Water			
Lab ID: 113607		Received: 07/07/16 12:00		Evidence of Cooling:N					
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0600	1.3	mg/L	0.0010	1	28836-185		07/14/16 19:11	
Lead	0.0004	0.02	mg/L	0.0002	1	28836-185		07/14/16 19:11	
<b>Sample:</b> C109-A		Collected: 07/07/16 06:58		Temp: 24 C		Matrix: Drinking Water			
Lab ID: 113608		Received: 07/07/16 12:00		Evidence of Cooling:N					
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>

Method: EPA 200.8									
Copper	0.0383	1.3	mg/L	0.0010	1	28836-190			07/14/16 19:21
Lead	0.0092	0.02	mg/L	0.0002	1	28836-190			07/14/16 19:21
<b>Sample: C109-B</b>		Collected: 07/07/16 06:59				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113609		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0299	1.3	mg/L	0.0010	1	28836-191			07/14/16 19:23
Lead	0.0006	0.02	mg/L	0.0002	1	28836-191			07/14/16 19:23
<b>Sample: D101-A</b>		Collected: 07/07/16 07:15				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113610		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0899	1.3	mg/L	0.0010	1	28836-192			07/14/16 19:25
Lead	0.0114	0.02	mg/L	0.0002	1	28836-192			07/14/16 19:25
<b>Sample: D102-A</b>		Collected: 07/07/16 07:16				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113611		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0561	1.3	mg/L	0.0010	1	28836-193			07/14/16 19:27
Lead	0.0078	0.02	mg/L	0.0002	1	28836-193			07/14/16 19:27
<b>Sample: D103-A</b>		Collected: 07/07/16 07:12				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113612		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0291	1.3	mg/L	0.0010	1	28836-194			07/14/16 19:29
Lead	ND	0.02	mg/L	0.0002	1	28836-194			07/14/16 19:29
<b>Sample: D104-A</b>		Collected: 07/07/16 07:13				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113613		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0250	1.3	mg/L	0.0010	1	28836-195			07/14/16 19:31
Lead	0.0006	0.02	mg/L	0.0002	1	28836-195			07/14/16 19:31
<b>Sample: D107-A</b>		Collected: 07/07/16 07:07				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113614		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0529	1.3	mg/L	0.0010	1	28836-196			07/14/16 19:33
Lead	0.0003	0.02	mg/L	0.0002	1	28836-196			07/14/16 19:33
<b>Sample: D108-A</b>		Collected: 07/07/16 07:09				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113615		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0454	1.3	mg/L	0.0010	1	28836-197			07/14/16 19:35
Lead	0.0085	0.02	mg/L	0.0002	1	28836-197			07/14/16 19:35
<b>Sample: D108-B</b>		Collected: 07/07/16 07:10				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113616		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>

Method: EPA 200.8									
Copper	0.0357	1.3	mg/L	0.0010	1	28836-221			07/14/16 20:25
Lead	0.0240	0.02	mg/L	0.0002	1	28836-221			07/14/16 20:25
<b>Sample:</b> D115-A-1		Collected: 07/07/16 07:27			Temp: 24 C		Matrix: Drinking Water		
Lab ID: 113617		Received: 07/07/16 12:00			Evidence of Cooling:N				
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.116	1.3	mg/L	0.0010	1	28836-222			07/14/16 20:27
Lead	0.0041	0.02	mg/L	0.0002	1	28836-222			07/14/16 20:27
<b>Sample:</b> D115-A-2		Collected: 07/07/16 07:28			Temp: 24 C		Matrix: Drinking Water		
Lab ID: 113618		Received: 07/07/16 12:00			Evidence of Cooling:N				
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0628	1.3	mg/L	0.0010	1	28836-223			07/14/16 20:30
Lead	0.0016	0.02	mg/L	0.0002	1	28836-223			07/14/16 20:30
<b>Sample:</b> D115-A-3		Collected: 07/07/16 07:29			Temp: 24 C		Matrix: Drinking Water		
Lab ID: 113619		Received: 07/07/16 12:00			Evidence of Cooling:N				
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0842	1.3	mg/L	0.0010	1	28836-224			07/14/16 20:31
Lead	0.0020	0.02	mg/L	0.0002	1	28836-224			07/14/16 20:31
<b>Sample:</b> D115-A-4		Collected: 07/07/16 07:30			Temp: 24 C		Matrix: Drinking Water		
Lab ID: 113620		Received: 07/07/16 12:00			Evidence of Cooling:N				
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.155	1.3	mg/L	0.0010	1	28836-225			07/14/16 20:34
Lead	0.0260	0.02	mg/L	0.0002	1	28836-225			07/14/16 20:34
<b>Sample:</b> D115-A-5		Collected: 07/07/16 07:31			Temp: 24 C		Matrix: Drinking Water		
Lab ID: 113621		Received: 07/07/16 12:00			Evidence of Cooling:N				
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.109	1.3	mg/L	0.0010	1	28836-226			07/14/16 20:36
Lead	0.0029	0.02	mg/L	0.0002	1	28836-226			07/14/16 20:36
<b>Sample:</b> D115-A-6		Collected: 07/07/16 07:32			Temp: 24 C		Matrix: Drinking Water		
Lab ID: 113622		Received: 07/07/16 12:00			Evidence of Cooling:N				
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.269	1.3	mg/L	0.0010	1	28836-227			07/14/16 20:38
Lead	0.0069	0.02	mg/L	0.0002	1	28836-227			07/14/16 20:38
<b>Sample:</b> D116-A		Collected: 07/07/16 07:33			Temp: 24 C		Matrix: Drinking Water		
Lab ID: 113623		Received: 07/07/16 12:00			Evidence of Cooling:N				
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0360	1.3	mg/L	0.0010	1	28836-232			07/14/16 20:48
Lead	0.0046	0.02	mg/L	0.0002	1	28836-232			07/14/16 20:48
<b>Sample:</b> D116-B		Collected: 07/07/16 07:34			Temp: 24 C		Matrix: Drinking Water		
Lab ID: 113624		Received: 07/07/16 12:00			Evidence of Cooling:N				



Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0409	1.3	mg/L	0.0010	1	28836-233		07/14/16 20:50	
Lead	0.0003	0.02	mg/L	0.0002	1	28836-233		07/14/16 20:50	
<b>Sample: D1118-A</b>		Collected: 07/07/16 07:35			Temp: 24 C		Matrix: Drinking Water		
Lab ID: 113625		Received: 07/07/16 12:00			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0525	1.3	mg/L	0.0010	1	28836-234		07/14/16 20:52	
Lead	0.0053	0.02	mg/L	0.0002	1	28836-234		07/14/16 20:52	
<b>Sample: D118-B</b>		Collected: 07/07/16 07:36			Temp: 24 C		Matrix: Drinking Water		
Lab ID: 113626		Received: 07/07/16 12:00			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0411	1.3	mg/L	0.0010	1	28836-235		07/14/16 20:54	
Lead	0.0006	0.02	mg/L	0.0002	1	28836-235		07/14/16 20:54	
<b>Sample: D119-A</b>		Collected: 07/07/16 07:40			Temp: 24 C		Matrix: Drinking Water		
Lab ID: 113627		Received: 07/07/16 12:00			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0278	1.3	mg/L	0.0010	1	28836-236		07/14/16 20:56	
Lead	0.0050	0.02	mg/L	0.0002	1	28836-236		07/14/16 20:56	
<b>Sample: D119-B</b>		Collected: 07/07/16 07:41			Temp: 24 C		Matrix: Drinking Water		
Lab ID: 113628		Received: 07/07/16 12:00			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0438	1.3	mg/L	0.0010	1	28836-237		07/14/16 20:58	
Lead	0.0006	0.02	mg/L	0.0002	1	28836-237		07/14/16 20:58	
<b>Sample: D120-A</b>		Collected: 07/07/16 07:43			Temp: 24 C		Matrix: Drinking Water		
Lab ID: 113629		Received: 07/07/16 12:00			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0723	1.3	mg/L	0.0010	1	28836-238		07/14/16 21:00	
Lead	0.0136	0.02	mg/L	0.0002	1	28836-238		07/14/16 21:00	
<b>Sample: D120-B</b>		Collected: 07/07/16 07:44			Temp: 24 C		Matrix: Drinking Water		
Lab ID: 113630		Received: 07/07/16 12:00			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0503	1.3	mg/L	0.0010	1	28836-239		07/14/16 21:02	
Lead	0.0059	0.02	mg/L	0.0002	1	28836-239		07/14/16 21:02	
<b>Sample: D121-A</b>		Collected: 07/07/16 07:47			Temp: 24 C		Matrix: Drinking Water		
Lab ID: 113631		Received: 07/07/16 12:00			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0531	1.3	mg/L	0.0010	1	28836-240		07/14/16 21:04	
Lead	0.0041	0.02	mg/L	0.0002	1	28836-240		07/14/16 21:04	
<b>Sample: D121-B</b>		Collected: 07/07/16 07:48			Temp: 24 C		Matrix: Drinking Water		

Lab ID: 113632		Received: 07/07/16 12:00				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0418	1.3	mg/L	0.0010	1	28836-241		07/14/16 21:06	
Lead	0.0003	0.02	mg/L	0.0002	1	28836-241		07/14/16 21:06	
<b>Sample: D122-A-1</b>		Collected: 07/07/16 07:26				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113633		Received: 07/07/16 12:00				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0450	1.3	mg/L	0.0010	1	28836-246		07/14/16 21:16	
Lead	0.0008	0.02	mg/L	0.0002	1	28836-246		07/14/16 21:16	
<b>Sample: D122-A-2</b>		Collected: 07/07/16 07:21				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113634		Received: 07/07/16 12:00				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0618	1.3	mg/L	0.0010	1	28836-247		07/14/16 21:18	
Lead	0.0008	0.02	mg/L	0.0002	1	28836-247		07/14/16 21:18	
<b>Sample: D123-A-1</b>		Collected: 07/07/16 07:22				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113635		Received: 07/07/16 12:00				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0634	1.3	mg/L	0.0010	1	28836-248		07/14/16 21:20	
Lead	0.0006	0.02	mg/L	0.0002	1	28836-248		07/14/16 21:20	
<b>Sample: D123-A-2</b>		Collected: 07/07/16 07:23				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113636		Received: 07/07/16 12:00				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.0543	1.3	mg/L	0.0010	1	28836-249		07/14/16 21:22	
Lead	0.0008	0.02	mg/L	0.0002	1	28836-249		07/14/16 21:22	
<b>Sample: E100-A</b>		Collected: 07/07/16 07:56				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113637		Received: 07/07/16 12:00				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.152	1.3	mg/L	0.0010	1	28836-250		07/14/16 21:24	
Lead	0.0058	0.02	mg/L	0.0002	1	28836-250		07/14/16 21:24	
<b>Sample: E100-B</b>		Collected: 07/07/16 07:57				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113638		Received: 07/07/16 12:00				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	0.136	1.3	mg/L	0.0010	1	28836-251		07/14/16 21:26	
Lead	0.0065	0.02	mg/L	0.0002	1	28836-251		07/14/16 21:26	
<b>Sample: E102-A</b>		Collected: 07/07/16 08:00				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113639		Received: 07/07/16 12:00				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Copper	3.28	1.3	mg/L	0.0200	20	28863-15		07/19/16 20:16	
Lead	0.0715	0.02	mg/L	0.0002	1	28836-252		07/14/16 21:29	

<b>Sample:</b> E102-B Lab ID: 113640		Collected: 07/07/16 08:01 Received: 07/07/16 12:00				Temp: 24 C Evidence of Cooling:N		Matrix: Drinking Water	
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0786	1.3	mg/L	0.0010	1	28836-253		07/14/16 21:31	
Lead	0.0039	0.02	mg/L	0.0002	1	28836-253		07/14/16 21:31	
<b>Sample:</b> E105-C Lab ID: 113641		Collected: 07/07/16 08:05 Received: 07/07/16 12:00				Temp: 24 C Evidence of Cooling:N		Matrix: Drinking Water	
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0512	1.3	mg/L	0.0010	1	28836-254		07/14/16 21:33	
Lead	0.0016	0.02	mg/L	0.0002	1	28836-254		07/14/16 21:33	
<b>Sample:</b> E107-A-1 Lab ID: 113642		Collected: 07/07/16 08:07 Received: 07/07/16 12:00				Temp: 24 C Evidence of Cooling:N		Matrix: Drinking Water	
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.210	1.3	mg/L	0.0010	1	28836-255		07/14/16 21:35	
Lead	0.0495	0.02	mg/L	0.0002	1	28836-255		07/14/16 21:35	
<b>Sample:</b> E107-A-2 Lab ID: 113643		Collected: 07/07/16 08:08 Received: 07/07/16 12:00				Temp: 24 C Evidence of Cooling:N		Matrix: Drinking Water	
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.334	1.3	mg/L	0.0010	1	28845-8		07/15/16 12:15	
Lead	0.0125	0.02	mg/L	0.0002	1	28845-8		07/15/16 12:15	
<b>Sample:</b> E107-A-3 Lab ID: 113644		Collected: 07/07/16 08:09 Received: 07/07/16 12:00				Temp: 24 C Evidence of Cooling:N		Matrix: Drinking Water	
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.196	1.3	mg/L	0.0010	1	28845-9		07/15/16 12:16	
Lead	0.0166	0.02	mg/L	0.0002	1	28845-9		07/15/16 12:16	
<b>Sample:</b> E107-A-4 Lab ID: 113645		Collected: 07/07/16 08:10 Received: 07/07/16 12:00				Temp: 24 C Evidence of Cooling:N		Matrix: Drinking Water	
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.139	1.3	mg/L	0.0010	1	28845-10		07/15/16 12:18	
Lead	0.0086	0.02	mg/L	0.0002	1	28845-10		07/15/16 12:18	
<b>Sample:</b> E107-A-5 Lab ID: 113646		Collected: 07/07/16 08:13 Received: 07/07/16 12:00				Temp: 24 C Evidence of Cooling:N		Matrix: Drinking Water	
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.176	1.3	mg/L	0.0010	1	28845-11		07/15/16 12:20	
Lead	0.0215	0.02	mg/L	0.0002	1	28845-11		07/15/16 12:20	
<b>Sample:</b> E107-A-6 Lab ID: 113647		Collected: 07/07/16 08:15 Received: 07/07/16 12:00				Temp: 24 C Evidence of Cooling:N		Matrix: Drinking Water	
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.298	1.3	mg/L	0.0080	20	28863-14	07/16/16 11:55	07/19/16 20:12	
Lead	0.0502	0.02	mg/L	0.0008	10	28851-10	07/16/16 11:55	07/18/16 14:17	

<b>Sample:</b> E107-A-7		Collected: 07/07/16 08:16				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113648		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.158	1.3	mg/L	0.0010	1	28845-12		07/15/16 12:22	
Lead	0.0125	0.02	mg/L	0.0002	1	28845-12		07/15/16 12:22	
<b>Sample:</b> E107-A-8		Collected: 07/07/16 08:17				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113649		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.157	1.3	mg/L	0.0010	1	28845-13		07/15/16 12:24	
Lead	0.0160	0.02	mg/L	0.0002	1	28845-13		07/15/16 12:24	
<b>Sample:</b> E111-A		Collected: 07/07/16 08:26				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113650		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0810	1.3	mg/L	0.0010	1	28845-14		07/15/16 12:26	
Lead	0.0006	0.02	mg/L	0.0002	1	28845-14		07/15/16 12:26	
<b>Sample:</b> E114-A		Collected: 07/07/16 08:33				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113651		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.107	1.3	mg/L	0.0010	1	28845-15		07/15/16 12:28	
Lead	0.0091	0.02	mg/L	0.0002	1	28845-15		07/15/16 12:28	
<b>Sample:</b> E114-B		Collected: 07/07/16 08:34				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113652		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0735	1.3	mg/L	0.0010	1	28845-16		07/15/16 12:30	
Lead	0.0048	0.02	mg/L	0.0002	1	28845-16		07/15/16 12:30	
<b>Sample:</b> E115-A		Collected: 07/07/16 08:36				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113653		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0657	1.3	mg/L	0.0010	1	28845-17		07/15/16 12:32	
Lead	0.0016	0.02	mg/L	0.0002	1	28845-17		07/15/16 12:32	
<b>Sample:</b> E115-B		Collected: 07/07/16 08:37				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113654		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0771	1.3	mg/L	0.0010	1	28845-22		07/15/16 12:43	
Lead	0.0013	0.02	mg/L	0.0002	1	28845-22		07/15/16 12:43	
<b>Sample:</b> E116-A		Collected: 07/07/16 08:41				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113655		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0854	1.3	mg/L	0.0010	1	28845-23		07/15/16 12:45	
Lead	0.0074	0.02	mg/L	0.0002	1	28845-23		07/15/16 12:45	

<b>Sample:</b> E116-B		Collected: 07/07/16 08:42				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113656		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0681	1.3	mg/L	0.0010	1	28845-24		07/15/16 12:47	
Lead	0.0024	0.02	mg/L	0.0002	1	28845-24		07/15/16 12:47	
<b>Sample:</b> F101-A		Collected: 07/07/16 08:22				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113657		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0762	1.3	mg/L	0.0010	1	28845-25		07/15/16 12:49	
Lead	0.0237	0.02	mg/L	0.0002	1	28845-25		07/15/16 12:49	
<b>Sample:</b> F103-A		Collected: 07/07/16 08:46				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113658		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0651	1.3	mg/L	0.0010	1	28845-26		07/15/16 12:50	
Lead	0.0066	0.02	mg/L	0.0002	1	28845-26		07/15/16 12:50	
<b>Sample:</b> F103-B		Collected: 07/07/16 08:47				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113659		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0737	1.3	mg/L	0.0010	1	28845-27		07/15/16 12:52	
Lead	0.0050	0.02	mg/L	0.0002	1	28845-27		07/15/16 12:52	
<b>Sample:</b> F104-A		Collected: 07/07/16 08:48				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113660		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0906	1.3	mg/L	0.0010	1	28845-28		07/15/16 12:54	
Lead	0.0024	0.02	mg/L	0.0002	1	28845-28		07/15/16 12:54	
<b>Sample:</b> F105-A-1		Collected: 07/07/16 08:50				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113661		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.228	1.3	mg/L	0.0010	1	28845-29		07/15/16 12:56	
Lead	0.0178	0.02	mg/L	0.0002	1	28845-29		07/15/16 12:56	
<b>Sample:</b> F105-A-2		Collected: 07/07/16 08:51				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113662		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.224	1.3	mg/L	0.0010	1	28836-108		07/14/16 16:35	
Lead	0.0319	0.02	mg/L	0.0002	1	28836-108		07/14/16 16:35	
<b>Sample:</b> F105-A-3		Collected: 07/07/16 08:52				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113663		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.157	1.3	mg/L	0.0010	1	28836-109		07/14/16 16:37	
Lead	0.0333	0.02	mg/L	0.0002	1	28836-109		07/14/16 16:37	

<b>Sample:</b> F105-A-4		Collected: 07/07/16 08:53				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113664		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.410	1.3	mg/L	0.0010	1	28836-110		07/14/16 16:39	
Lead	0.0232	0.02	mg/L	0.0002	1	28836-110		07/14/16 16:39	
<b>Sample:</b> F105-A-5		Collected: 07/07/16 08:54				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113665		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.139	1.3	mg/L	0.0010	1	28836-111		07/14/16 16:40	
Lead	0.0172	0.02	mg/L	0.0002	1	28836-111		07/14/16 16:40	
<b>Sample:</b> F105-A-6		Collected: 07/07/16 08:55				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113666		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.204	1.3	mg/L	0.0010	1	28836-112		07/14/16 16:42	
Lead	0.0242	0.02	mg/L	0.0002	1	28836-112		07/14/16 16:42	
<b>Sample:</b> F105-A-7		Collected: 07/07/16 08:57				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113667		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.229	1.3	mg/L	0.0010	1	28836-113		07/14/16 16:44	
Lead	0.0204	0.02	mg/L	0.0002	1	28836-113		07/14/16 16:44	
<b>Sample:</b> F106-C-1		Collected: 07/07/16 09:00				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113668		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.178	1.3	mg/L	0.0010	1	28836-114		07/14/16 16:46	
Lead	0.0067	0.02	mg/L	0.0002	1	28836-114		07/14/16 16:46	
<b>Sample:</b> F106-C-2		Collected: 07/07/16 09:01				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113669		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0979	1.3	mg/L	0.0010	1	28836-115		07/14/16 16:48	
Lead	0.0018	0.02	mg/L	0.0002	1	28836-115		07/14/16 16:48	
<b>Sample:</b> F109-A		Collected: 07/07/16 09:02				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113670		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0513	1.3	mg/L	0.0010	1	28836-120		07/14/16 16:58	
Lead	0.0077	0.02	mg/L	0.0002	1	28836-120		07/14/16 16:58	
<b>Sample:</b> F109-B		Collected: 07/07/16 09:03				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113671		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0984	1.3	mg/L	0.0010	1	28836-121		07/14/16 17:00	
Lead	0.0089	0.02	mg/L	0.0002	1	28836-121		07/14/16 17:00	

<b>Sample:</b> F112-A		Collected: 07/07/16 09:04				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113672		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0800	1.3	mg/L	0.0010	1	28836-122		07/14/16 17:02	
Lead	0.0077	0.02	mg/L	0.0002	1	28836-122		07/14/16 17:02	
<b>Sample:</b> F112-B		Collected: 07/07/16 09:05				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113673		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.262	1.3	mg/L	0.0010	1	28836-123		07/14/16 17:04	
Lead	0.0154	0.02	mg/L	0.0002	1	28836-123		07/14/16 17:04	
<b>Sample:</b> F113-A		Collected: 07/07/16 09:06				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113674		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0707	1.3	mg/L	0.0010	1	28836-124		07/14/16 17:06	
Lead	0.0051	0.02	mg/L	0.0002	1	28836-124		07/14/16 17:06	
<b>Sample:</b> F113-B		Collected: 07/07/16 09:07				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113675		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.0974	1.3	mg/L	0.0010	1	28836-125		07/14/16 17:08	
Lead	0.0022	0.02	mg/L	0.0002	1	28836-125		07/14/16 17:08	
<b>Sample:</b> F115-A		Collected: 07/07/16 09:08				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113676		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.115	1.3	mg/L	0.0010	1	28836-126		07/14/16 17:10	
Lead	0.0070	0.02	mg/L	0.0002	1	28836-126		07/14/16 17:10	
<b>Sample:</b> F115-B		Collected: 07/07/16 09:09				Temp: 24 C		Matrix: Drinking Water	
Lab ID: 113677		Received: 07/07/16 12:00				Evidence of Cooling:N			
<b>Analyte</b>	<b>Result</b>	<b>Limit</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Batch</b>	<b>Start/Extract</b>	<b>Analyzed</b>	<b>Notes</b>
Method: EPA 200.8									
Copper	0.145	1.3	mg/L	0.0010	1	28836-127		07/14/16 17:12	
Lead	0.0032	0.02	mg/L	0.0002	1	28836-127		07/14/16 17:12	

#### Abbreviations

MRL Method Reporting Limit

ND None Detected at or above the MRL

Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

#### Units of Measure:

mg/L Milligrams Per Liter

**Chain of Custody Record-Water Samples**  
**011-Inza Wood Middle School: 11055 SW Wilsonville Rd., Wilsonville, OR 97070**

Location/Site	Date Collected	Collector's Name	Time	Date Delivered
A100-A	7/7/2016	Steve Matthias	6:08 AM	7/7/2016
A100-B	7/7/2016	Steve Matthias	6:09 AM	7/7/2016
A101-A-1	7/7/2016	Steve Matthias	6:10 AM	7/7/2016
A101-A-2	7/7/2016	Steve Matthias	6:11 AM	7/7/2016
A103-A	7/7/2016	Steve Matthias	6:12 AM	7/7/2016
A103-B	7/7/2016	Steve Matthias	6:13 AM	7/7/2016
B105-A-1	7/7/2016	Steve Matthias	6:32 AM	7/7/2016
B105-A-2	7/7/2016	Steve Matthias	6:33 AM	7/7/2016
B105-A-3	7/7/2016	Steve Matthias	6:34 AM	7/7/2016
B105-A-4	7/7/2016	Steve Matthias	6:35 AM	7/7/2016
B105A-A-1	7/7/2016	Steve Matthias	6:36 AM	7/7/2016
B105A-A-2	7/7/2016	Steve Matthias	6:37 AM	7/7/2016
Gym Entry C	7/7/2016	Steve Matthias	6:16 AM	7/7/2016
Gym Entry D	7/7/2016	Steve Matthias	6:17 AM	7/7/2016
B108-A	7/7/2016	Steve Matthias	6:18 AM	7/7/2016
B109-A-1	7/7/2016	Steve Matthias	6:22 AM	7/7/2016
B109-A-2	7/7/2016	Steve Matthias	6:23 AM	7/7/2016
B114-A-1	7/7/2016	Steve Matthias	6:25 AM	7/7/2016
B114-A-2	7/7/2016	Steve Matthias	6:26 AM	7/7/2016
B115-A	7/7/2016	Steve Matthias	6:28 AM	7/7/2016
C100-A	7/7/2016	Steve Matthias	6:41 AM	7/7/2016
C100-B	7/7/2016	Steve Matthias	6:42 AM	7/7/2016
C101-A	7/7/2016	Steve Matthias	6:43 AM	7/7/2016
C101-B	7/7/2016	Steve Matthias	6:44 AM	7/7/2016
C102-A	7/7/2016	Steve Matthias	6:47 AM	7/7/2016
C102-B	7/7/2016	Steve Matthias	6:48 AM	7/7/2016
C103-A	7/7/2016	Steve Matthias	6:49 AM	7/7/2016
C103-B	7/7/2016	Steve Matthias	6:50 AM	7/7/2016
C104-A-1	7/7/2016	Steve Matthias	6:51 AM	7/7/2016
C104-A-2	7/7/2016	Steve Matthias	6:52 AM	7/7/2016
C104-A-3	7/7/2016	Steve Matthias	6:53 AM	7/7/2016
C104-A-4	7/7/2016	Steve Matthias	6:54 AM	7/7/2016
C104-A-5	7/7/2016	Steve Matthias	6:55 AM	7/7/2016
C104-A-6	7/7/2016	Steve Matthias	6:56 AM	7/7/2016
C107-A-1	7/7/2016	Steve Matthias	7:03 AM	7/7/2016

Westlinn School District



WESTLINN SC 6070719

Westlinn Sc  
6070719  
Page 1 of 1

24.2°C  
no cooling

*Steve Matthias* 7/7/16  
 Collector's Signature Date

*MRH* 7.7.16 1200  
 Laboratory Signature Date



**Chain of Custody Record-Water Samples**  
**011-Inza Wood Middle School: 11055 SW Wilsonville Rd., Wilsonville, OR 97070**

C107-A-2	7/7/2016	Steve Matthias	7:04 AM	7/7/2016
C108-A-1	7/7/2016	Steve Matthias	7:01 AM	7/7/2016
C108-A-2	7/7/2016	Steve Matthias	7:02 AM	7/7/2016
C109-A	7/7/2016	Steve Matthias	6:58 AM	7/7/2016
C109-B	7/7/2016	Steve Matthias	6:59 AM	7/7/2016
D101-A	7/7/2016	Steve Matthias	7:15 AM	7/7/2016
D102-A	7/7/2016	Steve Matthias	7:16 AM	7/7/2016
D103-A	7/7/2016	Steve Matthias	7:12 AM	7/7/2016
D104-A	7/7/2016	Steve Matthias	7:13 AM	7/7/2016
D107-A	7/7/2016	Steve Matthias	7:07 AM	7/7/2016
D108-A	7/7/2016	Steve Matthias	7:09 AM	7/7/2016
D108-B	7/7/2016	Steve Matthias	7:10 AM	7/7/2016
D115-A-1	7/7/2016	Steve Matthias	7:27 AM	7/7/2016
D115-A-2	7/7/2016	Steve Matthias	7:28 AM	7/7/2016
D115-A-3	7/7/2016	Steve Matthias	7:29 AM	7/7/2016
D115-A-4	7/7/2016	Steve Matthias	7:30 AM	7/7/2016
D115-A-5	7/7/2016	Steve Matthias	7:31 AM	7/7/2016
D115-A-6	7/7/2016	Steve Matthias	7:32 AM	7/7/2016
D116-A	7/7/2016	Steve Matthias	7:33 AM	7/7/2016
D116-B	7/7/2016	Steve Matthias	7:34 AM	7/7/2016
D1118-A	7/7/2016	Steve Matthias	7:35 AM	7/7/2016
D118-B	7/7/2016	Steve Matthias	7:36 AM	7/7/2016
D119-A	7/7/2016	Steve Matthias	7:40 AM	7/7/2016
D119-B	7/7/2016	Steve Matthias	7:41 AM	7/7/2016
D120-A	7/7/2016	Steve Matthias	7:43 AM	7/7/2016
D120-B	7/7/2016	Steve Matthias	7:44 AM	7/7/2016
D121-A	7/7/2016	Steve Matthias	7:47 AM	7/7/2016
D121-B	7/7/2016	Steve Matthias	7:48 AM	7/7/2016
D122-A-1	7/7/2016	Steve Matthias	7:26 AM	7/7/2016
D122-A-2	7/7/2016	Steve Matthias	7:21 AM	7/7/2016
D123-A-1	7/7/2016	Steve Matthias	7:22 AM	7/7/2016
D123-A-2	7/7/2016	Steve Matthias	7:23 AM	7/7/2016
E100-A	7/7/2016	Steve Matthias	7:56 AM	7/7/2016
E100-B	7/7/2016	Steve Matthias	7:57 AM	7/7/2016
E102-A	7/7/2016	Steve Matthias	8:00 AM	7/7/2016
E102-B	7/7/2016	Steve Matthias	8:01 AM	7/7/2016

Page 2 of 3

*Steve Matthias* 7-7-16  
 Collector's Signature Date

*MRH* 7-7-16 1200  
 Laboratory Signature Date

**Chain of Custody Record-Water Samples**  
**011-Inza Wood Middle School: 11055 SW Wilsonville Rd., Wilsonville, OR 97070**

E105-C	7/7/2016	Steve Matthias	8:05 AM	7/7/2016
E107-A-1	7/7/2016	Steve Matthias	8:07 AM	7/7/2016
E107-A-2	7/7/2016	Steve Matthias	8:08 AM	7/7/2016
E107-A-3	7/7/2016	Steve Matthias	8:09 AM	7/7/2016
E107-A-4	7/7/2016	Steve Matthias	8:10 AM	7/7/2016
E107-A-5	7/7/2016	Steve Matthias	8:13 AM	7/7/2016
E107-A-6	7/7/2016	Steve Matthias	8:15 AM	7/7/2016
E107-A-7	7/7/2016	Steve Matthias	8:16 AM	7/7/2016
E107-A-8	7/7/2016	Steve Matthias	8:17 AM	7/7/2016
E111-A	7/7/2016	Steve Matthias	8:26 AM	7/7/2016
E114-A	7/7/2016	Steve Matthias	8:33 AM	7/7/2016
E114-B	7/7/2016	Steve Matthias	8:34 AM	7/7/2016
E115-A	7/7/2016	Steve Matthias	8:36 AM	7/7/2016
E115-B	7/7/2016	Steve Matthias	8:37 AM	7/7/2016
E116-A	7/7/2016	Steve Matthias	8:41 AM	7/7/2016
E116-B	7/7/2016	Steve Matthias	8:42 AM	7/7/2016
F101-A	7/7/2016	Steve Matthias	8:22 AM	7/7/2016
f103-A	7/7/2016	Steve Matthias	8:46 AM	7/7/2016
F103-B	7/7/2016	Steve Matthias	8:47 AM	7/7/2016
F104-A	7/7/2016	Steve Matthias	8:48 AM	7/7/2016
F105-A-1	7/7/2016	Steve Matthias	8:50 AM	7/7/2016
F105-A-2	7/7/2016	Steve Matthias	8:51 AM	7/7/2016
F105-A-3	7/7/2016	Steve Matthias	8:52 AM	7/7/2016
F105-A-4	7/7/2016	Steve Matthias	8:53 AM	7/7/2016
F105-A-5	7/7/2016	Steve Matthias	8:54 AM	7/7/2016
F105-A-6	7/7/2016	Steve Matthias	8:55 AM	7/7/2016
F105-A-7	7/7/2016	Steve Matthias	8:57 AM	7/7/2016
F105-A-8		(Leaking-test upon repair)		
F106-C-1	7/7/2016	Steve Matthias	9:00 AM	7/7/2016
F106-C-2	7/7/2016	Steve Matthias	9:01 AM	7/7/2016
F109-A	7/7/2016	Steve Matthias	9:02 AM	7/7/2016
F109-B	7/7/2016	Steve Matthias	9:03 AM	7/7/2016
F112-A	7/7/2016	Steve Matthias	9:04 AM	7/7/2016
F112-B	7/7/2016	Steve Matthias	9:05 AM	7/7/2016
F113-A	7/7/2016	Steve Matthias	9:06 AM	7/7/2016
F113-B	7/7/2016	Steve Matthias	9:07 AM	7/7/2016

Page 3 of 4

*Steve Matthias* 7-7-16  
 Collector's Signature Date

*MRH* 7.7.16 1200  
 Laboratory Signature Date

**Chain of Custody Record-Water Samples**  
**011-Inza Wood Middle School: 11055 SW Wilsonville Rd., Wilsonville, OR 97070**

F115-A	7/7/2016	Steve Matthias	9:08 AM	7/7/2016
F115-B	7/7/2016	Steve Matthias	9:09 AM	7/7/2016

Page 4 of 4

*Steve Matthias* 7-7-16  
 Collector's Signature Date

*MBH* 7-7-16 1200  
 Laboratory Signature Date