

PIXIS Labs

Accurate. Reliable. On Time.

Pixis Labs

12423 NE Whitaker Way

Portland, OR 97230

503-254-1794

Job
Number: 6080436
Report
Date: 08/15/2016
ORELAP #: OR100028
Project No: 011- Inza Wood Middle
School

Cover Letter

Pat McGough
West Linn School District
2755 SW Borland
West Linn, OR 97068

Dear Pat McGough,

Enclosed please find Pixis Labs analytical report for samples received as order number 6080436 on 08/04/2016. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed

Richard Reid

Project Manager

Sample Results

Sample: C101-A		Collected: 08/04/16 10:21		Temp: 26 C		Matrix: Drinking Water			
Lab ID: 117150		Received: 08/04/16 14:50		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0014	0.02	mg/L	0.0002	1	29140-10		08/10/16 19:56	
Sample: D108 - B		Collected: 08/04/16 10:23		Temp: 26 C		Matrix: Drinking Water			
Lab ID: 117151		Received: 08/04/16 14:50		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0045	0.02	mg/L	0.0002	1	29139-201		08/10/16 19:45	
Sample: D115 - A - 4		Collected: 08/04/16 10:30		Temp: 26 C		Matrix: Drinking Water			
Lab ID: 117152		Received: 08/04/16 14:50		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0093	0.02	mg/L	0.0002	1	29140-11		08/10/16 19:58	
Sample: E102 - A		Collected: 08/04/16 10:35		Temp: 26 C		Matrix: Drinking Water			
Lab ID: 117153		Received: 08/04/16 14:50		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0014	0.02	mg/L	0.0002	1	29140-12		08/10/16 20:00	
Sample: E107 - A - 1		Collected: 08/04/16 10:38		Temp: 26 C		Matrix: Drinking Water			
Lab ID: 117154		Received: 08/04/16 14:50		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0012	0.02	mg/L	0.0002	1	29140-13		08/10/16 20:03	
Sample: E107 - A - 5		Collected: 08/04/16 10:41		Temp: 26 C		Matrix: Drinking Water			
Lab ID: 117155		Received: 08/04/16 14:50		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	ND	0.02	mg/L	0.0002	1	29140-14		08/10/16 20:05	
Sample: E107 - A - 6		Collected: 08/04/16 10:45		Temp: 26 C		Matrix: Drinking Water			
Lab ID: 117156		Received: 08/04/16 14:50		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0045	0.02	mg/L	0.0002	1	29140-15		08/10/16 20:07	
Sample: F101 - A		Collected: 08/04/16 10:47		Temp: 26 C		Matrix: Drinking Water			
Lab ID: 117157		Received: 08/04/16 14:50		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									

Lead	0.0010	0.02	mg/L	0.0002	1	29140-16		08/10/16 20:10	
Sample: F105 - A - 2		Collected: 08/04/16 10:50			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 117158		Received: 08/04/16 14:50			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0022	0.02	mg/L	0.0002	1	29140-17		08/10/16 20:12	
Sample: F105 - A - 3		Collected: 08/04/16 10:51			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 117159		Received: 08/04/16 14:50			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0011	0.02	mg/L	0.0002	1	29140-18		08/10/16 20:14	
Sample: F105 - A - 4		Collected: 08/04/16 10:53			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 117160		Received: 08/04/16 14:50			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0025	0.02	mg/L	0.0002	1	29140-19		08/10/16 20:17	
Sample: F105 - A - 6		Collected: 08/04/16 10:56			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 117161		Received: 08/04/16 14:50			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0009	0.02	mg/L	0.0002	1	29140-24		08/10/16 20:28	
Sample: F105 - A - 7		Collected: 08/04/16 10:59			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 117162		Received: 08/04/16 14:50			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0011	0.02	mg/L	0.0002	1	29140-25		08/10/16 20:30	
Sample: F105 - A - 8		Collected: 08/04/16 11:03			Temp: 26 C		Matrix: Drinking Water		
Lab ID: 117163		Received: 08/04/16 14:50			Evidence of Cooling:N				
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0007	0.02	mg/L	0.0002	1	29140-26		08/10/16 20:32	

Abbreviations

MRL Method Reporting Limit

ND None Detected at or above the MRL

Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

Units of Measure:

mg/L Milligrams Per Liter

Chain of Custody Record-Water Samples
011-Inza Wood Middle School: 11055 SW Wilsonville Rd., Wilsonville, OR 97070

Location/Site	Date Collected	Collector's Name	Time	Date Delivered
C101-A	8/4/2016	Steve Matthias	10:21 AM	8/4/2016
D108-B	8/4/2016	Steve Matthias	10:23 AM	8/4/2016
D115-A-4	8/4/2016	Steve Matthias	10:30 AM	8/4/2016
E102-A	8/4/2016	Steve Matthias	10:35 AM	8/4/2016
E107-A-1	8/4/2016	Steve Matthias	10:38 AM	8/4/2016
E107-A-5	8/4/2016	Steve Matthias	10:41 AM	8/4/2016
E107-A-6	8/4/2016	Steve Matthias	10:45 AM	8/4/2016
F101-A	8/4/2016	Steve Matthias	10:47 AM	8/4/2016
F105-A-2	8/4/2016	Steve Matthias	10:50 AM	8/4/2016
F105-A-3	8/4/2016	Steve Matthias	10:51 AM	8/4/2016
F105-A-4	8/4/2016	Steve Matthias	10:53 AM	8/4/2016
F105-A-6	8/4/2016	Steve Matthias	10:56 AM	8/4/2016
F105-A-7	8/4/2016	Steve Matthias	10:59 AM	8/4/2016
F105-A-8	8/4/2016	Steve Matthias	11:03 AM	8/4/2016

60804136

Steve Matthias 8/4/16
 Collector's Signature Date

26°C
 No cooling
MRH 8.4.16 1450
 Laboratory Signature Date