



WEST LINN - WILSONVILLE SCHOOL DISTRICT

Water Quality Information

July 21, 2016

Dear Wood Families,

As you know, the West Linn-Wilsonville School District is testing the water in all schools this summer. As each school's lab results are made available to the District, they are being shared with families in that school.

The results from July testing at Wood Middle School show that out of 109 test locations, 13 indicated elevated levels of lead that exceed the action level of 20 parts per billion. This includes 8 lab sinks in science classrooms, 1 teacher demonstration lab sink, 3 classroom sink faucets, and 1 bubbler in a classroom sink. Results indicated that 1 classroom sink faucet has an elevated level of copper that exceeds the action level of 1,350 parts per billion.

Immediate remediation steps taken include turning water off at these locations, replacing subject fixtures and retesting. These results will be sent out to you once all remediation steps are complete. The remediation and retesting will occur before children return to school this fall.

More information about District water quality testing is available at <http://www.wlww.k12.or.us/Page/10603> .

West Linn-Wilsonville School District
Department of Operations
Tim K. Woodley, Director

22210 SW Stafford Road Tualatin OR 97062
Business: 503.673.7000 Fax: 503.673.7001

www.wlww.k12.or.us