

# PERIODIC SURVEILLANCE REPORT

Client: West Linn Wilsonville School District

Page #: 1 of 1  
Apex Job#: 10004

Campus: Stafford Primary  
Address: 19875 SW Stafford Road

Building: Main  
Date of Surveillance: March 14, 2013

AHERA Designated Person: Tim Woodley  
Person Conducting Surveillance: Amy Milligan

**SUMMARY:** Some asbestos-containing materials were removed in the summer 2004, 2005, 2009, 2010, 2011 remodel projects, Sheet flooring was removed from bathrooms and floor tile in hallways and in the cafeteria hallway and textured ceiling material was removed from the Custodian Office.

Material Description: Glued on Ceiling Tile, Lay-in Ceiling Tile  
Homogeneous area(s): Hallways  
Last Material Condition: Good  
Change in material condition: Small puncture holes were observed and slight water damage  
Change in material condition: Same

Material Description: Vinyl Asbestos Floor Tile and Mastic  
Homogeneous area(s): Hallways  
Last Material Condition: Good  
Change in material condition: one square foot of damage in the faculty restroom  
Change in material condition: Faculty restroom repaired.

Material Description: Hard Fittings on Non-Asbestos Pipe Runs  
Homogeneous area(s): Custodian closet  
Last Material Condition: Good  
Change in material condition: none, good condition

Material Description: Sheet Flooring, Vinyl Floor Tile (USA 99), Gypsum Wallboard & Plaster, Window Putty, Fire Doors, Glued on ceiling tile, Lay in ceiling tile, Cove base/Mastic, Chalkboards, Electrical Wiring Casing  
Homogeneous area(s): Various Locations  
Last Material Condition: Good: Same

SIGNATURES:

AHERA Inspector:

*Amy Milligan*

Amy Milligan

Certification # 139604

Management Planner

*Tulla Stocker*

Tulla R. Stocker

Calif. Accreditation 30293PR